Table 2, Summary of Compliance Requirements

Hillsborough County — *Revised* Draft/Proposed Permit No. 0570261-012-AV

Hillsborough County Resource Recovery Facility — Facility ID No. 0570261

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
107	Municipal Waste Combustor & Auxiliary Burners - Unit 4

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS [1]	Regulatory Citation(s)	See permit condition(s)
PM/PM_{10}	MSW	EPA Method 5	CY, 5 in 5-year period		3 1-hour test runs	No	40 CFR 60.58b(c)(9)	III.G.27. - 29.
VE (opacity)	MSW	EPA Method 9 or COMS	CY, 5 in 5-year period (COMS)		1-hour test	Yes	40 CFR 60.58b(c)(8) & Rule 62-297.310(7)(a)4., F.A.C.	III.G.27. - 29.
Cd	MSW	EPA Method 29	CY, 5 in 5-year period		3 1-hour test runs	No	40 CFR 60.58b(d)(1)(vii)	III.G.27. - 29.
Hg	MSW	EPA Method 29	CY, 5 in 5-year period		3 1-hour test runs	No	40 CFR 60.58b(d)(2)	III.G.27. - 29.
Pb	MSW	EPA Method 29	CY, 5 in 5-year period		3 1-hour test runs	No	40 CFR 60.58b(d)(1)(vii)	III.G.27. - 29.
SO_2	MSW	CEMS	daily (CEMS)		24-hour daily geometric mean	Yes	40 CFR 60.58b(e)(4)	III.G.27. - 29.
HCl	MSW	EPA Method 26 or 26A	annual [3]		1-hour	No	40 CFR 60.58b(f)(7)	III.G.27. - 29.
Dioxin/Furan	MSW	EPA Method 23	CY, 5 in 5-year period [4]		4-hours	No	40 CFR 60.58b(g)(i)-(iii)	III.G.27. - 29.
NOx	MSW	CEMS	daily (CEMS)		24-hour daily arithmetic average	Yes	40 CFR 60.58b(h)(3)	III.G.27. - 29.
CO	MSW	CEMS	daily (CEMS)		4-hour block average	Yes	40 CFR 60.58b(i)(3)	III.G.27. - 29.
ammonia slip	MSW	EPA Method CTM-027 (Conditional Test Method)	annual		3 1-hour test runs		PSD-FL-369	III.G.27. - 29.
VE - fugitive ash emissions		EPA Method 22	annual [3]		3 1-hour observations	No	40 CFR 60.58b(k)	III.G.27. - 29.
O_2/CO_2	MSW	Method 3, 3A, or 3B, or as an alternative ASME PTC-19-10-1981-Part 10	N/A		N/A	Yes	40 CFR 60.58b(b)	III.G.21.
steam flow	MSW		N/A		N/A	Yes	40 CFR 60.58b(i)(6)	III.G.6.
inlet temperature to baghouse			N/A		N/A	Yes	40 CFR 60.58b(i)(7)	III.G.33.

Notes:

"N/A" represents not applicable.

"CY" represents calendar year.

* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.

[1] CMS [=] continuous monitoring system.

[3] The CFR contained an error on testing frequency per the 01/22/2009 dated e-mail from U.S. EPA.

[4] Test at least one MWC unit annually, subject to 40 CFR 60.58b(g) requirements.