TABLE 2

SUMMARY OF COMPLIANCE REQUIREMENTS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID Nos.	Brief Description	Fuels	Pollutant Name	Emission Control	Compliance Method EPA Method	Testing Time Frequency	Min. Compliance Test Duration	See Permit Conditions
026	Turbine	Natural Gas	NO_X	Steam Injection	EPA Method 20 or 7E	Once Each Federal Fiscal Year (10/1-9/30)	3- 1 hour runs	F.15.
			VE	No Controls	EPA Method 9		30 minutes	F.15.