TABLE 2

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID Nos.	Brief Description	Fuels	Pollutant Name	Compliance Method EPA Method	Testing Time Frequency	Min. Compliance Test Duration	See Permit Conditions
015	Boilers	No. 2 Fuel Oil & Natural Gas	NOx	EPA Method 7E	Once Every Federal Fiscal Year (10/1-9/30)	3 -1 hour runs	B.16.
015 and 025		No. 2 Fuel Oil & Natural Gas	VE	EPA Method 9	Once Every Federal Fiscal Year (10/1-9/30)	30 min	B.15. & D.12.
			SO_2	ASTM methods	Each Delivery		B.18. & D.14.
023		Natural Gas	VE	EPA Method 9	Once Every Federal Fiscal Year (10/1-9/30)	30 min	D.6.