Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Charlie Crist
Governor

Jeff Kottkamp
Lt. Governor

Mimi A. Drew
Secretary

Electronically Sent- Received Receipt Requested
dave.shellhouse@sug.com

David W. Shellhouse, Vice President, Southeast Operations
Florida Gas Transmission Company
2405 Lucien Way, Suite 200
Maitland, FL 32751-7047

Re: **Draft** Air Construction Permit No.: 0830070-008-AC
REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal Project. No.: 0830070-007-AV
Compressor Station No. 17

Dear Mr. Shellhouse:

One copy of the Technical Evaluation and Preliminary Determination, the combined Public Notice, the Draft Air Construction Permit, and the REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal for the existing Compressor Station No. 17 located at 19555 NE County Road 314, Salt Springs, Marion County, is enclosed. The permitting authority's "INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL" and the "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL" are also included.

An electronic version of the DRAFT Permit will be posted on the Division of Air Resource Management's world wide web site for the United States Environmental Protection Agency (USEPA) Region 4 office's review. The web site address is:

"http://www.dep.state.fl.us/air/eproducts/ards/default.asp"

The "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL" must be published as soon as possible. Proof of publication, i.e., newspaper affidavit, must be provided to the permitting authority's office within 7 (seven) days of publication pursuant to Rule 62-110.106(5), F.A.C. Failure to publish the notice and provide proof of publication within the allotted time may result in the denial of the permits pursuant to Rule 62-110.106(11), F.A.C.

Please submit any written comments you wish to have considered concerning the permitting authority's proposed action to Jeffrey Rustin, P.E., at the above letterhead address. If you have any other questions, please contact Jeffrey Rustin, P.E., at 407-893-3335.

Sincerely,

Caroline D. Shine
Program Administrator
Air Resource Management

Date: 1/12/11

jar
Enclosures

In the Matter of an
Application for Permits by:

Florida Gas Transmission Company
2405 Lucien Way,
Suite 200
Maitland, FL 32751-7047

Draft Air Construction Permit No.: 0830070-008-AC
REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal No.: 0830070-007-AV
Compressor Station No. 17
Marion County

INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL

The Florida Department of Environmental Protection (permitting authority) gives notice of its intent to issue an Air Construction Permit and a Title V Air Operation Permit Renewal (copies of the Draft Air Construction Permit and DRAFT Title V Air Operation Permit Renewaln attached) for the Title V source detailed in the application(s) specified above and the attached Technical Evaluation and Preliminary Determination, for the reasons stated below.

The applicant, Florida Gas Transmission Company, applied on May 19, 2010, to the permitting authority for an Air Construction Permit and a Title V Air Operation Permit Renewal for the existing Compressor Station No. 17 located at 19555 NE County Road 314, Salt Springs, Marion County.

Air Construction Permit, No. 0830070-008-AC, will modify Condition No.11 in Air Construction Permit No. 0830070-003-AC and previous condition No. B20 in Air Operation Permit No. 0830070-006-AV to discontinue quarterly engine inspections of Engine 1704 and to discontinue quarterly measurements of exhaust carbon monoxide (CO) and nitrogen oxides (NO_X) from Engine 1704.

The Title V Air Operating Permit Renewal will renew the Title V Air Operation Permit and incorporate the conditions of Air Construction Permit No. 0830070-008-AC.

The permitting authority has permitting jurisdiction under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, 62-212 and 62-213. This source is not exempt from construction and Title V permitting procedures. The permitting authority has determined that an Air Construction Permit and a Title V Air Operation Permit Revision are required to construct and to commence or continue operations at the described facility.

The permitting authority intends to issue the Air Construction Permit and the Title V Air Operation Permit Renewal based on the belief that reasonable assurances have been provided to indicate that the construction activity and operation of the source will not adversely impact air quality, and the source will comply with all appropriate provisions of Chapters 62-4, 62-204, 62-210, 62-212, 62-213, 62-256, 62-257, 62-281, 62-296, and 62-297, F.A.C.

Pursuant to Sections 403.815 and 403.087, F.S., and Rules 62-110.106 and 62-210.350(3), F.A.C., you (the applicant) are required to publish at your own expense the enclosed "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL." The notice shall be published one time only as soon as possible in the legal advertisement section of a newspaper of general circulation in the area affected. For the purpose of these rules, "publication in a newspaper of general circulation in the area affected" means publication in a newspaper meeting the requirements of Sections 50.011 and 50.031, F.S., in the county where the activity is to take place. If you are uncertain that a newspaper meets these requirements, please contact the permitting authority at the address or telephone number listed below. The applicant shall provide proof of publication to the Florida Department of Environmental Protection, 3319 Maguire Blvd., Suite 232, Orlando, FL 32803 (Telephone: 407/893-3334), within 7 (seven) days of publication pursuant to Rule 62-110.106(5), F.A.C. Failure to publish the notice and provide proof of publication may result in the denial of the permits pursuant to Rule 62-110.106(11), F.A.C.

The permitting authority will issue the Air Construction Permit and the PROPOSED Title V Air Operation Permit Renewal and subsequent FINAL Title V Air Operation Permit Renewal, in accordance with the conditions of the attached Draft Air Construction Permit and the DRAFT Title V Air Operation Permit Renewal unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

EPA has agreed to treat the DRAFT Title V Permit Revnewal as a PROPOSED Title V Permit Renewal and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day period is performed after the public comment period has ended. The FINAL Title V Air Operation Permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that results in a different decision or significant change of terms or conditions.

The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:

http://www.epa.gov/region4/air/permits/Florida.htm

The permitting authority will accept written comments concerning the proposed Air Construction Permit issuance action for a period of 14 (fourteen) days from the date of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this Draft Air Construction Permit, the permitting authority shall issue a Revised Draft Air Construction Permit and require, if applicable, another Public Notice.

The permitting authority will accept written comments concerning the proposed Title V Air Operation Permit Revision issuance action for a period of 30 (thirty) days from the date of publication of the "PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL." Written comments should be provided to the permitting authority office. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this REVISED DRAFT/PROPOSED Title V Air Operation Permit Revision, the permitting authority shall issue a Revised REVISED DRAFT/PROPOSED Title V Air Operation Permit Revision and require, if applicable, another Public Notice.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, FL 32399-3000 (Telephone: 850/245-2242, Fax: 850/245-2303). Petitions filed by the permits' (construction and revision) applicant or any of the parties listed below must be filed within 14 (fourteen) days of receipt of this notice of intent. Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 (fourteen) days of publication of the public notice or within 14 (fourteen) days of receipt of this notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within 14 (fourteen) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the appropriate time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205, F.A.C.

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address, and telephone number of the petitioner; the name, address and telephone number of the petitioner's representative, if any, which shall be the address for service purposes during the course of the proceeding; and an explanation of how the petitioner's substantial interests will be affected by the agency determination;

(c) A statement of how and when each petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so indicate;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle the petitioner to relief;

(f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application(s) have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation will not be available in this proceeding.

Finally, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any Title V permit. Any petition shall be based only on objections to the Title V permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any Title V permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

Executed in Orlando, Florida.

STATE OF FLORIDA DEPARTMENT
OF ENVIRONMENTAL PROTECTION

Caroline D. Shine
Program Administrator
Air Resources Management

PUBLIC NOTICE OF INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
Central District

Draft Air Construction Permit No.: 0830070-008-AC
REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal Project No.: 0830070-007-AV
Florida Gas Transmission Company
Compressor Station No. 17
Marion County

The Florida Department of Environmental Protection (permitting authority) gives notice of its intent to issue an Air Construction Permit and a Title V Air Operation Permit Renewal to Florida Gas Transmission Company for the existing Compressor Station No. 17 located at 19555 NE County Road 314, Salt Springs, Marion County. The applicant's name and address are: Florida Gas Transmission Company, 2405 Lucien Way, Suite 200, Maitland, FL 32751-7047, Attention: Dave W. Shellhouse, Vice President, Southeast Operations.

Air Construction Permit, No. 0830070-008-AC, will modify Condition No.11 in Air Construction Permit No. 0830070-003-AC and previous condition No. B20 in Air Operation Permit No. 0830070-006-AV to discontinue quarterly engine inspections of Engine 1704 and to discontinue quarterly measurements of exhaust carbon monoxide (CO) and nitrogen oxides (NO_X) from Engine 1704.

The Title V Air Operation Permit Renewal will renew the Title V Air Operation Permit and incorporate the conditions of Air Construction Permit No. 0830070-008-AC.

The permitting authority will issue the Air Construction Permit and the REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal and subsequent FINAL Title V Air Operation Permit Renewal, in accordance with the conditions of the Draft Air Construction Permit and the REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal unless a response received in accordance with the following procedures results in a different decision or significant change of terms or conditions.

EPA has agreed to treat the DRAFT Title V Permit Renewal as a PROPOSED Title V Permit Renewal and to perform its 45-day review provided by the law and regulations concurrently with the public comment period. Although EPA's 45-day review period will be performed concurrently with the public comment period, the deadline for submitting a citizen petition to object to the EPA Administrator will be determined as if EPA's 45-day period is performed after the public comment period has ended. The FINAL Title V Air Operation Permit will be issued after the conclusion of the 45-day EPA review period so long as no adverse comments are received that results in a different decision or significant change of terms or conditions.

The status regarding EPA's 45-day review of this project and the deadline for submitting a citizen petition can be found at the following website address:

http://www.epa.gov/region4/air/permits/Florida.htm

The permitting authority will accept written comments concerning the proposed Draft Air Construction Permit issuance action for a period of 14 (fourteen) days from the date of publication of this Public Notice. Written comments should be provided to the Florida Department of Environmental Protection, 3319 Maguire Blvd., Suite 232, Orlando, FL 32803. Any written comments filed shall be made available for public inspection. If written comments received result in a significant change in this Draft Air Construction Permit, the permitting authority shall issue a Revised Draft Air Construction Permit and require, if applicable, another Public Notice.

The Permitting Authority will accept written comments concerning the REVISED DRAFT/PROPOSED Title V Air Operation Permit Revision for a period of thirty (30) days from the date of publication of this Public Notice. Written comments must be post-marked and all facsimile comments must be received by the close of business (5:00 pm), on or before the end of this 30-day period, by the Permitting Authority at Florida Department of Environmental Protection, 3319 Maguire Blvd., Suite 232, Orlando, FL 32803, telephone (407/893-3334) or facsimile (850/412-0455). As part of his or her comments, any person may also request that the Permitting

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL (including the combined PUBLIC NOTICE, the Draft Air Construction Permit and the REVISED DRAFT/PROPOSED Title V Air Operation Permit package) and all copies were sent by certified mail or electronically (with Received Receipt) before the close of business on 1/12/11 to the person(s) listed:

Electronically Sent- Received Receipt Requested
dave.shellhouse@sug.com

David W. Shellhouse, Vice President, Southeast Operations
Florida Gas Transmission Company
2405 Lucien Way, Suite 200
Maitland, FL 32751-7047

In addition, the undersigned duly designated deputy agency clerk hereby certifies that copies of this INTENT TO ISSUE AN AIR CONSTRUCTION PERMIT AND A TITLE V AIR OPERATION PERMIT RENEWAL (including the combined PUBLIC NOTICE, the Draft Air Construction Permit and the REVISED DRAFT/PROPOSED Title V Air Operation Permit) were sent by U.S. mail or electronically (with Received Receipt) on the same date to the person(s) listed or as otherwise noted:

Thomas W. Davis, P.E., Environmental Consulting & Technology, Inc. **(tdavis@ectinc.com)**
Janice Taylor, Division Engineer-Environmental Services **(Janice.Taylor@sug.com)**
Barbara Friday, BAR **[Barbara.Friday@dep.state.fl.us]** (for posting with Region 4, USEPA)

Clerk Stamp

FILING AND ACKNOWLEDGMENT FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency Clerk, receipt of which is hereby acknowledged.

D L Agner 1/12/11
(Clerk) (Date)

Authority hold a public meeting on this permitting action. If the Permitting Authority determines there is sufficient interest for a public meeting, it will publish notice of the time, date, and location in the Florida Administrative Weekly (http://faw.dos.state.fl.us/) and in a newspaper of general circulation in the area affected by the permitting action. For additional information, contact the Permitting Authority at the above address or phone number. If written comments or comments received at a public meeting result in a significant change to the REVISED DRAFT Title V Air Operation Permit Renewal, the Permitting Authority shall issue a Revised REVISED DRAFT/PROPOSED Title V Air Operation Permit Renewal and require, if applicable, another Public Notice. All comments filed will be made available for public inspection.

A person whose substantial interests are affected by the proposed permitting decision may petition for an administrative hearing in accordance with Sections 120.569 and 120.57 of the Florida Statutes (F.S.). The petition must contain the information set forth below and must be filed (received) in the Office of General Counsel at 3900 Commonwealth Boulevard, Mail Station 35, Tallahassee, FL 32399-3000 (Telephone: 850/245-2242, Fax: 850/245-2303). Petitions filed by any persons other than those entitled to written notice under Section 120.60(3), F.S., must be filed within 14 (fourteen) days of publication of the public notice or within 14 (fourteen) days of receipt of the notice of intent, whichever occurs first. Under Section 120.60(3), F.S., however, any person who asked the permitting authority for notice of agency action may file a petition within 14 (fourteen) days of receipt of that notice, regardless of the date of publication. A petitioner shall mail a copy of the petition to the applicant at the address indicated above, at the time of filing. The failure of any person to file a petition within the applicable time period shall constitute a waiver of that person's right to request an administrative determination (hearing) under Sections 120.569 and 120.57, F.S., or to intervene in this proceeding and participate as a party to it. Any subsequent intervention will be only at the approval of the presiding officer upon the filing of a motion in compliance with Rule 28-106.205 of the Florida Administrative Code (F.A.C.).

A petition that disputes the material facts on which the permitting authority's action is based must contain the following information:

(a) The name and address of each agency affected and each agency's file or identification number, if known;

(b) The name, address and telephone number of the petitioner; name address and telephone number of the petitioner's representative, if any., which shall be the address for service purposes during the course of the proceeding; and an explanation of how petitioner's substantial rights will be affected by the agency determination;

(c) A statement of how and when the petitioner received notice of the agency action or proposed action;

(d) A statement of all disputed issues of material fact. If there are none, the petition must so state;

(e) A concise statement of the ultimate facts alleged, as well as the rules and statutes which entitle petitioner to relief;

(f) A statement of the specific rules or statutes the petitioner contends require reversal or modification of the agency's proposed action; and,

(g) A statement of the relief sought by the petitioner, stating precisely the action petitioner wishes the agency to take with respect to the agency's proposed action.

A petition that does not dispute the material facts upon which the permitting authority's action is based shall state that no such facts are in dispute and otherwise shall contain the same information as set forth above, as required by Rule 28-106.301, F.A.C.

Because the administrative hearing process is designed to formulate final agency action, the filing of a petition means that the permitting authority's final action may be different from the position taken by it in this notice of intent. Persons whose substantial interests will be affected by any such final decision of the permitting authority on the application(s) have the right to petition to become a party to the proceeding, in accordance with the requirements set forth above.

Mediation is not available for this proceeding.

In addition to the above, pursuant to 42 United States Code (U.S.C.) Section 7661d(b)(2), any person may petition the Administrator of the EPA within 60 (sixty) days of the expiration of the Administrator's 45 (forty-five) day review period as established at 42 U.S.C. Section 7661d(b)(1), to object to issuance of any Title V permit. Any petition shall be based only on objections to the Title V permit that were raised with reasonable specificity during the 30 (thirty) day public comment period provided in this notice, unless the petitioner demonstrates to the Administrator of the EPA that it was impracticable to raise such objections within the

comment period or unless the grounds for such objection arose after the comment period. Filing of a petition with the Administrator of the EPA does not stay the effective date of any Title V permit properly issued pursuant to the provisions of Chapter 62-213, F.A.C. Petitions filed with the Administrator of EPA must meet the requirements of 42 U.S.C. Section 7661d(b)(2) and must be filed with the Administrator of the EPA at: U.S. EPA, 401 M Street, S.W., Washington, D.C. 20460.

A complete project file is available for public inspection during normal business hours, 8:00 a.m. to 5:00 p.m., Monday through Friday, except legal holidays, at:

Permitting Authority:
Florida Department of Environmental Protection
3319 Maguire Blvd., Suite 232
Orlando, FL 32803
Telephone: 407/893-3334
Fax: 850/412-0455

The complete project file includes the Technical Evaluation and Preliminary Determination and associated Draft Air Construction Permit and REVISED DRAFT/PROPOSED Title V Air Operation Permit Revision, the application(s), and the information submitted by the responsible official, exclusive of confidential records under Section 403.111, F.S. Interested persons may contact Jeffrey Rustin, P.E., at the above address, or call 407/894-3334 for additional information.

TECHNICAL EVALUATION
&
PRELIMINARY DETERMINATION

APPLICANT

Florida Gas Transmission Company
2405 Lucien Way, Suite 200
Maitland, FL 32751-7047

Compressor Station No. 17

Facility ID No. 0830070

PROJECT

Project No. 0830070-007-AV
Application for Title V Air Operation Permit Renewal
Project Name: Renewal

COUNTY

Marion County, Florida

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Air Resource Management
Central District Office
Orlando, Florida 32803-3767

November 2 and 3, 2010
Revised December 29, 2010

Prepared by Jeffrey Rustin, P.E.

GENERAL PROJECT INFORMATION

Air Pollution Regulations

Projects at stationary sources with the potential to emit air pollution are subject to the applicable environmental laws specified in Section 403 of the Florida Statutes (F.S.). The statutes authorize the Department of Environmental Protection (Department) to establish regulations regarding air quality as part of the Florida Administrative Code (F.A.C.), which includes the following applicable chapters: 62-4 (Permits); 62-204 (Air Pollution Control - General Provisions); 62-210 (Stationary Sources - General Requirements); 62-212 (Stationary Sources - Preconstruction Review); 62-213 (Operation Permits for Major Sources of Air Pollution); 62-296 (Stationary Sources - Emission Standards); and 62-297 (Stationary Sources - Emissions Monitoring). Specifically, air construction permits are required pursuant to Rules 62-4, 62-210 and 62-212, F.A.C.

In addition, the U. S. Environmental Protection Agency (EPA) establishes air quality regulations in Title 40 of the Code of Federal Regulations (CFR). Part 60 specifies New Source Performance Standards (NSPS) for numerous industrial categories. Part 61 specifies National Emission Standards for Hazardous Air Pollutants (NESHAP) based on specific pollutants. Part 63 specifies NESHAP based on the Maximum Achievable Control Technology (MACT) for numerous industrial categories. The Department adopts these federal regulations on a quarterly basis in Rule 62-204.800, F.A.C.

Glossary of Common Terms

Because of the technical nature of the project, the permit contains numerous acronyms and abbreviations, which are defined in Appendix A of this permit.

I. Project Description:

A. Applicant:

Mr. David W. Shellhouse, Vice President, Southeast Operations
Florida Gas Transmission Company
2405 Lucien Way, Suite 200
Maitland, FL 32751-7047

B. Professional Engineer:

Mr. Thomas W. Davis, P.E.
Environmental Consulting and Technology, Inc.
3701 Northeast 98th Street
Gainesville, FL 32606-5004

C. Project Location:

Compressor Station No. 17
19555 NE County Road 314
Salt Springs, FL 32134-3200

D. Project Summary:

The purpose of this project is modify Condition No. 11 in Air Construction Permit No. 0830070-003-AC and previous condition No. B20 in Air Operation Permit No. 0830070-006-AV to discontinue quarterly engine inspections of Engine 1704 and to discontinue quarterly measurements of exhaust carbon monoxide (CO) and nitrogen oxides (NO_X) from Engine 1704. The draft permit was revised to address comments from the consultant on behalf of the applicant. Three of the engines (EU 001, EU 002, and EU 003) were changed from regulated emission units to unregulated emission units. These engines were not subject to any unit-specific emission standards, monitoring provisions, or testing requirements. Additionally, Appendix U-1 and Appendix ICE were added. Condition No. 16 (facility-wide) was modified, some language was added. The Internal Combustion engines are not subject to Subpart IIII because they are existing units and are not subject to Subpart ZZZZ because of Section 63.6590 (3) and (3)(ii), as listed in the following sentence. From Subpart ZZZZ, Section 63.6590 (3) and (3)(ii) - the following stationary RICE do not have to meet the requirements of this subpart and of subpart A of this part, including initial notification requirements: (ii) Existing spark ignition 4 stroke lean burn (4SLB) stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions.

E. Application Information:

Application Received on: 05/19/2010
Additional Information Requested on: 07/16/2010
Additional Information Received on: 08/06/2010
Application Complete: 08/06/2010

II. PSD Applicability for Project

As provided in the application, the following table summarizes potential emissions and PSD applicability for the project.

Table A. Potential Emissions (Tons/Year) and PSD Applicability

Pollutant	Project Potential Emission (tpy)	Significant Emissions Rate (tpy)	Subject to PSD?
NO_X	0	40	No
CO	0	100	No

VOC	0	40	No
SO_2	0	40	No
PM/PM_{10}	0	25/15	No

As shown in the above table, total project emissions will not exceed the PSD significant emissions rates; therefore, the project is not subject to PSD preconstruction review; **however, any future facility permitting action after the issuance of the Final Title Air V Operation Permit No. 0830070-007-AV or the issuance of Final construction permit No. 0830070-008-AC that will allow an increase of facility emissions (potential to emit) or add additional regulated emission units to the facility will be subject to PSD Review.**

III. Rule Applicability

Rules 62-4, 62-210, 62-296, 62-297, F.A.C. apply.

IV. Summary of Emissions

No increase in emissions due to the modification of the condition authorized by the construction permit.

V. Federal NSPS and/or NESHAP Provisions

A. NSPS, 40 CFR 60 Subpart A, General Provisions

B. NSPS, 40 CFR 60 Subpart GG, Standards of Performance for Stationary Gas Turbines.

C. NESHAP, 40 CFR 63 Subpart A, General Provisions

D. NESHAP, 40 CFR 60 Subpart ZZZZ, National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

VI. Conclusions

The emission limits proposed by the applicant will meet all of the requirements of Chapters 62-204 through 297, F.A.C.

The General and Specific Conditions listed in the proposed permit (attached) will assure compliance with all the applicable requirements of Chapters 62-204 through 297, F.A.C.

VII. Preliminary Determination

The Department makes a preliminary determination that the proposed project will comply with all applicable state and federal air pollution regulations as conditioned by the draft

permit. This determination is based on a technical review of the complete application, reasonable assurances provided by the applicant, and the conditions specified in the draft permit. Additional details of this analysis may be obtained by contacting the project engineer at the Florida Department of Environmental Protection Air Resource Management, Central District Office, 3319 Maguire Blvd., Suite 232, Orlando, Florida 32803-3767, 407/893-3334.

STATEMENT OF BASIS

Florida Gas Transmission Company
Compressor Station No. 17
Facility ID No.: 0830070
Marion County

Title V Air Operation Permit Renewal
REVISED DRAFT/PROPOSED Permit Project No.: 0830070-007-AV

This Title V Air Operation Permit Renewal is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210, and 62-213. The above named permittee is hereby authorized to perform the work or operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

The subject of this permit is for the renewal of Title V Air Operation Permit and the incorporation of an air construction permit, No. 0830070-003-AC. This facility consists of five natural gas fired internal combustion engines and one gas turbine engine. Four internal combustion engines are rated at 2000 bhp and are manufactured by Cooper-Bessemer, Model LS-8-SG. One internal combustion engine is rated at 2400 bhp and is manufactured by Dresser-Rand, Model 412KVSRA. The gas turbine engine is rated at 15,700 bhp and is manufactured by Nuovo Pigone. This facility is part of a natural gas pipeline system serving the State of Florida. The applicable emission limitations are as follows: The four 2000 bhp engines are each subject to the general visible emissions limit per Rule 62-210-320(4)(b)1., F.A.C. Visible emissions for the 2400 bhp engine are limited to 10% opacity per construction permit AC42-189455 and Title V permit renewal application received October 20, 2000. Hourly and annual emissions limits for the 2400 bhp engine are as follows, per construction permit AC42-189455 and Title V permit renewal application received June 20, 2005:

Pollutant	Lbs/hr	Tons/yr
Nitrogen Oxides	10.6	46.3
Carbon Monoxide	14.8	64.9
VOC (non-methane)	9.0	39.4
Particulates (TSP)	0.21	0.9
Particulates (PM10)	0.21	0.9
Sulfur Dioxide	0.49	2.2
HAPs	1.04	4.5

Hourly and annual emissions limits for the 15,700 bhp combustion turbine engine are as follows, per construction permit 0830070-005-AC and Title V permit renewal application received June 20, 2005:

Pollutant	Lbs/hr	Tons/yr
Nitrogen Oxides	14.1	61.76
Carbon Monoxide	7.03	30.79
Sulfur Dioxide	3.7	16.21

The facility potential (potential to emit) emissions for total HAPs is 26.84 tons/yr.

The draft permit was revised to address comments from the consultant on behalf of the applicant. Three of the engines (EU 001, EU 002, and EU 003) were changed from regulated emission units to unregulated emission units. These engines were not subject to any unit-specific emission standards, monitoring provisions, or testing requirements. Additionally, Appendix U-1 and Appendix ICE were added. Condition No. 16 (facility-wide) was modified, some language was added. Internal Combustion Engines at the site are not subject to the requirements listed in 40 CFR 60 Subpart IIII and 40 CFR 63 Subpart ZZZZ. CAM does not apply. Also included in this permit are unregulated emission units and/or activities.

Based on the Title V permit renewal application received May 19, 2010, this facility is a major source of hazardous air pollutants (HAPs).

Florida Gas Transmission Company
Compressor Station No. 17
Facility ID No.: 0830070
Marion County

Title V Air Operation Permit Renewal

REVISED DRAFT/PROPOSED Permit Project No.: 0830070-007-AV

Permitting and Compliance Authority:
Florida Department of Environmental Protection
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803
Telephone: 407/893-3333
Fax: 850/412-0455

Title V Air Operation Permit Renewal

REVISED DRAFT/PROPOSED Permit No.: 0830070-007-AV

Table of Contents

Section **Page Number**

Placard Page 1

I. Facility Information ..... 2 - 3
- A. Facility Description.
- B. Summary of Emissions Unit ID No(s). and Brief Description(s).
- C. Relevant Documents.

II. Facility-wide Conditions ..... 4 - 6

III. Emissions Unit(s) and Conditions
- A. Emissions Unit 005 – I.C. Engine Nos. 1705 ..... 7 - 9
- B. Emissions Unit 004 – Modified I.C. Engine No. 1704 ..... 10 - 14
- C. Emissions Unit 008 – Gas Turbine No. 1706 ..... 15 – 20

Florida Gas Transmission Company
Compressor Station No. 17
Facility ID No.: 0830070
Marion County

Title V Air Operation Permit Renewal

REVISED DRAFT/PROPOSED Permit Project No.: 0830070-007-AV

Permitting and Compliance Authority:
Florida Department of Environmental Protection
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803
Telephone: 407/893-3333
Fax: 850/412-0455

Title V Air Operation Permit Renewal

REVISED DRAFT/PROPOSED Permit No.: 0830070-007-AV

Table of Contents

Section **Page Number**

Placard Page 1

I. Facility Information ..... 2 - 3
- A. Facility Description.
- B. Summary of Emissions Unit ID No(s). and Brief Description(s).
- C. Relevant Documents.

II. Facility-wide Conditions ..... 4 - 6

III. Emissions Unit(s) and Conditions
- A. Emissions Unit 005 – I.C. Engine Nos. 1705 ..... 7 - 9
- B. Emissions Unit 004 – Modified I.C. Engine No. 1704 ..... 10 - 14
- C. Emissions Unit 008 – Gas Turbine No. 1706 ..... 15 – 20

Florida Department of Environmental Protection

Central District
3319 Maguire Boulevard, Suite 232
Orlando, Florida 32803-3767

Rick Scott
Governor

Jennifer Carroll
Lt. Governor

Mimi A. Drew
Secretary

Permittee:
Florida Gas Transmission Co.
Post Office Box 4967
Houston, Texas 77210-4967

REVISED DRAFT/PROPOSED Permit No.: 0830070-007-AV
Facility ID No.: 0830070
SIC No(s).: 49, 4922
Project: Title V Air Operation Permit Renewal

The purpose of this permit is to renew the Title V Air Operation Permit and incorporate construction permit, No. 0830070-008-AC. This existing facility is located at 19555 NE County Road 314, Salt Springs, Marion County; UTM Coordinates: Zone 17, 418.8 km East and 3240.9 km North; and, Latitude: 29° 17' 47" North and Longitude: 81° 50' 08" West.

This Title V Air Operation Permit Renewal is issued under the provisions of Chapter 403, Florida Statutes (F.S.), and Florida Administrative Code (F.A.C.) Chapters 62-4, 62-210 and 62-213. The above named permittee is hereby authorized to operate the facility shown on the application and approved drawing(s), plans, and other documents, attached hereto or on file with the permitting authority, in accordance with the terms and conditions of this permit.

Referenced attachments made a part of this permit:
Appendix A-2 General Provisions (NSPS)
Appendix A-3 General Provisions (NESHAP)
Appendix GG, NSPS Subpart GG – Standards of Performance for Stationary Gas Turbines
Appendix I-1, List of Insignificant Emission Units and/or Activities
Appendix ICE, Requirements for Internal Combustion Engines
Appendix TV-6, TITLE V CONDITIONS version dated 06/23/06
Appendix SS-1, STACK SAMPLING FACILITIES version dated 10/07/96
Appendix U-1, List of Unregulated Emission Units and/or Activities
Table 297.310-1, CALIBRATION SCHEDULE version dated 10/07/96

Renewal Effective Date: TBD
Renewal Application Due Date: TBD
Expiration Date: TBD

DRAFT PERMIT

Caroline D. Shine
Program Administrator
Air Resource Management

CS/jar

Section I. Facility Information.

Subsection A. Facility Description.

This facility consists of five natural gas-fired reciprocating internal combustion engines and one natural gas-fired turbine engine. Four reciprocating engines (emissions units 001 – 004) are rated at 2000 brake horse power (bhp) and are manufactured by Cooper-Bessemer, Model LS-8-SG; one reciprocating engine (emissions unit 005) is rated at 2400 bhp and is manufactured by Dresser-Rand, Model 412KVSRA; the natural gas-fired turbine engine (emissions unit 008) is rated at 15,700 bhp and is manufactured by Nuovo Pignone, Model PGT-10B.

Also included in this permit are miscellaneous unregulated emissions units and/or activities identified as emissions unit 009.

Based on the Title V Air Operation Permit Renewal application received October 30, 2000, this facility is a major source of hazardous air pollutants (HAPs).

Subsection B. Summary of Emissions Unit ID No(s). and Brief Description(s).

Existing Compressor station 17 consists of the following six compressor engines, three regulated and three unregulated.

E.U. ID No.	Brief Description
-004	**FGT No. 1704**: One 2000 bhp natural gas-fired reciprocating internal combustion engine (Cooper-Bessemer Model No. LS-8-SG)
-005	**FGT No. 1705**: One 2400 bhp natural gas-fired reciprocating internal combustion engine (Dresser-Rand Model No. 412KVSRA)
-008	**FGT No. 1706**: One 15,700 bhp natural gas-fired turbine engine (Nuovo Pignone Model No. PGT-10B)

{Note: Emissions units 006 and 007 are "inactive". These were the old full-time electrical generators, which have been retired.}

Unregulated Emissions Units and/or Activities (see Appendix U-1)

-001	**FGT No. 1701**: One 2000 bhp natural gas-fired reciprocating internal combustion engine (Cooper-Bessemer Model No. LS-8-SG)
-002	**FGT No. 1702**: One 2000 bhp natural gas-fired reciprocating internal combustion engine (Cooper-Bessemer Model No. LS-8-SG)
-003	**FGT No. 1703**: One 2000 bhp natural gas-fired reciprocating internal combustion engine (Cooper-Bessemer Model No. LS-8-SG)

Please reference the Permit No., Facility ID No., and appropriate Emissions Unit(s) ID No(s). on all correspondence, test report submittals, applications, etc.

Subsection C. Relevant Documents.

The documents listed below are not a part of this permit; however, they are specifically related to this permitting action.

These documents are provided to the permittee for information purposes only:
Appendix A-1: Abbreviations, Acronyms, Citations, and Identification Numbers
Appendix H-1: Permit History

These documents are on file with the permitting authority:
Initial Title V Air Operation Permit issued February 18, 1998
Application for a Title V Air Operation Permit Renewal received July 10, 2002
Additional Information Request dated September 4, 2002
Additional Information Response received November 20, 2002
Application for a Title V Air Operation Permit Renewal received June 20, 2005.
Application for a Title V Air Operation Permit Renewal and air construction permit received May 19, 2010.

Section II. Facility-wide Conditions.

The following conditions apply facility-wide:

1. APPENDIX TV-6, TITLE V CONDITIONS, is a part of this permit.

2. General Pollutant Emission Limiting Standards. Objectionable Odor Prohibited. No person shall cause, suffer, allow, or permit the discharge of air pollutants which cause or contribute to an objectionable odor.
[Rule 62-296.320(2), F.A.C.]

3. General Particulate Emission Limiting Standards. General Visible Emissions Standard. Except for emissions units that are subject to a particulate matter or opacity limit set forth or established by rule and reflected by conditions in this permit, no person shall cause, let, permit, suffer or allow to be discharged into the atmosphere the emissions of air pollutants from any activity, the density of which is equal to or greater than that designated as Number 1 on the Ringelmann Chart (20 percent opacity). EPA Method 9 is the method of compliance pursuant to Chapter 62-297, F.A.C.
[Rules 62-296.320(4)(b)1. & 4., F.A.C.]

4. Prevention of Accidental Releases (Section 112(r) of CAA).

a. The permittee shall submit its Risk Management Plan (RMP) to the Chemical Emergency Preparedness and Prevention Office (CEPPO) RMP Reporting Center when, and if, such requirement becomes applicable. Any Risk Management Plans, original submittals, revisions or updates to submittals, should be sent to:

RMP Reporting Center
Post Office Box 1515
Lanham-Seabrook, Maryland 20703-1515
301/429-5018

and,

b. The permittee shall submit to the permitting authority Title V certification forms or a compliance schedule in accordance with Rule 62-213.440(2), F.A.C.
[40 CFR 68]

5. Unregulated Emissions Units and/or Activities. Appendix U-1, List of Unregulated Emissions Units and/or Activities, is a part of this permit.
[Rule 62-213.440(1), F.A.C.]

6. General Pollutant Emission Limiting Standards. Volatile Organic Compounds (VOC) Emissions or Organic Solvents (OS) Emissions. The permittee shall allow no person to store, pump, handle, process, load, unload or use in any process or installation, volatile organic compounds (VOC) or organic solvents (OS) without applying known and existing vapor emission control devices or systems deemed necessary and ordered by the Department.
[Rule 62-296.320(1)(a), F.A.C.]

7. Emissions of Unconfined Particulate Matter. Pursuant to Rule 62-296.320(4)(c), F.A.C., and the application, this facility has **no** emissions of unconfined particulate matter **(see Condition 57. of APPENDIX TV-6, TITLE V CONDITIONS).**
[Rule 62-296.320(1)(a), F.A.C.]

8. When appropriate, any recording, monitoring, or reporting requirements that are time-specific shall be in accordance with the effective date of the permit, which defines day one.
[Rule 62-213.440, F.A.C.]

9. Annual Statement of Compliance. The annual statement of compliance pursuant to Rule 62-213.440(3)(a)2., F.A.C., shall be submitted to the Department and EPA within 60 (sixty) days after the end of the calendar year using DEP Form No. 62-213.900(7), F.A.C.
[Rules 62-213.440(3) and 62-213.900, F.A.C.]

{Permitting Note: This condition implements the requirements of Rules 62-213.440(3)(a)2. & 3., F.A.C. (see Condition 51. of APPENDIX TV-6, TITLE V CONDITIONS)}

10. The permittee shall submit all compliance related notifications and reports required of this permit to the Department's Central District air compliance section:

Department of Environmental Protection
Central District Office
3319 Maguire Boulevard
Orlando, Florida 32803
Telephone: 407/893-3333; Fax: 850/412-0455

11. Any reports, data, notifications, certifications, and requests required to be sent to the United States Environmental Protection Agency, Region 4, should be sent to:

United States Environmental Protection Agency
Region 4
Air, Pesticides & Toxics Management Division
Air and EPCRA Enforcement Branch
Air Compliance Section
61 Forsyth Street
Atlanta, Georgia 30303-8960
Telephone: 404/562-9155; Fax: 404/562-9163

12. Certification by Responsible Official (RO). In addition to the professional engineering certification required for applications by Rule 62-4.050(3), F.A.C., any application form, report, compliance statement, compliance plan and compliance schedule submitted pursuant to Chapter 62-213, F.A.C., shall contain a certification signed by a responsible official that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. Any responsible official who fails to submit any required information or who has submitted incorrect information shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary information or correct information.[Rule 62-213.420(4), F.A.C.]

13. Annual Operating Report. The owner or operator shall complete DEP Form No. 62-210.900(5), F.A.C., "Annual Operating Report for Air Pollutant Emitting Facility," for each calendar year and submit it either electronically using the latest Department Annual Operating Report software or by hard copy to the air compliance section of this office **by April 1** of the

following year in accordance with Rule 62-210.370(3), F.A.C. If the report is submitted using the Department's electronic annual operating report software, there is no requirement to submit a copy to any DEP or local air program office. The emissions shall be computed in accordance with the provisions of Rule 62-210.370(2), F.A.C., for the purposes of the annual operating report. [Rule 62-210.370(3), F.A.C.]

14. Annual Emissions Fee Form and Fee. The annual Title V emissions fees are due (postmarked) by March 1st of each year. The completed form and calculated fee shall be submitted to: Major Air Pollution Source Annual Emissions Fee, P.O. Box 3070, Tallahassee, Florida 32315-3070. The forms are available for download by accessing the Title V Annual Fee On-Line Information Center at the following Internet web site: http://www.dep.state.fl.us/air/emission/tvfee.htm..
[Rule 62-213.205, F.A.C.]

15. At least 225 days prior to the expiration date of this operation permit, the permittee shall submit to this office four copies of the air permit application, DEP Form No. 62-210.900(1).
[Rule 62-4.090(1), F.A.C.]

16. PSD Review: This facility is an existing PSD major stationary source. Any future facility permitting action after the issuance of the Final Title V Air Operation Permit No. 0830070-007-AV or the issuance of Final construction permit No. 0830070-008-AC that will allow an increase of facility emissions (potential to emit) or add additional regulated emission units to the facility will be subject to PSD Applicability Review. New projects at the facility exceeding the PSD significant emission rates are subject to PSD Preconstruction Review.
[Rule 62-4.070, F.A.C.]

Section III. Emissions Unit(s) and Conditions.

Subsection A. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-005	**FGT No. 1705**: One 2400 bhp natural gas-fired reciprocating internal combustion engine (Dresser-Rand Model No. 412KVSRA)

The emissions unit is part of a natural gas pipeline system serving the State of Florida.

The following specific conditions apply to the emissions unit(s) listed above:

A1. NESHAP Requirements: The Internal Combustion Engine (EU ID No. -005, FGT No. 1705) is subject to the provisions of 40 CFR Part 63, Subpart A – General Provisions (see Appendix A-3 General Provisions (NESHAP) and 40 CFR Part 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (see Appendix ICE).

{Permitting Note: The engine is an "affected unit" as defined in Subpart ZZZ, but the engine is not subject to any specific requirement of Subpart ZZZZ at this time. It was constructed before the applicability dates in Subpart ZZZZ for new engines.}

Essential Potential to Emit (PTE) Parameters

A2. Capacity. The maximum natural gas consumption for engine number 1705 shall not exceed 20,569 scf/hr, and the maximum heat input shall not exceed 21.19 MMBTU/hr.
[Rule 62-210.200, (PTE), F.A.C., and 0830070-002-AV]

A3. Methods of Operation. Engine Number 1705 is allowed to use natural gas only.
[Rule 62.210.200, (PTE), F.A.C.]

A4. Hours of Operation. Engine Number 1705 is allowed to operate continuously.
[Rule 62-210.200, (PTE), F.A.C.]

A5. Emissions Unit Operating Rate Limitation After Testing. See specific condition No. A14.
[Rule 62-297.310(2), F.A.C.]

Emission Limitations and Standards

A6. The maximum allowable emissions from engine number 1705 shall not exceed the emission rates as follows:

Pollutant	Lbs/hr	Tons/yr	Emission factor
Nitrogen Oxides (NO_X)	10.6	46.3	2.0 g/bhp-hr
Carbon Monoxide (CO)	14.8	64.9	2.8 g/bhp-hr
Volatile Organic Compounds, non-	9.0	39.4	1.7 g/bhp-hr

methane (VOC)			
Particulates (TSP)	0.21	0.9	29 lbs/MMscf
Particulates (PM10)	0.21	0.9	29 lbs/MMscf
Sulfur Dioxide (SO_2)	0.49	2.2	8.27 gr S/100 scf

[Construction permit AC42-189455]

A7. Visible emissions shall not exceed 10 percent opacity from Engine No. 1705.
[Construction permits AC42-189455 and 0830070-002-AV]

A8. See facility-wide condition number 3 on page 4 for the visible emission limitation for the other emission units.

Test Methods and Procedures

A9. Engine number 1705 shall demonstrate compliance with its emission limits for each affected pollutant during each fiscal year (October 1st to September 30th). [Rule 62-297.310(7)(a)4., F.A.C.]

A10. Compliance with the NO_X, CO, visible emissions, and VOC standards shall be determined by the following reference methods as described in 40 CFR 60, Appendix A and adopted by reference in Rule 62-297.401, F.A.C.:

a) Method 1 Sample and Velocity Traverse
b) Method 2 Volumetric Flow Rate
c) Method 3A Gas Analysis
d) Method 7E Determination of Nitrogen Oxides Emissions from Stationary Sources
e) Method 9 Determination of the Opacity of the Emissions from Stationary Sources
f) Method 10 Determination of Total Gaseous Nonmethane Organic Emissions as Carbon
g) Method 25A Determination of Total Gaseous Organic Concentration using a Flame Ionization Analyzer

A11. Compliance with the SO_2 emission limit can be demonstrated by calculations based on fuel analysis using ASTM D1072-80, D3031-81, D4084-82, or D3246-81 or other FDEP approved test methods for sulfur content of gaseous fuels.

A12. Initial compliance with the VOC emission limits was demonstrated by EPA Method 25A, thereafter, compliance with the VOC emission limits is assumed, provided the CO allowable emission limit is not exceeded. Test results will be the average of three valid runs.
[Construction permits AC42-189455, operating permit AO42-191302, and Rule 62-297.401, F.A.C.]

A13. The owner or operator shall notify the Department (the air compliance section of this office), at least 15 days prior to the date on which each formal compliance test is to begin, the date, time and place of such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
[Rule 62-297.310(7)(a)9, F.A.C.]

A14. Testing of emissions shall be conducted with the emissions unit operation at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the minimum permitted capacity; in this case, subsequent emissions unit operation is limited to 110 percent of the test load until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity. [Rule 62-297.310(2)& (2) (b), F.A.C.]

A15. Reports of the required test report shall be filed with the air compliance section of this office as soon as practical but no later than 45 days after the last test is completed.
[Rules 62-297.310(8), F.A.C.]

Monitoring of Operations

A16. Required Equipment. The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
[Rule 62-297.310(5), F.A.C.]

A17. Accuracy of Equipment. Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10 percent of its true value.
[Rule 62-297.310(5), F.A.C.]

Recordkeeping and Reporting Requirements

A18. In order to demonstrate compliance with Specific Condition Nos. A2. and A6., the permittee shall maintain a log at the facility for a period of at least five years from the date the data is recorded. The log, at a minimum, shall contain the following:

Monthly
a) month
b) consecutive 12 month total of:
- MMBTU heat input
- hours of operation
- emission rates

[Rules 62-4.070(3), and 62-213.440(1)(b)2.b., F.A.C.]

A19. Supporting documentation. The log and documents shall be kept at the facility for at least five years and made available to the Department. Daily logs shall be completed within seven business days and the monthly logs shall be completed by the end of the following month.
[Rules 62-4.070(3), and 62-213.440(1)(b)2.b., F.A.C.]

Subsection B. This section addresses the following emissions unit.

E.U. ID No.	Brief Description
-004	**FGT No. 1704**: Modified 2000 bhp natural gas-fired reciprocating internal combustion engine (Cooper-Bessemer Model No. LS-8-SG)

The emissions unit, which was installed in 1966 is part of a natural gas pipeline system serving the State of Florida. The engine fires only pipeline-quality natural gas at a maximum rate of approximately 15,900 cubic feet per hour based on a heat content of 1040 BTU per SCF of gas. At 16.5 MMBTU per hour of heat input, the engine produces approximately 2000 bhp. After initial startup, the engine is intended to operate at or near capacity. The efficient combustion of pipeline-quality natural gas at high temperatures minimizes emissions of CO, PM/PM_{10}, SO_2, and VOC. Modifications to the engine turbocharger increase the air manifold pressure and airflow to each cylinder, which reduces NO_x emissions.

B1. NESHAP Requirements: The Internal Combustion Engine (EU ID No. -004, FGT No. 1704) is subject to the provisions of 40 CFR Part 63, Subpart A – General Provisions (see Appendix A-3 General Provisions (NESHAP) and 40 CFR Part 63, Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (see Appendix ICE).

{Permitting Note: The engine is an "affected unit" as defined in Subpart ZZZ, but the engine is not subject to any specific requirement of Subpart ZZZZ at this time. It was constructed before the applicability dates in Subpart ZZZZ for new engines.}

Essential Potential to Emit (PTE) Parameters

B2. Capacity. The maximum heat input rate to the modified reciprocating compressor engine shall not exceed 16.5 MMBTU per hour while producing approximately 2000 bhp based on a higher heating value (HHV) of 1040 BTU per SCF for natural gas.
[Rule 62-210.200, (PTE), F.A.C.]

B3. Methods of Operation. The modified reciprocating compressor engine shall fire only natural gas delivered by the interstate grid with a maximum of 10 grains of sulfur per 100 standard cubic feet of natural gas. The current pipeline tariff specifies a maximum of 10 grains of sulfur per 100 standard cubic feet of natural gas. Therefore, no fuel monitoring is required.
[Rule 62.210.200, (PTE), F.A.C. and 0830070-005-AC]

B4. Hours of Operation. The engine is allowed to operate continuously.
[Rule 62-210.200, (PTE), F.A.C. and 0830070-005-AC]

B5. Engine Turbocharger Modification. The permittee shall tune, maintain, and operate the modified engine and control system to preserve the reduced NO_x emissions.
[0830070-003-AC]

Emission Limitations and Standards

B6. Emissions Standards: Emissions from the modified reciprocating compressor engine shall not exceed the following limits for CO, NO_x, opacity, PM, SO_2 and VOC.

Pollutant	Standards	Equivalent Maximum Emissions[f]		Rule Basis[g]
		lb/hour	TPY	
CO[a]	2.0 gram/bhp-hour	8.8	38.54	Avoid Rule 62-212.400, F.A.C.
NO_x[b]	8.0 gram/bhp-hour	35.3	154.61	Avoid Rule 62-212.400, F.A.C.
SO_2[c]	10 grains of sulfur per 100 SCF of gas	0.5	2.19	Avoid Rule 62-212.400, F.A.C.
Opacity[d]	10% opacity, 6-minute average	Not Applicable		Avoid Rule 62-212.400, F.A.C.
PM[e]	Good combustion practices (Factor: 0.00999 lb/MMBTU)	0.2	0.88	Avoid Rule 62-212.400, F.A.C.
VOC[e]	Good combustion practices (Factor: 0.1 gram/bhp-hour)	0.4	1.75	Avoid Rule 62-212.400, F.A.C.

a. The CO standards are based on 3-hour test averages as determined by EPA Method 10.
b. The NO_x standards are based on 3-hour test averages as determined EPA Method 7E.
c. The fuel sulfur specification is based on the maximum limit specified by Federal Energy Regulatory Commission (FERC) and effectively limits the potential SO_2 emissions. Expected fuel sulfur levels are less than 1 grain per 100 SCF of natural gas from the pipeline. Compliance is by record keeping.
d. The opacity standard is based on a 6-minuted average, as determined by EPA Method 9.
e. For both PM and VOC, the efficient combustion of clean fuels is indicated by compliance with opacity and CO standards. There are no pollutant-specific limits and no testing required.
f. The equivalent maximum hourly emissions are based on permitted capacity, the corresponding emissions standard (CO, NO_x, and SO2), an emission factor from EPA's AP-42 reference document (PM), and vendor test data (VOC). The equivalent maximum annual emissions are based on 8760 hours of operation per year and the specified restrictions.
g. The conditions of this permit ensure that the project does not trigger the PSD preconstruction review requirements of Rule 62-212.400, F.A.C. The project includes emissions increases and decreases from emissions units 004, 008 and 009.

B7. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operation practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

B8. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

B9. Excess Emissions – Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Department in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department. [Rule 62-210.700(6), F.A.C.]

Test Methods and Procedures

B10. Annual Compliance Tests: During each federal fiscal year (October 1st to September 30th), the modified reciprocating compressor engine shall be tested to demonstrate compliance with the emissions standards for CO, NO_x, and opacity. CO and NO_x performance tests shall be conducted concurrently at permitted capacity. SO_2 emissions shall be calculated based on fuel flow and vendor analysis of fuel sulfur content.
[Rule 62-297.310(7)(a)4., F.A.C. and to avoid Rule 62-212.400, F.A.C.]

B11. Test Notification: The owner or operator shall notify the Department (the air compliance section of this office), at least 15 days prior to the date on which each formal compliance test is to begin, the date, time and place of such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
[Rule 62-297.310(7)(a)9, F.A.C.]

B12. Test Methods: Required tests shall be performed in accordance with the following reference methods.

a) Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
b) Method 7E	Determination of NO_x Emissions from Stationary Sources
c) Method 9	Determination of the Opacity of the Emissions from Stationary Sources
d) Method 10	Determination of CO Emissions from Stationary Sources {Note: The method shall be based on a continuous sampling train.}
e) Method 19	Determination of SO_2 Removal Efficiency and PM, SO_2, and NO_x Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4)

Tests shall also be conducted in accordance with the requirements specified in Section 4, Appendix SC of this permit. The above methods are described in 40 CFR 60, Appendix A and adopted by reference in Rule 62-204.800, F.A.C., No other methods may be used for compliance testing unless prior written approval is received from the Department.
[Rules 62-204.800 and 62.297.100, F.A.C.; 40 CFR 60, Appendix A]

B13. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20 percent below the allowable emission limiting standard.
[Rule 62-297.310(1), F.A.C.]

B14. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emission unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[Rule 62-297.310(2), F.A.C.]

B15. Calculation of Emission Rate: For each emission performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate of concentration determined by each of the three separated test runs unless otherwise specified in a particular test method or applicable rules.
[Rule 62-297.310(3), F.A.C.]

B16. Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
a. *Required Sampling Time.* Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.
b. *Minimum Sample Volume.* Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
c. *Calibration of Sampling Equipment.* Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.
[Rule 62-297.310(4), F.A.C.]

B17. Determination of Process Variables
a. *Required Equipment.* The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
b. *Accuracy of Equipment.* Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10 percent of its true value. [Rule 62-297.310(5), F.A.C.]

B18. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.

B19. Special Compliance Tests: When the Department, after investigations, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emission unit and to provide a report on the results of said tests to the Department.
[Rule 62-297.310(7)(b), F.A.C.]

Recordkeeping and Reporting Requirements

B20. Test Reports: The permittee shall prepare and submit reports for all required tests in accordance with the requirements specified in Section 4, Appendix SC of this permit. For each test run, the report shall also indicate the natural gas firing rate (cubic feet per hour), the heat input rate (MMBTU per hour), and the power output (bhp).
[Rule 62-297.310(8), F.A.C.]

B21. Operational Data: The permittee shall adequately monitor the fuel consumption rate and hours of operation for use in submittal of the required Annual Operating Report.

Subsection C. This section addresses the following emissions unit(s).

E.U. ID No.	Brief Description
-008	**FGT No. 1706**: One 15,700 bhp Natural Gas-Fired Turbine Compressor Engine (Pignone Model No. PGT-10B)

The emissions unit is part of a natural gas pipeline system serving the State of Florida. The gas turbine fires only pipeline-quality natural gas at a maximum rate of approximately 129,600 cubic feet per hour based on a heat content of 1040 BTU per SCF of gas. At 134.8 MMBTU per hour of heat input, the gas turbine produces approximately 15,700 bhp. After initial startup, the gas turbine is intended to operate between 50 and 100 percent of base load. The efficient combustion of pipeline-quality natural gas at high temperatures minimizes emissions of CO, PM/PM_{10}, SO_2, and VOC. NOx emissions are reduced with dry low-NOX combustion technology.

C1. NSPS Requirements: The gas turbine shall comply with the New Source Performance Standards (NSPS) of Subpart GG in 40 CFR 60. The applicable NSPS requirements are provided in Appendix GG of this permit. The Department determines that the conditions in this section are at least as stringent, or more stringent than, the NSPS requirement of Subpart GG. The conditions are incorporated into this permit (attached and part of this permit).

Essential Potential to Emit (PTE) Parameters

C2. Capacity. The maximum heat input rate to the gas turbine shall not exceed 134.8 MMBTU per hour while producing approximately 15,700 bhp based on a compressor inlet air temperature of 59° F, 100 percent load, and an HHV of 1040 BTU per SCF for natural gas. Heat input rates will vary depending upon gas turbine characteristics, load, and ambient conditions. The permittee shall provide manufacturer's performance curves (or equations) that correct for site conditions to the Department's Central District air section within 45 days of completing the initial compliance testing. Performance data shall be adjusted for the appropriate site conditions in accordance with the performance curves and/or equations on file with the Department.
[Rule 62-210.200, (PTE), F.A.C.]

C3. Methods of Operation. The gas turbine shall fire only natural gas delivered by the interstate grid with a maximum of 10 grains of sulfur per 100 standard cubic feet of natural gas.
[Rule 62.210.200, (PTE), F.A.C. and 0830070-003-AC]

C4. Hours of Operation. The total hours of operation for the gas turbine are not limited.. Except for startup and shutdown, operation below 50 percent of base load is prohibited
[Rules 62-4.070(3) and 62-210.200, (PTE), F.A.C. and 0830070-003-AC]

C5. Engine Turbocharger Modification. removed

Emission Limitations and Standards

C6. Emissions Standards: Emissions from the gas turbine shall not exceed the following limits for CO, NO_x, opacity, PM, SO_2 and VOC.

Pollutant	Standards	Equivalent Maximum Emissions[f]		Rule Basis[g]
	Standards	lb/hour	TPY	Avoid Rule 62-212.400, F.A.C.
CO[a]	21.0 ppmvd @15% O_2	7.03	30.79	Avoid Rule 62-212.400, F.A.C. 40 CFR 60.332
NO_x[b]	25.0 ppmvd @15% O_2	14.1	61.76	Avoid Rule 62-212.400, F.A.C. 40 CFR 60.332
SO_2[c]	10.0 grains of sulfur per 100 SCF of natural gas	3.7	16.21	Avoid Rule 62-212.400, F.A.C.
Opacity[d]	10% opacity, 6-minute average	Not Applicable		Avoid Rule 62-212.400, F.A.C.
PM[e]	Good combustion practices	0.9	3.94	Avoid Rule 62-212.400, F.A.C.
	Good combustion practices	1.5	6.57	

a. The CO standards are based on 3-hour test averages as determined by EPA Method 10.
b. The NO_x standards are based on 3-hour test averages as determined EPA Method 20.
c. The fuel sulfur specification is based on the maximum limit specified by Federal Energy Regulatory Commission (FERC) and effectively limits the potential SO_2 emissions. Expected fuel sulfur levels are less than 1 grain per 100 SCF of natural gas from the pipeline. Compliance is by record keeping.
d. The opacity standard is based on a 6-minuted average, as determined by EPA Method 9.
e. For both PM and VOC, the efficient combustion of clean fuels is indicated by compliance with opacity and CO standards. There are no pollutant-specific limits and no testing required.
f. The equivalent maximum hourly emissions are based on permitted capacity, a compressor inlet air temperature of 59° F, the corresponding emissions standard (CO, NO_x, and SO_2), an emission factor from EPA's AP-42 reference document (PM), and vendor test data (VOC). The equivalent maximum annual emissions are based on 8760 hours of operation per year and the specified restrictions. Each test report shall include measured mass emission rates for CO, NO_x and SO_2. Mass emission rates for SO_2 shall be calculated based on actual fuel sulfur content and fuel flow rate. For comparison purposes, the permittee shall provide a reference table with the initial compliance test report of CO and NO_x mass emission rates versus the compressor inlet temperatures. For tests conducted at 59° F or greater, measured CO and NO_x mass emission rates shall be compared to the equivalent maximum emissions above. For tests conducted below 59° F, measured mass emission rates shall be compared to the tabled mass emission rates provided by the manufacturer based on compressor inlet temperatures.
g. The conditions of this permit ensure that the project does not trigger the PSD preconstruction review requirements of Rule 62-212.400, F.A.C. The project includes emissions increases and decreases from emissions units 004, 008, and 009.

C7. Excess Emissions Allowed: Excess emissions resulting from startup, shutdown or malfunction of any emissions unit shall be permitted providing (1) best operation practices to minimize emissions are adhered to and (2) the duration of excess emissions shall be minimized but in no case exceed two hours in any 24-hour period unless specifically authorized by the Department for longer duration.
[Rule 62-210.700(1), F.A.C.]

C8. Excess Emissions Prohibited: Excess emissions caused entirely or in part by poor maintenance, poor operation, or any other equipment or process failure that may reasonably be prevented during startup, shutdown or malfunction shall be prohibited.
[Rule 62-210.700(4), F.A.C.]

C9. Excess Emissions – Notification: In case of excess emissions resulting from malfunctions, the permittee shall notify the Department or the appropriate Local Program in accordance with Rule 62-4.130, F.A.C. A full written report on the malfunctions shall be submitted in a quarterly report, if requested by the Department.
[Rule 62-210.700(6), F.A.C.]

Test Methods and Procedures

C10. Annual Compliance Tests: During each federal fiscal year (October 1st to September 30th), the gas turbine shall be tested to demonstrate compliance with the emissions standards for CO, NO_x, and opacity. CO and NO_x tests shall be conducted concurrently at permitted capacity. SO_2 emissions shall be calculated based on fuel flow and vendor analysis of fuel sulfur content.
[Rule62-297.310(7)(a)4.,F.A.C., to avoid Rule 62-212.400, F.A.C., and permit 0830070-005-AC]

C11. Test Notification: The owner or operator shall notify the Department (the air compliance section of this office), at least 15 days prior to the date on which each formal compliance test is to begin, the date, time and place of such test, and the test contact person who will be responsible for coordinating and having such test conducted for the owner or operator.
[Rule 62-297.310(7)(a)9, F.A.C.]

C12. Test Methods: Required tests shall be performed in accordance with the following reference methods.

a) Methods 1-4	Traverse Points, Velocity and Flow Rate, Gas Analysis, and Moisture Content
b) Method 9	Determination of the Opacity of the Emissions from Stationary Sources
c) Method 10	Determination of CO Emissions from Stationary Sources {Note: The method shall be based on a continuous sampling train.}
d) Method 19	Determination of SO_2 Removal Efficiency and PM, SO_2, and NO_x Emission Rates (Optional F-factor method may be used to determine flow rate and gas analysis to calculate mass emissions in lieu of Methods 1-4)
e) Method 20	Determination of Nitrogen Oxides, Sulfur Dioxide and Diluent Emissions from Gas Turbines

Tests shall also be conducted in accordance with the requirements specified in Section 4, Appendix SC of this permit. The above methods are described in 40 CFR 60, Appendix A and adopted by reference in Rule 62-204.800, F.A.C., No other methods may be used for compliance testing unless prior written approval is received from the Department. [Rules 62-204.800 and 62.297.100, F.A.C.; 40 CFR 60, Appendix A]

C13. Required Number of Test Runs: For mass emission limitations, a compliance test shall consist of three complete and separate determinations of the total air pollutant emission rate through the test section of the stack or duct and three complete and separate determinations of any applicable process variables corresponding to the three distinct time periods during which the stack emission rate was measured; provided, however, that three complete and separate determinations shall not be required if the process variables are not subject to variation during a compliance test, or if three determinations are not necessary in order to calculate the unit's emission rate. The three required test runs shall be completed within one consecutive five-day

period. In the event that a sample is lost or one of the three runs must be discontinued because of circumstances beyond the control of the owner or operator, and a valid third run cannot be obtained within the five-day period allowed for the test, the Secretary or his or her designee may accept the results of two complete runs as proof of compliance, provided that the arithmetic mean of the two complete runs is at least 20 percent below the allowable emission limiting standard.
[Rule 62-297.310(1), F.A.C.]

C14. Operating Rate During Testing: Testing of emissions shall be conducted with the emissions unit operating at permitted capacity. Permitted capacity is defined as 90 to 100 percent of the maximum operation rate allowed by the permit. If it is impractical to test at permitted capacity, an emissions unit may be tested at less than the maximum permitted capacity; in this case, subsequent emission unit operation is limited to 110 percent of the test rate until a new test is conducted. Once the unit is so limited, operation at higher capacities is allowed for no more than 15 consecutive days for the purpose of additional compliance testing to regain the authority to operate at the permitted capacity.
[Rule 62-297.310(2), F.A.C.]

C15. Calculation of Emission Rate: For each emission performance test, the indicated emission rate or concentration shall be the arithmetic average of the emission rate of concentration determined by each of the three separated test runs unless otherwise specified in a particular test method or applicable rules.
[Rule 62-297.310(3), F.A.C.]

C16. Test Procedures: Tests shall be conducted in accordance with all applicable requirements of Chapter 62-297, F.A.C.
a. *Required Sampling Time.* Unless otherwise specified in the applicable rule, the required sampling time for each test run shall be no less than one hour and no greater than four hours, and the sampling time at each sampling point shall be of equal intervals of at least two minutes. The minimum observation period for a visible emissions compliance test shall be thirty (30) minutes. The observation period shall include the period during which the highest opacity can reasonably be expected to occur.
b. *Minimum Sample Volume.* Unless otherwise specified in the applicable rule or test method, the minimum sample volume per run shall be 25 dry standard cubic feet.
c. *Calibration of Sampling Equipment.* Calibration of the sampling train equipment shall be conducted in accordance with the schedule shown in Table 297.310-1, F.A.C.
[Rule 62-297.310(4), F.A.C.]

C17. Determination of Process Variables
a. *Required Equipment.* The owner or operator of an emissions unit for which compliance tests are required shall install, operate, and maintain equipment or instruments necessary to determine process variables, such as process weight input or heat input, when such data are needed in conjunction with emissions data to determine the compliance of the emissions unit with applicable emission limiting standards.
b. *Accuracy of Equipment.* Equipment or instruments used to directly or indirectly determine process variables, including devices such as belt scales, weight hoppers, flow meters, and tank scales, shall be calibrated and adjusted to indicate the true value of the parameter being measured with sufficient accuracy to allow the applicable process variable to be determined within 10 percent of its true value. [Rule 62-297.310(5), F.A.C.]

C18. Sampling Facilities: The permittee shall install permanent stack sampling ports and provide sampling facilities that meet the requirements of Rule 62-297.310(6), F.A.C.

C19. Special Compliance Tests: When the Department, after investigations, has good reason (such as complaints, increased visible emissions or questionable maintenance of control equipment) to believe that any applicable emission standard contained in a Department rule or in a permit issued pursuant to those rules is being violated, it shall require the owner or operator of the emissions unit to conduct compliance tests which identify the nature and quantity of pollutant emissions from the emission unit and to provide a report on the results of said tests to the Department. [Rule 62-297.310(7)(b), F.A.C.]

Recordkeeping and Reporting Requirements

C20. Test Reports: The permittee shall prepare and submit reports for all required tests in accordance with the requirements specified in Section 4, Appendix SC of this permit. In addition, NO_x emissions shall be corrected to ISO ambient atmospheric conditions and compared to the NSPS Subpart GG standard identified in Appendix GG of this permit for each required test. For each run, the test report shall also indicate the natural gas firing rate (cubic feet per hour), the heat input rate (MMBTU per hour), the power output (bhp), percent base load, and the compressor inlet air temperature.
[Rule 62-297.310(8), F.A.C.]

C21. Fuel Monitoring: The permittee shall not claim the allowance for fuel-bound nitrogen in establishing the NSPS NOx standard. Only pipeline quality natural gas shall be fired. The current pipeline tariff specifies the maximum sulfur content as 10 grains of sulfur per 100 cubic feet of natural gas. Therefore, no fuel nitrogen or fuel sulfur monitoring is required. The fuel monitoring provisions were revised pursuant to the final July 2004 amendments to Subpart GG See Appendix GG. [Air Permit No. 0830070-005-AC]

C22. Using the automated gas turbine control system, the permittee shall monitor and record heat input (MMBtu), power output (bhp), and hours of gas turbine operation. Within at least 5 business days of an agency request, the permittee shall summarize the following information: average heat input (MMBtu per hour); average heat input for the month shall be based on the contracted heat content (MMBtu per SCF) of the natural gas for the given month. This information shall also be used for submittal of the required Annual Operating Report. [Rule 62-4.070(3), F.A.C.]

C23. Component Replacements: For the replacement of gas turbine components to facilitate prompt repair and return the unit to its original specifications, the permittee shall comply with the following notifications and testing requirements.

a. Components shall only be replaced with functionally equivalent "like-kind" equipment. Replacement components may consist of improved or newer equipment, but such components shall not change operation or increase the capacity (heat input and power output rates) of the gas turbine. Replacement components that affect emissions shall be designed to achieve the emissions standards specified in all valid air permits and shall achieve these standards or better. After a component replacement, the gas turbine compressor engine remains subject to the standards of all valid air permits. [Rule 62-210.200(169), F. A. C.]

b. The permittee shall notify the Compliance Authority within seven days after beginning any replacement of the gas generator component of the compressor engine. Within seven days of first fire on a replacement gas generator, the permittee shall submit the following information to the Compliance Authority: date of first fire and certification from the vendor that the replacement gas generator is a functionally equivalent "like-kind" component. The vendor certification shall also identify the make, model number, maximum, heat input rate (MMBtu/hour), power output (bhp) at ISO conditions, and that the permitted emission rates are achievable with the replacement component. This notification may be made by letter, fax, or email. A copy of the information shall be kept on site at the compressor station. Within 60 days of restarting the unit after a gas generator replacement, the permittee shall conduct stack tests to demonstrate compliance with the applicable emission standards. The permittee shall notify the Compliance Authority in writing at least 15 days prior to conducting these tests. The permittee shall comply with all permit requirements for test notifications, test methods, test procedures, and reporting. [Rules 62-4.130, 62-4.160(2), (6), and (15) and 62-297.310(7)(b), F.A.C.]

c After investigation and for good cause, the Department may require special compliance tests pursuant to Rule 62-297.310(7)(b), F.A.C.