TABLE H

PERMIT HISTORY/ID NUMBER CHANGES

Relevant Permits Issued & Projects:

E.U. ID No.	Description	Permit No.	Effective Date	Expiration Date	Project Type
All	Facility	0970014-016-AV	pending - 01/01/2013	pending - 12/31/2017	Renewal (3rd)
001 - 006, 007 - 011 & 018 - 020	CAIR	0970014-015-AV	01/28/2009	NA	Revision of Title V Permit
018, 019 & 020	Inclusion of 0970014-013-AC/PSD-FL-268B	0970014-014-AV	11/02/2008	NA	Revision of Title V Permit
018, 019 & 020	Exclusion of Excess Emissions Data Language	0970014-013-AC/PSD-FL-268B	08/05/2008	NA	Construction (rev.)
018, 019 & 020	Exclusion of Excess Emissions Data Language	0970014-012-AC	NA	NA	Withdrawn
All	Facility	0970014-010-AV [1]	01/01/2008	12/31/2012	Renewal (2nd)
NA	NA	0970014-008-AC	NA	NA	Project No. not used
All	Facility	0970014-007-AV	01/01/2003	12/31/2007	Renewal (1st)
018, 019 & 020	Units CT12 through CT14 NOx BACT modification	0970014-006-AC/PSD-FL-268A {Supersedes 0970014-003-AC/PSD-FL-268}	01/30/2002	12/01/2002	Construction (rev.)
018, 019 & 020	Construction of three new simple cycle CTs, GE Model PG7121EA (Units CT12 through CT14)	0970014-003-AC/PSD-FL-268	12/09/1999	07/01/2001	Construction (new)
007 - 010 & 011	Addition of Inlet Foggers to CTs C7 to CT11	0970014-002-AC/PSD-FL-180H {Supersedes AC49-203114/PSD-FL-180 & revisions}	05/17/1999	12/31/1999	Construction (rev.)
All	Facility	0970014-001-AV	01/01/1998	12/31/2002	Initial Title V Permit
007 - 010 & 011	Custom Fuel Monitoring Schedule	PSD-FL-180G	12/15/1997	NA	Project No. assumed

TABLE H

PERMIT HISTORY/ID NUMBER CHANGES

007 - 010 & 011	Natural Gas Use	PSD-FL-180F	08/11/1995	NA	Construction (rev.)
007 - 010 & 011	Compliance Testing Requirements	PSD-FL-180E	01/20/1995	NA	Construction (rev.)
007 - 010 & 011	Mfr Heat Input vs. Ambient Temperature Curve	PSD-FL-180D	09/23/1994	NA	Construction (rev.)
007 - 010 & 011	Substitute one 171 MW Siemens V84.3 for two 185.5 MW GE 7FA	PSD-FL-180C	07/15/1994	NA	Construction (rev.)
007 - 010	Fuel Oil No. 2 in lieu of F, Hg, Pb, As and Be Limits	PSD-FL-180B	11/15/1993	NA	Construction (rev.)
007 - 010	Test and Compliance Methods	PSD-FL-180A	10/06/1993	NA	Construction (rev.)
007 - 010	Construction of 92.9 MW & 185.5 MW Simple Cycle Gas CTs	AC49-203114/PSD-FL-180	08/17/1992	12/31/1994	Construction (new)

[1] the most recent Title V air operation permit posted on the web site.
"NA" represents not applicable.