Table 2, Summary of Compliance Requirements

FPL — Final Permit No. 0990646-004-AV

West County Energy Center — Facility ID No. 0990646

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
001 - 006	Combined Cycle Combustion Turbine and Heat Recovery Steam Generator, Unit 1 and Unit 2

The following apply to each individual CT

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
CO	all	CEMS and EPA Method 10	Annual		1-hour	yes	III.A.9. & III.A.23-28.
NO_X	all	CEMS and EPA Method 7E or 20	Annual		1-hour	yes	III.A.9. & III.A.23-28.
PM/PM_{10}	all	Fuel Sampling & Analysis - ASTM Methods	Daily/Transfer				III.A.9.
SAM/SO_2	all	Fuel Sampling & Analysis - ASTM Methods	Daily/Transfer				III.A.9.
VOC	all	EPA Method 25A or 18	see note [1]		1-hour		III.A.9. & III.A.23-28.
VE	all	EPA Method 9	Annual		30-minutes		III.A.9.

Notes:

* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.

**CMS [=] continuous monitoring system

[1] Annual compliance tests for VOC emissions are not required. Compliance with the continuously monitored CO standards shall indicate efficient combustion and low VOC emissions.

Table 2, Summary of Compliance Requirements

FPL
West County Energy Center

Final Permit No. 0990646-004-AV
Facility ID No. 0990646

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
009 & 010	One Limited Use Gas-fueled Auxiliary Boiler and Two Gas-fired Process Heaters

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
-009 One Limited Use Gas-fueled Auxiliary Boiler							
CO	natural gas	EPA Method 10	upon renewal (every 5 years)		60 minutes		III.B.5. & 7.
NOx	natural gas	EPA Method 7E	upon renewal (every 5 years)		60 minutes		III.B.5. & 7.
SO_2	natural gas	Fuel Sampling & Analysis - ASTM Methods					III.B.5. & 10.
VE	natural gas	EPA Method 9	annual		30 minutes		III.B.5. & 6.
-010 Two Gas-fired Process Heaters							
CO	natural gas	EPA Method 10	upon renewal (every 5 years)***		60 minutes		III.B.5. & 7.
NOx	natural gas	EPA Method 7E	upon renewal (every 5 years)***		60 minutes		III.B.5. & 7.
SO_2	natural gas	Fuel Sampling & Analysis - ASTM Methods					III.B.5. & 9.
VE	natural gas	EPA Method 9	annual		30 minutes		III.B.5. & 6.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system
***As an alternative to testing for NOx and CO emissions, a manufacturer certification of emissions characteristics for NOx and CO that are at least as stringent as the BACT values can be used to fulfill this requirement.

Table 2, Summary of Compliance Requirements

FPL
West County Energy Center

Final Permit No. 0990646-004-AV
Facility ID No. 0990646

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
011	Three Emergency Generators/Engines (EPA Tier 1 certified)

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
CO	fuel oil	manufacturer certification					III.C.8.
NOx	fuel oil	manufacturer certification					III.C.8.
SO_2	fuel oil	fuel sampling & analysis	upon each fuel delivery				III.C.5. & 6.
PM/PM_{10}	fuel oil	manufacturer certification					III.C.8.
NMHC	fuel oil	manufacturer certification					III.C.8.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

Table 2, Summary of Compliance Requirements

FPL
West County Energy Center

Final Permit No. 0990646-004-AV
Facility ID No. 0990646

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
012	One Emergency Fire Pump Engine (EPA Tier 1 certified)

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
CO	fuel oil	manufacturer certification					III.D.7.
NOx	fuel oil	manufacturer certification					III.D.7.
SO_2	fuel oil	fuel sampling & analysis	upon each fuel delivery				III.D.5.
PM	fuel oil	manufacturer certification					III.D.7.
NMHC	fuel oil	manufacturer certification					III.D.7.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system