COMBINED CYCLE COMBUSTION TURBINE (CT) AND HEAT RECOVERY STEAM GENERATOR (HRSG) UNIT 1 AND UNIT 2

FIRING ULTRA LOW SULFUR DISTILLATE FUEL OIL

The West County Energy Center's combustion turbines are allowed to fire both natural gas and ultra low sulfur distillate (ULSD) fuel oil. Initial compliance by these units has been demonstrated for natural gas firing, but not yet on ULSD fuel oil firing **as of February 25, 2011**. Dry low-NOx burners are used when firing natural gas and water injection is used when firing ULSD fuel oil. The following Compliance Plan, for initial compliance by these units while firing ULSD fuel oil, follows the requirements of air construction permits, 0990646-001-AC and 0990646-003-AC/PSD-FL-354, as amended:

1. The compliance authority shall be notified of the actual date of initial operation while firing ULSD fuel oil within 15 days of such date.
2. The emission limitations and standards, when firing ULSD fuel oil, are identified in the permit, respectively, and compliance shall be demonstrated on the emissions unit within 60 days of achieving maximum production rate, but no later than 180 days of initial operation on ULSD fuel oil.
3. Initial performance tests for the emission limitations and standards shall be conducted using the test methods identified in the permit.
4. The compliance authority shall be notified in writing at least 30 days prior to the initial performance tests.
5. Performance test results shall be submitted to the compliance authority no later than 45 days after the last test run.

[Rule 62-213.440(2), F.A.C.; and, 0990646-001 & -003-AC/PSD-FL-354, as amended.]