Table 3, **Revised** Facility Baseline and Projected Actual Emissions Estimates

Air Pollutant	Baseline Actual Emissions, TPY[a]	Projected Actual Emissions, TPY	Net Increase, TPY	PSD Threshold, SER, TPY	Subject to PSD Review?
CO	133	232	99	100	No
NOx	1540	1579	39	40	No
SO_2	91	130	39	40	No
PM/PM_{10}/ MWC Metals	9	23	14	15	No
Lead	0.03	0.52	0.5	0.6	No
Hydrogen Fluoride	0.14	2.14	2	3	No
MWC Organics	3.2E-06	6.2E-06	3.0E-06	3.5E-06	No
MWC Acid Gases	165	204	39	40	No

[a] "TPY" means tons per year.

Nitrogen Oxides: May 2004 – April 2006
Carbon Monoxide: May 2004 – April 2006
Sulfur Dioxide: November 2005 – October 2007
Particulate Matter, PM-10, and MWC Metals: January 2004 – December 2005
Lead: January 2004 – December 2005
MWC Organics: April 2004 – April 2006
Hydrogen Chloride: November 2005 – October 2007
MWC Acid Gases: November 2005 – October 2007

Baseline data calculated using airflow from 2003 - 2007