LIST OF UNREGULATED EMISSIONS UNITS AND/OR ACTIVITIES.

Unregulated Emissions Units and/or Activities. An emissions unit which emits no "emissions-limited pollutant" and which is subject to no unit-specific work practice standard, though it may be subject to regulations applied on a facility-wide basis (e.g., unconfined emissions, odor, general opacity) or to regulations that require only that it be able to prove exemption from unit-specific emissions or work practice standards.

The below listed emissions units and/or activities are neither 'regulated emissions units' nor 'insignificant emissions units'.

EU ID No.	Brief Description
004[1]	One Backup Emergency Spark Ignition Engine (4SLB) For Bryan Dairy Road Operation • Cummins 60kW Generator [2]

Notes:

1. The following table provides details for the spark ignition engine listed above as EU 004.

Engine Identification	Engine Brake HP	Date of Installation	Model Year	Displacement liter/cylinder (l/c)	Model No.
Backup Generator	98.3	8/26/2007	2007	6.8	Cummins Model GGHE 5863890

2. The facility is an area source of HAPs and the backup generator was manufactured in June 2007 and installed 8/26/2007. Under 40 CFR 63, Subpart ZZZZ this is a "New" stationary RICE (as defined by 40 CFR 63.6590(a)(2)(iii)). The engine meets two of the criteria in paragraph 40 CFR 63.6590(c) (i.e., 40 CFR 63.6590(c)(1)) and therefore it must meet the applicable requirements of 40 CFR 60, Subpart JJJJ. The engine has no other applicable requirements in 40 CFR 63, Subpart ZZZZ. Under 40 CFR 60, Subpart JJJJ, the applicability provisions (as defined by 40 CFR 60.4230(a)(1) through (6)) do not cover the engine because it was manufactured before July 1, 2007 and installed in 2007 and the engine has not been reconstructed. Note: This engine would be covered (see 40 CFR 60.4230(a)(5)) if modified or reconstructed after June 12, 2006.