FINAL DETERMINATION

PERMITTEE

Citrosuco North America, Inc.
5937 Hwy 60 East
Lake Wales, FL 33898

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Air Resource Management
Southwest District
13051 North Telecom Parkway
Temple Terrace, Florida 33637-7600

PROJECT

Air Permit No. 1050001-013-AC
Minor Air Construction Permit
Citrosuco North America, Inc.

This project establishes previously regulated 125 HP Boiler (Emissions Unit 014) as an insignificant emissions unit; replaces individual maximum heat input limitations for 800 HP Boiler (Emissions Unit 001), 2000 HP Boiler (Emissions Unit 008), and 1000 HP Boiler (Emissions Unit 012) with a combined maximum heat input limitation of 153.85 mmBtu/hr; reduces particulate matter emissions testing frequency for Pellet Cooler Nos. 2 and 3 (Emissions Units 009 and 010) from annually to once per permit period (prior to renewal); eliminates the PM/PM_{10} recordkeeping for Pellet Cooler Nos. 2 and 3 (Emissions Units 009 and 010); and modifies the method of operation for the two dryers (Emissions Units 006 and 007) and three boilers (Emissions Units 001, 008, and 012) by specifying that the No. 2 distillate fuel oil can only be burned during periods of gas curtailment.

NOTICE AND PUBLICATION

The Permitting Authority distributed a draft minor air construction permit package on June 24, 2011. The applicant published the Public Notice in the News Chief on July 8, 2011. The Permitting Authority received the proof of publication on July 27, 2011. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

COMMENTS

No comments on the Draft Permit were received from the public or the applicant.

CONCLUSION

In conclusion, no changes were made to the draft permit. The permitting authority hereby issues the FINAL Permit, with no changes.