TABLE 2

SUMMARY OF COMPLIANCE REQUIREMENTS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID Nos.	Brief Description	Fuels	Pollutant Name	Emission Control	Compliance Method EPA Method	Testing Time Frequency	Min. Compliance Test Duration	See Permit Conditions
012 and 027	Turbines	Natural Gas	NO_X	No Controls	EPA Method 20 or 7E	Renewal	3- 1 hour runs	D.13.
			VE	No Controls	EPA Method 9	Once Each Federal Fiscal Year (10/1-9/30)	30 minutes	D.12.