TABLE 1

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuels	Hrs/Yr	Pollutant Name	Standard Allowable Emissions		Equivalent Emissions[1]		Regulatory Citations	See Permit Conditions
					Standards	TPY	lbs/hr	TPY Each unit		
012 and 027	Turbines	Natural Gas	8,760	VE	10%				1050002-005-AC	D.4.
012				NOX	168 ppmvd @ 15% O_2	96.4	22.0			D.5.
027					30 ppmvd @ 15% O_2	39.4	9.0			
012				SO_2	Pipeline Natural Gas		[2]1.63	[2]7.16		D.6.
027							[3]2.43	[3]10.68		

Notes:
[1] Equivalent Emissions are for information l purposes only.
[2] Equivalent Emissions are based on operating 8760 hours/year, max heat input of 51.15 MMBtu/hr and 0.034% sulfur in natural gas.
[3] Equivalent Emissions are based on operating 8760 hours/year, max heat input of 76.26 MMBtu/hr and 0.034% sulfur in natural gas.