TABLE 1

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID Nos.	Brief Description	Fuels	Hrs/Yr	Pollutant Name	Standard Allowable Emissions	Equivalent Emissions		Regulatory Citation(s)	See Permit Condition(s)
						lbs/hr Each unit	TPY Each unit		
003, 004, and 017	Boilers	No. 2 Fuel Oil & Natural Gas	8,760	VE	20% except ≤ 27% 6 min/hr			Rule 62-296.406(1), F.A.C.	B.5.
003				SO_2	0.10% by weight sulfur	[1]8.75	[1]38.31	1050002-005-AC	B.6.
004						[2]8.85	[2]38.75		
017						[3]3.71	[3]16.23		

Notes:
[1] Equivalent Emissions are based on burning 616 gallons/hour of No. 2 fuel oil and operating 8,760 hours/year and are for informational purposes only.
[2] Equivalent Emissions are based on burning 623 gallons/hour of No. 2 fuel oil and operating 8,760 hours/year and are for informational purposes only.
[3] Equivalent emissions are based on burning 261 gallons/hour of No. 2 fuel oil and operating 8,760 hours/year and are for informational purposes only.