Table 2-1, Summary of Compliance Requirements

Lakeland Electric
Charles Larsen Memorial Power Plant

FINAL Permit Renewal No.: 1050003-017-AV
Facility ID No.: 1050003

E.U. ID No.	Brief Description
-005	Peaking Gas Turbine #3
-006	Peaking Gas Turbine #2

This table summarizes information for convenience purposes only.
This table does not supersede any of the terms or conditions of this permit.

Pollutant Name or parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	Permit Condition(s)
Sulfur	Oil	Fuel Sampling and Analysis					III.B.25., III.B.26.
VE	All	9	Annual	5-Mar	30 Minutes		III.B.27.

Notes:
Frequency base date established for planning purposes only; see Rule 62-297.310. F.A.C.
**CMS [=] compliance demonstrated by CEMS

[electronic file name: 10500032.xls]

Table 2-1, Summary of Compliance Requirements

Lakeland Electric
Charles Larsen Memorial Power Plant

FINAL Permit Revision No.: 1050003-013-AV
Facility ID No.: 1050003

E.U. ID No.	Brief Description
-008	Combined or Simple Cycle Combustion Turbine

This table summarizes information for convenience purposes only.
This table does not supersede any of the terms or conditions of this permit.

Pollutant Name or parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS **	Permit Condition(s)
NO_X	all	20 or 7E	Annual	31-Dec	1 Hour		III.D.27.
PM/PM_{10}	oil	5, 5B, or 17	Renewal	31-Dec	1 Hour		III.D.31.
SAM	all	Low Sulfur Fuel					III.D.32.
VE	all	9	Annual	31-Dec	30 Minutes		III.D.33.
Water to Fuel	all					yes	III.D.26.

Notes:
Frequency base date established for planning purposes only; see Rule 62-297.310. F.A.C.
**CMS [=] compliance demonstrated by CEMS