**STANDARDS OF PERFORMANCE FOR STATIONARY COMPRESSION IGNITION INTERNAL COMBUSTION ENGINES 40 CFR 60 SUBPART IIII-Applicable Requirements**
***(Mosaic Fertilizer LLC - Bartow Facility, Facility ID: 1050046)***

| Reciprocating Internal Combustion Engine (RICE) Information | | | | | | | | | | 40 CFR 60 Subpart IIII Applicable Requirements | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|---|---|
| **Engine Description / Location** | **Owned or Rented?** | **Engine Serial Number** | **Engine Manufacturer** | **Model Number** | **Date of Construction / Reconstruction** | **Power (bhp)** | **Fuel** | **CI or SI** | **Indicate if Emergency or Limited Use*** | **Emission Standards** (from 60.4205(a) Table 1) | **Fuel Requirements** 60.4207(b) | **Compliance Requirements** (60.4211(b)) | **Testing Requirements** (from 63.4212) | **Notification, Reports and Records** ( 60.4214) |
| South Stack Seepage Pump | Owned | -- | Deutz | -- | After June 12, 2006; New RICE; pre-2007 | 113, < 10 liters/cylinder | diesel | CI | Emergency | 6.9 g/HP-hr $NO_x$ | Meet 40 CFR 80.510(b) | Demonstrate compliance by one of 60.4211(b) (1) thru (5) | Test per 60.4212 | 60.4214(b) No initial notification Per Table 5, keep records of emergency and non emergency via non resettable hour meter |
| Main Office Power | Owned | E4M03180 | Caterpiller | 3054C | After June 12, 2006; New RICE; pre-2007 | 83, < 10 liters/cylinder | diesel | CI | Emergency | | | | | |