STANDARDS OF PERFORMANCE FOR STATIONARY COMPRESSION IGNITION INTERNAL COMBUSTION ENGINES 40 CFR 60 SUBPART IIII
(Mosaic Fertilizer LLC - Bartow Facility, Facility ID: 1050046)

Reciprocating Internal Combustion Engine (RICE) Information										40 CFR 60 Subpart IIII Applicable Requirements				
Engine Description / Location	**Owned or Rented?**	**Engine Serial Number**	**Engine Manufacturer**	**Model Number**	**Date of Construction / Reconstruction**	**Power (bhp)**	**Fuel**	**CI or SI**	**Indicate if Emergency or Limited Use***	**Emission Standards** (from 60.4205(a) Table 1)	**Fuel Requirements** 60.4207(b)	**Compliance Requirements** (60.4211)	**Testing Requirements** (from 60.4212)	**Notification, Reports and Records** (60.4214)
South Stack Seepage Pump	Owned	--	Deutz	--	After June 12, 2006; New RICE; pre-2007	113, < 10 liters/cylinder	diesel	CI	Emergency	6.9 g/HP-hr NOx	Meet 40 CFR 80.510(b)	Demonstrate compliance by one of 60.4211(b) (1) thru (5)	Test per 60.4212	60.4214(b) No initial notification Per Table 5, keep records of emergency and non emergency via non resettable hour meter
Main Office Power	Owned	E4M03180	Caterpiller	3054C	After June 12, 2006; New RICE; pre-2007	83, < 10 liters/cylinder	diesel	CI	Emergency					
1-R Well	Owned	--	Caterpiller	C15 ACERT	After June 12, 2006; New RICE; 2007 and later	580, < 10 liters/cylinder	diesel	CI	Non-Emergency	6.9 g/HP-hr Nox	Ultra low sulfur diesel (ULSD) fuel per manufacturer's specifications	Manufacturer's certification, Tier 4 Interim/Stage IIIB	Test per 60.4212	60.4214(a) Certified, no initial notification. Keep records of corrective action for backpressure limit (60.4214©)