TABLE 1

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No..	Brief Description	Fuel(s)	Pollutant Name	Allowable Emissions			Equivalent Emissions*		Regulatory Citation(s)	See Permit Condition(s)
				Standard(s)	lbs./hour	TPY	lbs./hour	TPY		
001	Multi-fuel Steam Boiler	Wood, yard waste, tires, landfill gas	VE	10% opacity					62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
				20% opacity (27% for 6 min/hr)					NSPS Subpart Db 40 CFR 60.43b	III. A.8.
			SO_2		65.0	284.7			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			NOx		90.0	394.2			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			CO		200.0	876.0			62-212.400, F.A.C., AC53-206244/PSD-FL-183A as amended	III. A.7.
			VOC		22.1	96.8			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			HCl		2.1	9.2			62-212.400, F.A.C.; 1050216-007-AC	III. A.7.
			Mercury (Hg)		0.022	0.096			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			Lead (Pb)		0.25	1.1			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			Beryllium (Be)		0.0063	0.028			62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
			PM/PM_{10}	0.0080 gr/SCF (@ 7% O_2)			12.6	55.2	62-212.400, F.A.C.; AC53-206244/PSD-FL-183A as amended	III. A.7.
				0.10 lb/MMBtu			63.0		60.43b, NSPS Subpart Db	III. A.8.
003	Lime Storage Building	N/A	VE	10% opacity					62-212.400, F.A.C.; 1050216-006-AC/PSD-FL-183C	III. B.2.

Notes: *The "Equivalent Emissions" listed are for informational purposes only.