TABLE 2

SUMMARY OF AIR POLLUTANT STANDARDS AND TERMS

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description	Fuel(s)	Pollutant Name	Compliance Method	Testing Frequency	Min. Test Duration	Emissions Monitoring	See Permit Condition(s)
001	Multi-Fuel Steam Boiler	Wood, yard waste, tires, landfill gas	VE	EPA Method 9 + COMS	every FFY	30 minutes	COMS	III. A.7., A.14., A.15., A.20., & A.21
			SO_2	30-day rolling average CEMS			CEMS	III. A.7, A.14, A.16 & A.17.
			NO_x					
			CO					
			VOC	25A	every FFY	As per test method		III. A.7., A.20. & A.21.
			HCl	26, 26A	every FFY	As per test method		III. A.7., A.20. & A.21
			Mercury (Hg)	29, 101A	Once every five years	As per test method		III. A.7., A.20. & A.21
			Lead (Pb)	12, 29	Once every five years	As per test method		III. A.7., A.20. & A.21
			Beryllium (Be)	29, 104	Once every five years	As per test method		III. A.7., A.20. & A.21
			PM/PM_{10}	5	every FFY	As per test method		III. A.7., A.20. & A.21
003	Lime Storage Building		VE	EPA Method 9	every FFY	30 minutes		III. B.3. & B.4.

Notes:

COMS = Continuous Opacity Monitoring CEMS = Continuous Emissions Monitoring

FFY = Federal Fiscal Year (Oct. 1 through Sept. 30)