Table 2, Summary of Compliance Requirements

Polk Power Partners, L.P.
Mulberry Cogeneration Facility

Final Permit No. 1050217-009-AV
Facility ID No. 1050217

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
001	Combined-cycle CT with a HRSG

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
NOx	All	CEMS	Continuous		4-hour rolling avg.	Yes	III.A.7., 8., 17. & 18. and 21.-25.
NOx	All	EPA Method 20	Annual/Concurrent with RATA		3 1-hour test runs		III.A.21.-25.
SO_2 % Sulfur	All	Fuel Sampling & Analysis - ASTM Methods	Daily / Transfer				III.A.19. & 20. and 21.-25.
PM/PM_{10}	All	VE serves as surrogate	N/A		N/A	No	III.A.10.
VE	All	EPA Method 9	Annual		30-minutes	No	III.A.21.-25.
VOC	All	N/A	N/A		N/A	No	III.A.12.
CO	All	EPA Method 10	Annual		3 1-hour test runs	No	III.A.21.-25.
O_2	All		N/A		N/A	Yes	III.A.32. [Appendix 40 CFR 60 KKKK]

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system
N/A represents not applicable.

Table 2, Summary of Compliance Requirements

Polk Power Partners, L.P.
Mulberry Cogeneration Facility

Final Permit No. 1050217-009-AV
Facility ID No. 1050217

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
002	Secondary Boiler

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
VE	All	EPA Method 9	Annual		30-minutes	No	III.B.13.-17.
PM	All	N/A	N/A			No	N/A
SO_2	All	Fuel Sampling & Analysis - ASTM Methods	Each delivery				III.B.13.-17.
NOx	All	EPA Method 7, 7A, 7C, 7D,or 7E	Renewal		3 1-hour test runs	Yes	III.B.13.-17.
CO	All	EPA Method 10	Renewal		3 1-hour test runs	No	III.B.13.-17.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system
N/A represents not applicable.