Table 1, Summary of Air Pollutant Standards

Auburndale Power Partners, L.P. **Permit No.: 1050221-016-AV**

Auburndale Power Partners Plant **Facility ID No.:** 1050221

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	**Brief Description**
001	Combined Cycle Combustion Turbine

			Allowable Emissions						
Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	Regulatory Citation(s)	lbs./hour	Regulatory Citation(s)	TPY	Regulatory Citation(s)	See permit condition(s)
VE	Gas/Oil		<10% opacity at full load	see note #3					A.6.
			≤20% opacity otherwise	see note #2					A.6.
PM_{10}	Oil	400	0.0472 lb/mmBtu	see note #2	36.8	see note #1	7.4	see note #2	A.7.
PM_{10}	Gas	8760	0.0134 lb/mmBtu	see note #2	10.5	see note #1	46.0	see note #2	A.7.
SO_2	Oil	400	0.05 % sulfur content by weight	see note #1	70.0	see note #1	14.0	see note #2	A.8.
SO_2	Gas	8760			40.0	see note #1	175.2	see note #2	A.8.
NO_x	Oil	400	42 ppmvd @15% O2, 24 hour block average	see note #1	230.0	see note #2	46.0	see note #2	A.9.
NO_x	Gas	8760	15 ppmvd @15% O2, 24 hour block average	see note #1	78.6	see note #2	177.0	see note #2, 4, and 5	A.9.
NO_x	Gas	8760	9 ppmvd @15% O2, 12 month rolling average					see note #2, 4, and 5	A.9.
VOC	Oil	400			10.0	see note #1	2.0	see note #2	A.10.
VOC	Gas	8760			6.0	see note #1	26.3	see note #2	A.10.
CO	Oil	400	25 ppmvd	see note #2	73.0	see note #1	14.6	see note #2	A.11.
CO	Gas	8760	21 ppmvd (min. load)	see note #2	43.5	see note #1	190.5	see note #2 and 5	A.11.
CO	Gas	8760	15 ppmvd (base load)	see note #2	43.5	see note #1	190.5	see note #2 and 5	A.11.

Notes:

#1 - from BACT Determination

#2 - from PSD-FL-185

#3 - from Rule 62-296.320(4)(b), F.A.C.

#4 - 1050221-004-AC

#5 - duel fuel total