Appendix I-1: List of Insignificant Emissions Units and/or Activities.

Lakeland Electric — DRAFT Permit No.: 1050352-005-AV
Winston Peaking Station — Facility ID No.: 1050352

The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and/or Activities:

1. Emergency foam fire protection system Model CC S3-500 VDF, manufactured by Arrow Tank and Engineering Company.
2. Storage operations for the 4,000-gallon fuel oil tank inside the building used to supply makeup oil to the engines.
3. Storage operations for the 12,000-gallon liquid ammonia tank which is used to supply ammonia for the Selective Catalytic Reduction (SCR) systems.
   [Permitting Note: Must submit risk management plan if NH_3 concentration reaches 20%, or greater (see Facility-wide Condition **4.**)]
4. Miscellaneous maintenance and cleaning of the building, control room, and their contents.
5. Storm water retention basin maintenance (if required).
6. 294,000-gallon No. 2 fuel oil storage tank.