FINAL DETERMINATION

PERMITTEE

Lakeland Electric
501 E. Lemon Street
Lakeland, FL 33801

PERMITTING AUTHORITY

Florida Department of Environmental Protection
Air Resource Management
Southwest District
13051 North Telecom Parkway
Temple Terrace, Florida 33637-7600

PROJECT

Air Permit No. 1050352-006-AC
Minor Air Construction Permit
Winston Peaking Station

The project is to remove 40 CFR 60, Subpart Kb requirements from the permit as these requirements do not apply to the 294,000 gallon No. 2 fuel oil storage tank.

NOTICE AND PUBLICATION

The Permitting Authority distributed a draft minor air construction permit package on 01/27/2011. The applicant published the Public Notice in The Ledger on 02/14/2011. The Permitting Authority received the proof of publication on 02/16/2011. No requests for administrative hearings or requests for extensions of time to file a petition for administrative hearing were received.

COMMENTS

No comments on the Draft Permit were received from the public, or the applicant.

CONCLUSION

In conclusion, no changes were made to the draft permit. The permitting authority hereby issues the FINAL Permit, with no changes.