FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

NORTHWEST DISTRICT
160 W. GOVERNMENT STREET
PENSACOLA, FLORIDA 32502-5794

RICK SCOTT
GOVERNOR

CARLOS LOPEZ-CANTERA
LT. GOVERNOR

JONATHAN P. STEVERSON
SECRETARY

February 6, 2015

PERMITTEE:

Breitburn Operating LP
St. Regis Gas Treatment Facility and Jay Gas Plant
5 Houston Center, 1401 McKinney Street, Suite 2400
Houston, Texas 77010

Authorized Representative:
Mr. Travis Melster, Vice President

Air Permit No. 1130005-021-AC
Facility ID No. 1130005
Project: South Waterflood Gas Turbine
Permit Expires: February 6, 2016

FACILITY AND LOCATION

The Breitburn Operating LP, St. Regis Gas Treatment Facility and Jay Gas Plant is an existing oil and gas production and natural gas processing facility located in Santa Rosa County at 5415 Oil Plant Road in Jay, Florida. The UTM coordinates are Zone 17, 482.8 km East and 3425.6 km North; and, Latitude 30°52'45" North and Longitude 87 10' 45" West.

REGULATORY CLASSIFICATION

Title III: The facility is a major source of hazardous air pollutants (HAP).

Title IV: The facility has no units subject to the acid rain provisions of the Clean Air Act.

Title V: The facility is a Title V major source of air pollution (Chapter 62-213, F.A.C.).

PSD: The facility is a PSD-major source of air pollution (Rule 62-212.400, F.A.C.).

SPECIFIC CONDITIONS

1. Previous Permits. This permit supplements all previously issued air construction and operation permits for this emission unit. Except for the changes noted below, the unit remains subject to the conditions of all other valid air construction and operations permits. [Rule 62-4.070, F.A.C.]

2. Emissions Unit No. 050: 14,300 HP South Waterflood Gas Turbine

2.1 Nitrogen Oxides (NOx) Emissions. NO_X emissions shall not exceed 30.0 pounds per hour or 60.4 tons per year. [Rule 62-4.070(3), F.A.C., and Application No. 1130005-021-AC]
{Permitting Note: The annual emissions limit for this emission unit is based on 4025 annual operating hours per Applicant's request in application 1130005-012-AV.}

2.2. Test Methods. Required tests shall be performed in accordance with the following reference methods:

Method	Description of Method and Comments
7E	Determination of Nitrogen Oxide Emissions from Stationary Sources
10	Determination of Carbon Monoxide Emissions from Stationary Sources

The above methods are described in 40 CFR 60, Appendix A, and adopted by reference in Rule 62-204.800, F.A.C. No other methods may be used unless prior written approval is received from the Department. [Rule 62-204.800, F.A.C. and 40 CFR 60, Appendix A]

2.3. Initial Compliance Tests. Compliance tests for NOx and CO are required to show compliance with the standards of the Department. The initial tests shall be conducted within 60 days after achieving permitted capacity, but not later than 180 days after initial operation of the unit. Notification of compliance testing and completed test reports may be submitted by electronic mail to nwdair@dep.state.fl.us. [Rules 62-4.070(3), 62-210.200(PTE) and 62-297.310(7)(a)1, F.A.C.]

3. Appendices A, B, C & D: The attached appendices A, B, C, & D are made a part of this permit. [Rule 62-4.070(3), F.A.C.]

STATEMENT OF BASIS

This air pollution construction permit is issued under the provisions of Chapter 403 of the Florida Statutes (F.S.), and Chapters 62-4, 62-210, 62-212 and 62-213 of the Florida Administrative Code (F.A.C.).

Executed in Pensacola, Florida.

/S/
Elizabeth Mullins Orr
Permitting Program Administrator
Northwest District

CERTIFICATE OF SERVICE

The undersigned duly designated deputy agency clerk hereby certifies that this Final Air Permit package (including the Final Determination and Final Permit) was sent by electronic mail (or a link to these documents made available electronically on a publicly accessible server) with received receipt requested before the close of business on February 6, 2015 to the persons listed below.

Travis Melster, Vice President, Breitburn Operating LP, travis.melster@breitburn.com
Larry Dilmore, Breitburn Operating LP, ldilmore@qracq.com
Barry D. Andrews, P.E., Antea Group, barry.andrews@anteagroup.com

FILED, on this date, pursuant to Section 120.52(7), Florida Statutes, with the designated agency clerk, receipt of which is hereby acknowledged.

/S/ February 6, 2015

Clerk Date