Table 1-1, Summary of Air Pollutant Standards and Terms

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
001	Internal Combustion Engines No. 1501, 1502, 1503, 1504, and 1505

			Allowable Emissions			Equivalent Emissions			
Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	lbs./hour	TPY	lbs./hour	TPY	Regulatory Citation(s)	See permit condition(s)
Nitrogen Oxides	Natural Gas	8,760							III. A.2
Carbon Monoxide	Natural Gas	8,760							III. A.2
VOC (non methane	Natural Gas	8,760							III. A.2
PM	Natural Gas	8,760							III. A.2
PM10	Natural Gas	8,760							III. A.2
Sulfur Dioxide	Natural Gas	8,760							III. A.2
Visible Emissions	Natural Gas	8,760							III. A.2

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
002	Internal Combustion Engines No. 1506

			Maximum Allowable Emission Rate				
Pollutant Name	Fuel(s)	Hours/Year	lbs./hour	TPY	Emission Factor	Regulatory Citation(s)	See permit condition(s)
Nitrogen Oxides	Natural Gas	8,760	17.6	77.2	2.0 g/bhp-hr	Rule 62-212.400(5), F.A.C.	III B.6.
Carbon Monoxide	Natural Gas	8,760	22.0	96.6	2.5 g/bhp-hr	Rule 62-212.400(5), F.A.C.	III B.6.
VOC (non methane)	Natural Gas	8,760	8.8	38.6	1.0 g/bhp-hr	Rule 62-212.400(5), F.A.C.	III B.6.
Sulfur Dioxide	Natural Gas	8,760	0.75	3.3	8.53 gr S/ 100 scf	Rule 62-212.400(5), F.A.C.	III B.6.
PM	Natural Gas	8,760	Good Combustion Practices	--	4.23 lbs/MMscf	Rule 62-212.400(5), F.A.C., Good Combustion Design and Fuel supersedes TSP and PM10, 1230034-011-AC	III B.6.
PM10	Natural Gas	8,760	Good Combustion Practices	--	4.23 lbs/MMscf	Rule 62-212.400(5), F.A.C., Good Combustion Design and Fuel supersedes TSP and PM10, 1230034-011-AC	III B.6.
Visible Emissions	Natural Gas	8,760	10% Opacity	--		Rule 62-212.400(5), F.A.C.	III B.6.

Table 1-1, Summary of Air Pollutant Standards and Terms

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
004	Internal Combustion Engines No. 1508

			Allowable Emissions	Equivalent Emissions			
Pollutant Name	Fuel(s)	Hours/Year	Standard(s)	lbs./hour	TPY	Regulatory Citation(s)	See permit condition(s)
Carbon Monoxide	Natural Gas	8,760	50.0 ppmvd @ 15% oxygen	7.0	30.66	Avoid Rule 62-212.400, F.A.C.	III.C.5., C.6.
Nitrogen Oxides	Natural Gas	8,760	25.0 ppmvd @ 15% oxyen	5.7	24.97	Avoid Rule 62-212.400, F.A.C., 40 CFR 60.332	III.C.5., C.6.
Sulfur Dioxide	Natural Gas	8,760	10.0 grains of sulfur per 100 SCF of natural gas	2.0	8.66	Avoid Rule 62-212.400, F.A.C., 40 CFR 60.332 (Subsumed by FERC)	III.C.5.,C.6.
Visible Emissions	Natural Gas	8,760	10% opacity, 6-minutes average	N.A.	N.A.	Avoid Rule 62-212.400, F.A.C.	III.C.5.,C.6.
PM	Natural Gas	8,760	Good combustion practices	0.5	2.08	Avoid Rule 62-212.400, F.A.C.	III.C.5., C.6.
VOC (non methane)	Natural Gas	8,760	Good combustion practices	1.5	6.57	Avoid Rule 62-212.400, F.A.C.	III.C.5., C.6.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.

Table 1-1, Summary of Air Pollutant Standards and Terms

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
006	Internal Combustion Engines No. 1507

			Allowable Emissions	Equivalent Emissions			
Pollutant Name	Fuel(s)	Hours/Yr	Standard(s)	lbs./hour	TPY	Regulatory Citation(s)	See permit condition(s)
Nitrogen Oxides	Natural Gas	8,760	25.0 ppmdv @ 15% oxygen	11.1	48.70	Rule 62.212.400, F.A.C. 40 CFR 60.332	III. D.3., D.4., D.5.
Carbon Monoxide	Natural Gas	8,760	50.0 ppmdv @ 15% oxygen	13.5	59.30	Avoid Rule 62-212.400, F.A.C.	III. D.3., D.4., D.5.
VOC (non methane)	Natural Gas	8,760	Efficient Combustion of Natural Gas	0.4	1.70	Rule 62.4.070(3), F.A.C.	III. D.3., D.4., D.5.
PM	Natural Gas	8,760	Efficient Combustion of Natural Gas	0.8	3.50	Rule 62-4.070(3), F.A.C. [Good Combustion Design and Fuel supersedes TSP and PM10, 1230034-011-AC]	III. D.3., D.4., D.5.
Sulfur Dioxide	Natural Gas	8,760	10 g S/100 scf of natural gas	3.4	14.89	40 CFR 60.333 (Subsummed by FERC) Avoid Rule 62-212.400, F.A.C.	III. D.3., D.4., D.5.
Visible Emissions	Natural Gas	8,760	10%, six min. avg.	N.A.	N.A.	Rule 62-4.070(3), F.A.C.	III. D.3., D.4., D.5.

Notes:
* The "Equivalent Emissions" listed are for informational purposes only.