The facilities, emissions units, or pollutant-emitting activities listed in Rule 62-210.300(3)(a), F.A.C., Categorical Exemptions, or that meet the criteria specified in Rule 62-210.300(3)(b)1., F.A.C., Generic Emissions Unit Exemption, are exempt from the permitting requirements of Chapters 62-210, 62-212 and 62-4, F.A.C.; provided, however, that exempt emissions units shall be subject to any applicable emission limiting standards and the emissions from exempt emissions units or activities shall be considered in determining the potential emissions of the facility containing such emissions units. Emissions units and pollutant-emitting activities exempt from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., shall not be exempt from the permitting requirements of Chapter 62-213, F.A.C., if they are contained within a Title V source; however, such emissions units and activities shall be considered insignificant for Title V purposes provided they also meet the criteria of Rule 62-213.430(6)(b), F.A.C. No emissions unit shall be entitled to an exemption from permitting under Rules 62-210.300(3)(a) and (b)1., F.A.C., if its emissions, in combination with the emissions of other units and activities at the facility, would cause the facility to emit or have the potential to emit any pollutant in such amount as to make the facility a Title V source.

The below listed emissions units and/or activities are considered insignificant pursuant to Rule 62-213.430(6), F.A.C.

Brief Description of Emissions Units and /or Activities

- 125 hp air compressor engine rated at approximately 0.42 MMBTU/hr (replaced by an electric unit).
- 10,000 gallon horizontal lube oil storage tank.
- 2,000 gallon horizontal lube oil storage tank.
- 90 bbl lube storage tank which stores used or waste oil.
- Lube oil rundown tank: Stores lube oil temporarily during maintenance operations.
- Oily water tanks: (2) 210 bbl storage tanks used to store wastewater containing used lube oil.
- Pipeline Condensate Tank: 210 bbl storage tank used to store pipeline condensate.
- Diesel Fuel Storage Tank: 500 gallon storage tank used to store diesel fuel for motor vehicles.
- Parts Cleaner: a citric-based cleaning fluid used to clean engine parts.
- Paint Cleaner: a cleaning fluid containing naphtha (removed).
- Blowdown Stacks: stacks used to blow down the natural gas in the station in an emergency or maintenance situation.
- Fugitive Component Leaks: emissions from leaks of numerous sources that are valves, flanges, and other components. The large majority of components are in natural gas service. Others are in pipeline condensate, wastewater and lube oil service.

- EU -007: 223- brake horsepower, natural gas fired, spark ignition, four-stroke rich burn, reciprocating internal combustion emergency engine generator. Manufacturer: Genrac® , Model: SG150, Manufactured date: December 8, 2008. Engine is classified as new stationary RICE by 40 CFR 63, Subpart ZZZZ—National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines. Required to meet 40 CFR 60 Subpart JJJ standards pursuant to 40 CFR 63.6590(c)(4). No other 40 CFR 63 Subpart ZZZZ standards apply. Pursuant to 40 CFR 60.4230(a)(4)(iv) of Subpart JJJJ, emergency engines with a maximum engine power greater than 19 KW (25 HP) that are manufactured prior to January 1, 2009 are not subject to 40 CFR 60 Subpart JJJJ.