Table 2-1, Summary of Compliance Requirements

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
001	Internal Combustion Engines No. 1501, 1502, 1503, 1504, and 1505

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Fuel Usage	Natural Gas		Recordkeeping	Annually			III.A.4.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
002	Internal Combustion Engines No. 1506

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Visible Emissions	Natural Gas	EPA Method 9	Annually		1 hour		III B.7.
Nitrogen Oxides	Natural Gas	EPA Method 7E	Annually		3 hours		III B.7.
		ASTM D1071-80 or ASTM D3031-81 or ASTM D4084-81 or					
Sulfur Dioxide	Natural Gas	ASTM D3246-81	Annually				III B.7.
Carbon Monoxide	Natural Gas	EPA Method 10	Annually		3 hours		III B.7.
VOC	Natural Gas	EPA Method 25A or w/CO in compliance	Annually		3 hours		III B.7.
Gas Analysis	Natural Gas	EPA Method 3A	Annually		3 hours		III B.7.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
004	Internal Combustion Engines No. 1508

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Visible Emissions	Natural Gas	EPA Method 9	Annually		1 hour		III C.7.
Nitrogen Oxides	Natural Gas	EPA Method 7E	Annually		3 hours		III C.7.
Sulfur Dioxide	Natural Gas	ASTM D1071-80 or ASTM D3031-81 or ASTM D4084-81 or ASTM D3246-81	Annually				III C.7.
Carbon Monoxide	Natural Gas	EPA Method 10	Annually		3 hours		
VOC	Natural Gas	EPA Method 25A or w/CO in compliance	Annually		3 hours		III.C.7.
Gas Analysis	Natural Gas	EPA Method 3A	Annually		3 hours		III.C.7.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.
**CMS [=] continuous monitoring system

Table 2-1, Summary of Compliance Requirements

Florida Gas Transmission Company
Compressor Station No. 15

FINAL Permit No.: 1230034-019-AV
Facility ID No.: 1230034

This table summarizes information for convenience purposes only. This table does not supersede any of the terms or conditions of this permit.

E.U. ID No.	Brief Description
006	Internal Combustion Engines No. 1507

Pollutant Name or Parameter	Fuel(s)	Compliance Method	Testing Time Frequency	Frequency Base Date *	Min. Compliance Test Duration	CMS**	See permit condition(s)
Visible Emiss	Natural Gas	EPA Method 9	Annually		1 hour		III D.6., D.7.
Nitrogen Oxid	Natural Gas	EPA Method 7 ASTM D1071-80 or ASTM D3031-81 or ASTM D4084-81 or ASTM	Annually		3 hours		III D.6., D.7.
Sulfur Dioxide	Natural Gas	D3246-81	Annually				III D.6., D.7.
Carbon Mono	Natural Gas	EPA Method 1	Annually		3 hours		III D.6., D.7.
VOC	Natural Gas	EPA Method 25A or w/CO in compliance	Annually		3 hours		III D.6., D.7.
Gas Analysis	Natural Gas	EPA Method 3	Annually		3 hours		III D.6., D.7.

Notes:
* The frequency base date is established for planning purposes only; see Rule 62-297.310, F.A.C.