



**CERTIFIED ANALYSIS**

Project ID: Finished Product  
 Site address: Pompano, FL  
 Sample Date: 2/27/2009  
 Siemens Lab ID#: 09-0149  
 Client ID: tank 17  
 Matrix: Oil

Company Name: FCC environmental Pompano  
 Client address: 1280 NE 48<sup>th</sup> St.  
 City, State, zip: Pompano, FL 33064  
 Client Phone: 754-785-2320  
 Sampled By: Tyrone Halfhill  
 Report Date: 3/10/2009

Parameter	Method	Result	Analysis date	Prep date	Units	RL	Dilution Factor	Regulatory Limit*
Viscosity	Visgage	180	3/9/2009	3/9/2009	SSU@100°F	10	1	N/A
Flash Point	EPA1010A	230	3/9/2009	3/9/2009	°F	30	1	<140°F
API Gravity	D287	29.5	3/9/2009	3/9/2009	N/A	0	1	N/A
Percent Water	D95	4.0	3/9/2009	3/9/2009	%	0.1	2	N/A
Percent Ash	D482	.7303	3/10/2009	3/10/2009	%	0.01	1	N/A
Total Halides (TX)	9075	132	3/9/2009	3/9/2009	mg/Kg	20	1	1000
Percent Sulfur	D4294	0.3116	3/9/2009	3/9/2009	%	0.05	1	N/A
PCBs Aroclor 1016	8082	ND	3/9/2009	3/9/2009	mg/Kg	2	4	2
PCBs Aroclor 1242	8082	ND	3/9/2009	3/9/2009	mg/Kg	2	4	2
PCBs Aroclor 1254	8082	ND	3/9/2009	3/9/2009	mg/Kg	2	4	2
PCBs Aroclor 1260	8082	ND	3/9/2009	3/9/2009	mg/Kg	2	4	2
Pounds per Gallon	CALC	7.318 CB	3/10/2009	3/10/2009	Lbs/gal	N/A	N/A	N/A
BTU per Gallon	CALC	143140 CB	3/10/2009	3/10/2009	BTU/gal	N/A	N/A	N/A
Arsenic	3040A/6010B	BRL	3/10/2009	3/10/2009	mg/Kg	2.0	10	5
Cadmium	3040A/6010B	BRL	3/10/2009	3/10/2009	mg/Kg	0.3	10	2
Chromium	3040A/6010B	1.1	3/10/2009	3/10/2009	mg/Kg	0.5	10	10
Lead	3040A/6010B	11.5	3/10/2009	3/10/2009	mg/Kg	1.0	10	100

ND= analyte was analyzed for but not detected above the reporting limit

BRL= Below Reporting Limit

*Ana Saldana*

Ana Saldana /Lab Technician

Chemist/Lab Technician

State of Florida Certification: E84160

Chemist/Lab Technician

*Carol Barrick*

Carol Barrick / Laboratory Manager

\*The regulatory limit stated above reflects the Federal EPA limit for on-specification fuel oil as defined in 40 CFR 279.11. The on-specification limit for PCB's is imposed by 40 CFR 761.20 (e). These regulatory limits may be less stringent than those required by site-specific permit requirements that may be held by the consumer. Please reference any applicable permits prior to acceptance of this material to ensure compliance.

The lab certifies results meet all requirements of the NELAC standards, unless otherwise noted. All weights are based on wet weights unless otherwise specified.