

ALL POWER GENERATOR

JOSE DELGADO
9840 NW 117 WAY
MEDLEY, FL 33178

FAX: 305-888-2090

PHONE: 305-888-0059

SAMPLE TYPE: OIL

SAMPLE SHIP TIME (days): 13

COMPANY NAME : ALL POWER GENERATOR

CUSTOMER EQUIP NUM : INT. LANDFILL

COMPARTMENT NAME : ENGINE

SERIAL NUMBER : 252242

MANUFACTURER : KOHLER

MODEL : 200R0Z71_KOHLER

JOB SITE :

EXT WARR NUMBER :

SHOP JOB NUM :

COMP SERIAL NUM :

COMPARTMENT MODEL :

COMP MANUFACTURER :

SAMPLE LABEL NUM :

FLUID BRAND/WEIGHT :

FLUID TYPE :

EXT WARR EXPIRE DATE :



Fluid Analysis Lab
8255 NW 58 Street
Miami, FL 33166-3493
(305) 592-5374 ext 1139/1304
www.kellytractor.com

LAB CONTROL NUMBER	SAMPLE DATE	PROCESS DATE	EQUIPMENT METER	METER ON FLUID	FLUID CHANGED	MAKE UP FLUID	MAKE UP FLUID UNITS	FILTER CHANGED
D260-43086-0128	3/14/13	3/27/13	0	0	Unknown			Unknown
<div style="border: 2px solid green; padding: 2px; display: inline-block;">No Action Required</div> NO PROBLEMS PRESENTLY ASSOCIATED WITH THIS SAMPLE. CONTINUE SAMPLING AT THE NORMAL INTERVAL.								
D260-40284-0085	9/27/10	10/11/10			Yes			Yes
<div style="border: 2px solid green; padding: 2px; display: inline-block;">No Action Required</div> NO PROBLEMS PRESENTLY ASSOCIATED WITH THIS SAMPLE. CONTINUE SAMPLING AT THE NORMAL INTERVAL.								

Wear Metals (ppm)	Cu	Fe	Cr	Al	Pb	Sn	Si	Na	K	Mo	Ni	Ag	Ca	Mg	Zn	P
D260-43086-0128	1	3	0	1	3	0	1	2	0	40	0	0	1243	781	1396	1111
D260-40284-0085	2	4	0	1	2	0	0	5	1	2	0	0	1564	515	1150	933

Oil Condition / Particle Count (ct/ml)	ST	OXI	NIT	SUL	W	A	F	V100
D260-43086-0128	0	16	7	18	N	N	N	14.2
D260-40284-0085	0	15	7	20	N	N	N	13.1

Ag = Silver, Al = Aluminum, B = Boron, Ca = Calcium, Cr = Chromium, Cu = Copper, Fe = Iron, P = Phosphorus, K = Potassium, Mg = Magnesium, Mo = Molybdenum, Na = Sodium, Ni = Nickel, Pb = Lead, Si = Silicon, Sn = Tin, V = Vanadium, Zn = Zinc, A = Antifreeze, F = Fuel, W = Water, P = Positive, N = Negative, T = Trace, E = Excessive, NIT = Nitration, OXI = Oxidation, ST = Soot, SUL = Sulfation, ISO = ISO Rating, PFC = Percent Fuel Content, PQI = Particle Quantifying index, NaW = Salt Water, FL Pt = Flash Point, TAN = Total Acid Number, TBN = Total Base Number, H2O = Karl Fisher result, V100 = Viscosity@100C, V40 = Viscosity@40C

Notice: This analysis is intended as an aid in predicting mechanical wear. No guarantee, expressed or implied, is made against failure of this piece of equipment or a component thereof.