

Southern Environmental Sciences, Inc.

1204 North Wheeler Street □ Plant City, Florida 33563 □ (813) 752-5014, Fax: (813) 752-2475

July 19, 2013

Richard A. Vogel
Director, Environmental & Regulatory Affairs
Vecenergy
1600 SE 17th Street Causeway, Suite 400
Ft. Lauderdale, Florida 33316

Re: Vapor Combustion Unit
Emissions Test Report

Dear Richard:

Attached is a PDF copy of the report detailing the testing performed on the above referenced source on June 12, 2013. You will need to send a copy of the report within 45 days of the testing to following address:

Broward County Environmental Protection
and Growth Management Department
Pollution Prevention, Remediation and Air Quality Division
One North University Drive, Suite 203
Ft. Lauderdale, Florida 33324

If you have any questions concerning the report or need additional copies please do not hesitate to call.

Very truly yours,

SOUTHERN ENVIRONMENTAL
SCIENCES, INC.



Kenneth M. Roberts, QEP
Vice President

MSG/mg

ec: Jim Estler, Clean Air Consulting, Inc. w/ electronic copy

**EMISSIONS TESTING
of the
SOUTH FLORIDA MATERIALS CORP.
DBA VECENERGY
VAPOR COMBUSTION UNIT
Dania Beach, Florida**

June 12, 2013

Broward County Permit No. 0112688-006-AO
SES Reference No. 13S166

Conducted by:

SOUTHERN ENVIRONMENTAL SCIENCES, INC.
1204 North Wheeler Street
Plant City, Florida 33563
Phone (813) 752-5014 Fax (813) 752-2475

Project Participants

Southern Environmental Sciences, Inc.
Byron E. Nelson
Kenneth M. Roberts
Mark S. Gierke
Dale A. Wingler

Clean Air Consulting
James Estler

**EMISSIONS TESTING
of the
SOUTH FLORIDA MATERIALS CORP.
DBA VECENERGY
VAPOR COMBUSTION UNIT
Dania Beach, Florida**

June 12, 2013

TABLE OF CONTENTS

1.0 INTRODUCTION	1
2.0 SUMMARY OF RESULTS	1
3.0 PROCESS DESCRIPTION	1
4.0 TESTING PROCEDURES	1
4.1 Methods	1
4.2 Pretest Preparation	3
4.3 Sampling Trains	3
4.4 Data Collection	3
5.0 ANALYTICAL PROCEDURE	4
5.1 Analysis	4
5.2 Data Reduction	4
FIGURES	5
APPENDIX	8
Project Participants	
Certification	
Facility Data	
Field Data Sheets	
Calculations and Equations	
Data Acquisition System Printout	
Calibration Data	

1.0 INTRODUCTION

Southern Environmental Sciences, Inc. conducted an emissions test of the South Florida Materials Corp., dba VECENERGY bulk petroleum and ethanol products loading rack vapor combustion unit (VCU) on June 12, 2013. This facility is located at 1200 SE 32nd Avenue in Dania Beach, Florida. Testing was performed to determine if the plant was operating in compliance with requirements of the Florida Department of Environmental Protection (FDEP) and the Broward County Environmental Protection and Growth Management Department (BCEPGMD). Mr. Art Pennetta of the BCEPGMD was present as an observer during a portion of the test.

2.0 SUMMARY OF RESULTS

The VCU was found to be in compliance with applicable emission limiting standards. Results of the test are summarized in Table 1. Emissions from the vapor collection system due to the loading of liquid product into gasoline tank trucks is limited to 10 milligrams of total organic compounds per liter of gasoline loaded. The emission rate during the test was 7.9 milligrams of total organic compounds per liter of gasoline loaded. The maximum allowable vapor system pressure, measured at each loading rack vapor recovery line is 17.7 inches of water. The maximum pressure observed during the test was 5.0 inches of water.

3.0 PROCESS DESCRIPTION

The VECENERGY, Dania Beach Petroleum Products Terminal truck loading facility controlled by this vapor combustion unit includes one loading rack consisting of four loading stations. Trucks are bottom filled to reduce the amount of vapors generated. All displaced vapors are routed through the vapor combustion unit. The amount of product loaded during the testing period was monitored by facility personnel and is included in Table 1 and in the appendix.

4.0 TESTING PROCEDURES

4.1 Methods

VCU testing and analyses were conducted in accordance with procedures described in 40 CFR 60.503. Volumetric flowrate at the inlet and outlet were determined in accordance with EPA Method 2B - Determination of Exhaust Gas Volume Flow Rate from Gasoline Vapor Incinerators, 40 CFR 60, Appendix A-1. Hydrocarbon concentrations were measured at the inlet and outlet in accordance with EPA Method 25A - Determination of Total Gaseous Organic Concentration Using a Flame Ionization Analyzer, 40 CFR 60, Appendix A-7. Carbon monoxide concentration was measured at the outlet in accordance with EPA Method 10 - Determination of Carbon Monoxide Emissions from Stationary Sources, 40 CFR 60, Appendix A-4. Carbon dioxide was also measured at the outlet using procedures generally described in Method 10 by substituting carbon dioxide gas where the method called for carbon monoxide. The carbon dioxide analyzer was calibrated with an Environics Model 2020 gas dilution system and calibration gases using procedures

TABLE 1. EMISSIONS TEST SUMMARY

Company: SOUTH FLORIDA MATERIALS CORP., DBA VECENERGY
Source: VAPOR RECOVERY UNIT

Date of Test	06/12/13
Start Time (24-hr. clock)	1022
End Time (24-hr. clock)	1622
Inlet Gas Volume (SCM)	780
Outlet Gas Volume (SCM)	16,129
Average Barometric Pressure (in. Hg.)	30.07
Average Static Pressure (in. H ₂ O)	1.3
Average Meter Temperature (°F)	92
Gas Meter Correction Factor	1
Total Loading Positions	4
Total Trucks Checked	21
Trucks With Leaks	0
Trucks With No Leaks	21
Total Gasoline Dispensed (gallons, net)	139,360
Gasoline excluded Due to Leaks (gallons)	
Total Countable Gasoline Dispensed (gallons)	139,360
Total Countable Gasoline Dispensed (liters)	527,478
Average VOC Inlet Concentration, (ppm, as propane)	244,850
Total mass of Inlet Hydrocarbons, (milligrams as carbon)	354,191,733
Average VOC Outlet Concentration, (ppm, as propane)	76.1
Average CO Outlet Concentration, (ppm)	210.7
Average CO ₂ Outlet Concentration, (ppm)	1.8
Total mass of Outlet Hydrocarbons, (milligrams as carbon)	4,143,839
Average Flare Efficiency, %	99.0
Emission rate (mg/l)	7.9
Allowable Emission rate (mg/l)	10

described in EPA Method 205 - Verification of Gas Dilution Systems for Field Instrument Calibrations, 40 CFR 51, Appendix M. Trucks were checked for leaks with portable flame ionization detectors (FID's) using procedures described in EPA Method 21 - Determination of Volatile Organic Compound Emission Leaks, 40 CFR 60, Appendix A-7. The FID's were calibrated on the day of the test with 450 ppm methane.

4.2 Pretest Preparation

Prior to testing, an eight inch American Meter Company turbine meter was connected in line to measure the total volume of vapor reaching the VCU. The entire vapor collection system, the vapor processing system and each gasoline loading rack were checked for vapor leaks with a combustible gas detector prior to the test. Any leaks detected were repaired prior to testing. Magnehelic gauges were connected at each loading station to measure the vapor collection system pressure. Two Photovac portable flame ionization detectors were calibrated prior to the test with zero air and 485 ppm methane calibration gas. All analyzers were calibrated in accordance with the applicable test method immediately prior to the test.

4.3 Sampling Trains

The inlet Method 25A sampling train consisted of a dilution probe (100:1), a teflon sample line, heated as necessary to prevent condensation and a California Analytical Instruments Model 300HFID(M) heated total hydrocarbon analyzer. The outlet Method 25A sampling train consisted of a heated stainless steel probe, heated teflon sample line and a California Analytical Instruments Model 300HFID(M) heated total hydrocarbon analyzer. A schematic of the hydrocarbon sampling trains is shown in Figure 1. The carbon monoxide sampling train consisted of a heated stainless steel probe, condenser, silica gel tube, carbon dioxide absorption tube, teflon sample line, and a Teledyne Instruments Gas Filter Correlation CO analyzer. The carbon dioxide sampling train consisted of a heated stainless steel sampling probe, condenser, teflon sample line and a California Analytical Instruments Model ZRH carbon dioxide analyzer. A schematic of the carbon monoxide sampling train is shown in Figure 2. Outputs from all analyzers were connected to a Eurotherm Model 6100 Data Acquisition System.

4.4 Data Collection

Inlet volume, temperature and static pressure measurements were recorded at the inlet to the meter at five minute intervals for the duration of the test to determine volume at standard conditions. Inlet and outlet hydrocarbon concentrations and outlet carbon monoxide and carbon dioxide concentrations were measured continuously throughout the six hour test period. During the testing each applicable tank truck was tested for leaks at all domes, boots and vapor recovery connections. The probe of the gas meter was held 2.5 centimeters from the potential leak source and probe movement was maintained at 2 centimeters per second. If an increase in concentration was noted at a possible leak, the probe was moved to locate the point of highest meter response. Leaks greater than or equal to 500 parts per million (as methane) should be

documented on field data sheets, however there were no leaks detected during the test period.

5.0 ANALYTICAL PROCEDURE

5.1 Analysis

Within 2 hours of the start of the test zero and high-level propane calibration gases were introduced into the hydrocarbon analyzers at the calibration valve assembly and the output was adjusted to the appropriate level if necessary. A linear regression was then conducted to calculate the predicted response for the low-level and mid-level gases. The low-level and mid-level gases were then introduced into the measurement system. The difference between the predicted and actual responses were calculated. A difference of less than 5 percent was considered acceptable. To assess the response time of the measurement system, zero gas was introduced into the system. After the output was stabilized, the high-level gas was quickly introduced. The time from the concentration change to the measurement system response equivalent to 95 percent of the step change was determined. The test was repeated three times. Results were recorded and are included in the appendix. The carbon monoxide and carbon dioxide analyzers were calibrated immediately before the beginning of the test by introducing zero and high-level calibration gases into the analyzers at the calibration valve assembly and the outputs were adjusted to the appropriate level if necessary. The low-level and mid-level gases were then introduced into the measurement systems. All instrument calibrations were checked periodically during the test by introducing mid-range and zero gases into the instruments through the sampling trains.

5.2 Data Reduction

The outlet volume was determined in accordance with equations in EPA Method 2B. Hydrocarbon emissions were determined from the outlet hydrocarbon concentrations and the calculated outlet gas flow. The total countable gasoline loaded during the test was calculated by summing the total gasoline loaded then subtracting the total loaded into trucks on which leaks were encountered. Note: There were no leaks detected on any trucks during the test period.

FIGURES

Figure 1. EPA Method 25A Sampling Train

Figure 2. Carbon Monoxide & Carbon Dioxide Sampling System




Figure 1. EPA Method 25A Sampling Train.




Figure 2. Carbon Monoxide (EPA Method 10) and Carbon Dioxide (APA Method 2B) Sampling Trains.

APPENDIX

Project Participants
Certification
Facility Data
Field Data Sheets
Calculations and Equations
Data Acquisition System Printouts
Calibration Data



PROJECT PARTICIPANTS AND CERTIFICATION

SOUTH FLORIDA MATERIALS CORP. DBA VECENERGY VAPOR COMBUSTION UNIT

Dania Beach, Florida


June 12, 2013

Project Participants:

Byron E. Nelson	Conducted the field testing.
Kenneth M. Roberts	
Mark S. Gierke	
Dale A. Wingler	
James Estler (Clean Air Consulting)	Project Coordinator
Richard Vogel (South Florida Materials Corp. dba Vecenergy)	Provided facility data
Kenneth M. Roberts	Computed test results.
Kenneth M. Roberts	Prepared the final test report.

Certification:

I certify that to my knowledge all data submitted in this report is true and correct.



Kenneth M. Roberts, QEP

Product Throughput Report by Tank (Period 1549)

SOUTH FLORIDA MATERIALS CORP PORT EVERGLADES

Report printed on: 6/12/13 at 4:51 PM

Page 1 of 1

Tank Thruput for Loads # 252866 (6/12/2013 10:27:31AM) through Loads # 252900 (6/12/2013 3:56:

Product	Tank No.	Base Code	Gross Gallons	Net Gallons	Net Barrels	Avg. Temp
ETH	207	1000	13,463 13,463	13,278 13,278	316.1 316.1	83.6
JET D	201 D	3100	39,999 39,999	39,566 39,566	942.0 942.0	81.0
PSG	206	9100	22,419 22,419	22,037 22,037	524.7 524.7	83.9
RSG	209	8500	106,035 106,035	104,045 104,045	2,477.3 2,477.3	87.2
ULSD	205	5200	34,516 34,516	34,042 34,042	810.5 810.5	89.2
Total:			216,432	212,968	5,070.7	


SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street, Plant City, Florida 33563
 (813) 752-5014 FAX (813) 752-2475

PAGE ____ OF ____

TRUCK LEAK CHECKS

COMPANY	VECTRA	DATE	6/12/13
LOCATION	Dania, FL	OPERATOR(S)	
FACILITY	Rack	INSTRUMENT(S)	Micro Fl d



LEAK LOCATION DIAGRAM

OWNER	TRUCK NO.	TIME	RACK NO.	LANE NO.	V.R. BACK PRESSURE (IN. H ₂ O)	GALLONS LOADED	PRODUCT THIS LOAD	PREV.	NO LEAK ✓	LEAK ✓	LEAK LOCATION
Rack Inc	633	1020	1	4	5.0	1 6200	REG	REG	✓		
					X	2 2600	REG	REG	✓		
						3					
						4					
					TOTAL						
Jet Star	1624	1020	1	3	41.0	1					
					X	2	JET				
						3					
						4					
					TOTAL						
AWC	477948	1020	1	2	3.0	1 3800	REG	REG	✓		
					X	2 300	REG	REG	✓		
						3					
						4					
					TOTAL						
VECTRA	121	1020	1	1	2.5	1 700	REG	REG	✓		
					X	2 1000	REG	REG	✓		
						3					
						4					
					TOTAL						
Green Sun	2938	1038	1	1	3.0	1 1600	REG	REG	✓		
					X	2 7400	REG	REG	✓		
						3					
						4					
					TOTAL						
Holiday Taqueria	T-801	1040	1	2	3.0	1 6000	MES	MES	✓		
					X	2 6250	MES	MES	✓		
						3					
						4					
					TOTAL						


SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street, Plant City, Florida 33563

(813) 752-5014 FAX (813) 752-2475

TRUCK LEAK CHECKS

COMPANY	VEHICLE #	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT LOAD	NO LOAD	LEAK	LEAK LOCATION
Palmdale		1045	1	4		1				
Bear Transport		1045				2.0				
Jet Star	1100									
Airline Carts	878	1100				4				
Holiday Transport	1094	1110				3				
ASL	7374	1115				1				



LEAK LOCATION DIAGRAM

OWNER	TRUCK NO.	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT LOAD	NO LOAD	LEAK	LEAK LOCATION
Palmdale	TR-7017	1045	1	4		1				
Bear Transport	05	1045				2.0				
Jet Star	1100									
Airline Carts	878	1100				4				
Holiday Transport	1094	1110				3				
ASL	7374	1115				1				

(3)


SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street, Plant City, Florida 33563

(813) 752-5014 FAX (813) 752-2475

TRUCK LEAK CHECKS

COMPANY	NAME	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT	NO LEAK	LEAK	LEAK LOCATION
LOCATION	OPERATOR(S)						LOAD	LOAD		
FACILITY	INSTRUMENT(S)									
JET STAR	167	1118	1	2	JET	1	2000	REG		
URBETA	8378	1132	1	3	4.0	4	2000	DIESEL		
HIALEAH TRAILER	611094	1135	1	4	DIESEL	1				
CABCO	35	1143	1	2	4.0	4	2700	REG		
URBETA	49044	1155	1	1	3.0	1	3520	REG		
ASIG	7320	1200	1	2	JET	1	2			



LEAK LOCATION DIAGRAM

OWNER	TRUCK NO.	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT	NO LEAK	LEAK	LEAK LOCATION
							LOAD	LOAD		
JET STAR	167	1118	1	2	JET	1	2000	REG		
URBETA	8378	1132	1	3	4.0	4	2000	DIESEL		
HIALEAH TRAILER	611094	1135	1	4	DIESEL	1				
CABCO	35	1143	1	2	4.0	4	2700	REG		
URBETA	49044	1155	1	1	3.0	1	3520	REG		
ASIG	7320	1200	1	2	JET	1	2			

SOUTHERN ENVIRONMENTAL SCIENCES, INC.


1204 North Wheeler Street, Plant City, Florida 33563
(813) 752-5014 FAX (813) 752-2475

PAGE OF

TRUCK LEAK CHECKS

TRUCK LEAK CHECKS			
COMPANY	VECTEN ENERGY	DATE	6/12/13
LOCATION	Danville, PA	OPERATORS	
FACILITY	Back	INSTRUMENTS(S)	PI-2000 FID

LEAK LOCATION DIAGRAM



FEAKI LOCATION DIAGRAM


OWNER	TRUCK NO.	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT		NO LEAK	LEAK	LEAK LOCATION
							THIS LOAD	PREV.			
Palmdale	7029 1080	1200	1	2	4.0	14300	REG				
MGM	07	1214	1	2	4.0	TOTAL	5700	REG			
DJS	2404	1245	1	2	Cance	1/2	1/2	Whitened Diesel			
CWC	1103	1315	1	3	Cance	1/2	1/2	Whitened Diesel			
Palmdale				1		Cance	1/2	1/2	Jacket Diesel		
Southgate	108	1320	1	1		TOTAL	500	1	9000	REG	
Turkey						TOTAL			2	3	
						TOTAL			4	4	

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street, Plant City, Florida 33563
 (813) 752-5014 FAX (813) 752-2475

(5)

PAGE ____ OF ____



LEAK LOCATION DIAGRAM

TRUCK LEAK CHECKS		
COMPANY	LOCATION	DATE
Facility	Dominick Pickle	6/12/13
		INSTRUMENT(S) Mico FID

OWNER	TRUCK NO.	TIME	RACK NO.	LANE NO.	V.R.BACK PRESSURE (IN. H ₂ O)	GALLONS LOADED	PRODUCT		NO LEAK	LEAK	LEAK LOCATION
							THIS LOAD	PREV.			
UNIBETH	115	1320	1	4	2.5	1	5600	REG			
						2					
						3					
						4					
						TOTAL	3200	REG			
Palmdale	55979	1320	21	2	4.5	1	3200	REG			
						2					
						3					
						4					
						TOTAL	7000	REG			
Liberty	4554	1334	1	2	5.0	1	1000	REG			
						2					
						3					
						4					
						TOTAL	7000	REG			
Liberty	4630	1338	1	3	3.0	1	2000	REG			
						2					
						3					
						4					
						TOTAL	7000	REG			
Cuts Team Fuel	171	1310	1	1	5.0	1	1000	REG			
						2					
						3					
						4					
						TOTAL	8100	REG			
Penn Tank Lines	41342	1356	1	4	2.5	1	2000	REG			
						2					
						3					
						4					
						TOTAL	8100	REG			


SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street, Plant City, Florida 33563

(813) 752-5014 FAX (813) 752-2475

(6)

PAGE ____ OF ____



LEAK LOCATION DIAGRAM

TRUCK LEAK CHECKS			
COMPANY	DATE	OPERATOR(S)	INSTRUMENT(S)
RECENERGY Diane Eel Rack	6/2/03		Mic E10

OWNER	TRUCK NO.	TIME	RACK NO.	LANE	V.R. BACK PRESSURE (IN. H2O)	GALLONS LOADED	PRODUCT		NO LEAK	LEAK	LEAK LOCATION
							THIS LOAD	PREV.			
Orca	171948	1403	1	1	2.5	1 6500 2 1000	REB	FRE			
VRB1ETA	8378	1417	1	2	2.5	1 8000	REB				
VRB1ETA	8776	1535	1	2	2.5	1 1600 2 300 3 400 4 400	REB				
Revert Lines	1Z1	1543	1	1	4.5	1 7100 2 1000	REB	SEM			
VRB1ETA						1 2 3 4	TOTAL				
						1 2 3 4	TOTAL				
						1 2 3 4	TOTAL				

COMPANY: VECENERGY
FACILITY: VAPOR COMBUSTION UNIT
DATE: 06/11/13

COMPANY: VECENERGY
FACILITY: VAPOUR COMBUSTION UNIT
DATE: 06/11/13

CLOCK TIME	TIME (min)	METER RDG. #1	STATIC PRESSURE ("H2O)	METER TEMP. (deg F)	BAROM. PRESSURE ("Hg)	INLET VOC (AS PROPANE)			OUTLET VOC (AS PROPANE)			ARBITRARY DIOXID			INLET			OUTLET			FLARE	
						INSTRU. CONC. (%)	INSTRU. SCALE (%)	CONC. (PPM)	INSTRU. CONC. (%)	INSTRU. SCALE (%)	CONC. (PPM)	INSTRU. CONC. (%)	INSTRU. SCALE (%)	CONC. (PPM)	MASS (M3)* (mg)	GAS VOLUME (M3)*	MASS (mg)	MASS (mg)	CONTROL EFF. (%)	ORIFICE VELOCITY		
13:27	185	19200	0.9	85	30.08	100	31.76	1,000	102.8	1,000	208.5	20	1.1	13.82	8,046,559	1174.08	221,234	97.25	2.98			
13:32	190	20700	1.4	84	30.08	100	35.28	1,000	40.9	1,000	149.7	20	4.3	41.59	26,897,162	1024.41	76,800	99.71	8.98			
13:37	195	21400	0.1	84	30.08	100	40.45	1,000	120.0	1,000	346.1	20	1.8	19.35	14,345,828	1275.62	280,586	98.04	4.18			
13:42	200	21500	0.1	85	30.08	100	38.78	1,000	18.7	1,000	16.2	20	0.0	2.76	1,961,188	-14096,62	-483,191	124.64	0.60			
13:47	205	21900	2.4	85	30.08	100	37.46	1,000	81.1	1,000	63.4	20	1.3	11.10	7,620,325	958.88	142,544	98.13	2.39			
13:52	210	22800	2.9	85	30.08	100	43.09	1,000	41.9	1,000	229.8	20	3.2	25.00	19,746,590	1008.20	77,433	99.61	5.40			
13:57	215	23900	1.5	84	30.08	100	39.47	1,000	76.5	1,000	223.3	20	3.3	30.51	22,072,535	1089.66	152,797	99.31	6.58			
14:02	220	24700	2.4	84	30.08	100	22	1,000	59.7	1,000	387.5	20	2.4	22.24	8,967,182	604.79	66,182	98.26	4.80			
14:07	225	25100	0.8	83	30.08	100	20.33	1,000	88.3	1,000	108.2	20	0.5	11.10	4,134,736	1333.93	215,902	94.78	2.39			
14:12	230	26000	0.4	85	30.08	100	13.63	1,000	110.3	1,000	211.7	20	1.2	24.85	6,208,234	829.95	167,800	97.30	5.36			
14:17	235	26500	2.1	85	30.08	100	31.91	1,000	82.5	1,000	378	20	2.2	13.86	8,108,225	594.41	89,888	98.89	2.99			
14:22	240	26800	1.1	85	30.08	100	35.79	1,000	82.3	1,000	271.2	20	1.7	8.30	5,443,202	517.40	78,053	98.57	1.79			
14:27	245	27300	0.2	85	30.08	100	12.41	1,000	84.3	1,000	367.9	20	2.4	13.80	3,138,769	211.22	32,639	98.96	2.98			
14:32	250	27500	0.1	84	30.08	100	15.05	1,000	79.2	1,000	186.5	20	1.0	5.53	1,525,020	246.53	35,790	97.65	1.19			
14:37	255	27500																				
14:42	260	27500																				
14:47	265	27500																				
14:52	270	27500																				
14:57	275	27500																				
15:02	280	27500																				
15:07	285	27500																				
15:12	290	27500																				
15:17	295	27500																				
15:22	300	27500																				
15:27	305	27500																				
15:32	310	27500																				
15:37	315	27500																				
15:42	320	27500																				
15:47	325	27500																				
15:52	330	28000	1.2	85	30.08	100	25.55	1,000	126.6	1,000	285.7	20	1.4	13.83	6,477,960	738.03	171,267	97.36	2.98			
15:57	335	28500	1.9	85	30.08	100	33.7	1,000	179.6	1,000	432.6	20	1.8	13.86	8,558,893	750.24	246,984	97.11	2.99			
16:02	340	28600	0.1	85	30.08	100	31.15	1,000	20.9	1,000	86.8	20	0.4	2.76	1,575,323	669.77	25,659	98.37	0.60			
16:07	345	28600																				
16:12	350	28600																				
16:17	355	28600																				
16:22	360	28600																				
TOTAL	28600																					
AVERAGE	1.3	92	30.07	24.49	76.1	210.7	1.8	779,973	354,191,733	16,129	4,143,839	98.95										

* At standard conditions of 68 deg F and 29.92in. Hg

Inlet Gas Volume

$$V_{is} = (V_f V_i) \times (Y_m) \times [P_{bar} + (P_g/13.6)] / P_{std} \times (T_{std}/T_m)$$

Where:

V_{is} =	Inlet Flow, ft ³ at standard conditions
Y_m =	Turbine meter correction factor
V_f =	Final meter reading (ft ³)
V_i =	Initial Meter Volume (ft ³)
P_{bar} =	Barometric pressure (in, Hg)
P_g =	Static pressure in duct (in. Hg)
P_{std} =	Standard Pressure, 29.92 in. Hg
T_{std} =	Absolute standard temperature, 528 Deg Rankin
T_m =	Absolute meter pressure (Deg Rankin)

Outlet Gas Volume

$$V_{es} = V_{is} \times \{(K_i \times (HC_i)) / [(K_e \times (HC_e)) + ((CO_2)_e - (CO_2)_a) + CO_a]\}$$

Where:

CO_e =	Mean carbon monoxide concentration in system exhaust, ppm.
$(CO_2)_a$ =	Ambient carbon dioxide concentration, ppm (if not measured during the test period, may be assumed to equal 300 ppm).
$(CO_2)_e$ =	Mean carbon dioxide concentration in system exhaust, ppm.
HC_e =	Mean organic concentration in system exhaust as defined by the calibration gas, ppm.
HC_i =	Mean organic concentration in system inlet as defined by the calibration gas, ppm.
K_e =	Hydrocarbon calibration gas factor for the exhaust hydrocarbon analyzer, unitless [equal to the number of carbon atoms per molecule of the gas used to calibrate the analyzer (2 for ethane, 3 for propane, etc.)].
K_i =	Hydrocarbon calibration gas factor for the inlet hydrocarbon analyzer, unitless.
V_{es} =	Exhaust gas volume, m ³ .
V_{is} =	Inlet gas volume, m ³ .
Q_{es} =	Exhaust gas volume flow rate, m ³ /min.
Q_{is} =	Inlet gas volume flow rate, m ³ /min.
θ =	Sample run time, min.

COMPANY: VECENERGY		VOC IN RANGE:		100	%
SOURCE: VAPOR COMBUSTION UNIT		VOC OUT RANGE:		1000	PPM
DATE: 6/12/2013		CO RANGE:		1000	PPM
		CO2 RANGE:		20	%
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %
6/12/2013 7:30	6/12/13 7:30:50 AM	Power Up			
6/12/2013 7:30	6/12/13 7:30:50 AM	Config Revision:71	Security Revision:0		
6/12/2013 7:31	-4.4	-1.9	6.8	0.3	
6/12/2013 7:32	-2.5	-2.1	-1.1	0.3	
6/12/2013 7:33	-3.4	-2.2	0.9	0.2	CALIBRATIONS
6/12/2013 7:34	-4.5	-2.2	0.9	0.2	CO CAL
6/12/2013 7:35	-6.2	-2.2	0.9	0.2	0.9
6/12/2013 7:36	-7	-2.2	722	0.2	
6/12/2013 7:37	-7.1	-2.2	917.2	0.2	
6/12/2013 7:38	-7.6	-2.2	921	0.1	
6/12/2013 7:39	-7.5	-2.3	949.2	0.1	
6/12/2013 7:40	-7.4	-2.2	949.4	0.1	
6/12/2013 7:41	-7.5	-2	949.6	0.1	949.4
6/12/2013 7:42	-7.7	-2.1	430.6	0.1	
6/12/2013 7:43	-8	-2.2	318.1	0.1	
6/12/2013 7:44	-7.8	-2.1	343.6	0.1	
6/12/2013 7:45	-7.8	-2.2	489.1	0.1	
6/12/2013 7:46	-8.1	-2.2	492.3	0.1	
6/12/2013 7:47	-8.2	-2.2	493.2	0.1	491.5
6/12/2013 7:48	-8.4	-2.1	88.1	0.1	
6/12/2013 7:49	-8.5	-2.2	3.2	0.1	
6/12/2013 7:50	-8.5	-2.2	1.4	0.1	
6/12/2013 7:51	-8.2	-2.1	133.9	0.1	METHOD 205 VERIFICATION
6/12/2013 7:52	-8.6	-2.2	200	0.1	
6/12/2013 7:53	-8.6	-2.2	202.5	0.1	201.25
6/12/2013 7:54	-8.7	-2	171.7	0.2	
6/12/2013 7:55	-9.3	-2.2	7.4	0.2	
6/12/2013 7:56	-8.9	-2.2	95.5	0.2	
6/12/2013 7:57	-9.1	-2.1	198.1	0.2	
6/12/2013 7:58	-9.3	-2.1	201.7	0.2	199.9
6/12/2013 7:59	-9.1	-2	83.4	0.2	
6/12/2013 8:00	-9	-2.1	3.6	0.2	
6/12/2013 8:01	-9.3	-2.1	1.7	0.2	
6/12/2013 8:02	-8.6	-2	182.4	0.2	
6/12/2013 8:03	-9.5	-2.1	200.6	0.2	
6/12/2013 8:04	-9.2	-2.2	201.1	0.2	200.85
6/12/2013 8:05	-9.1	-2.2	8.5	0.2	
6/12/2013 8:06	-9.1	-1.1	2	0.2	
6/12/2013 8:07	-9.2	-2	465.1	0.2	
6/12/2013 8:08	-9.5	-1.1	602.7	0.2	
6/12/2013 8:09	-9.4	-1	606	0.2	604.35
6/12/2013 8:10	-9.5	-0.9	515.4	0.2	
6/12/2013 8:11	-9.5	-0.6	15.9	0.2	
6/12/2013 8:12	-9.7	-1.5	2	0.2	
6/12/2013 8:13	-9.8	-1.7	1.7	0.2	
6/12/2013 8:14	-9.7	-2.6	468.8	0.2	
6/12/2013 8:15	-9.8	-2.4	603.2	0.2	
6/12/2013 8:16	-9.6	-2	606.1	0.2	604.65

COMPANY: VECENERGY		VOC IN RANGE:		100	%				
SOURCE: VAPOR COMBUSTION UNIT - INLET/VOC OUT RANGE:		1000 PPM							
DATE: 6/12/2013		CO RANGE:		1000	PPM				
		CO2 RANGE:		20	%				
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 8:17		-9.7	1	33.6	0.2				
6/12/2013 8:18		-9.5	-0.8	2.4	0.2				
6/12/2013 8:19		-9.1	0.1	1.7	0.2				0.1
6/12/2013 8:20		-9.1	877.3	368.2	0.2				
6/12/2013 8:21		-8.4	872.7	599.2	0.2				
6/12/2013 8:22		-8	880	605.9	0.2				
6/12/2013 8:23		-8.2	872.5	606.3	0.2				875.1
6/12/2013 8:24		-8.9	117.1	606.2	0.2				
6/12/2013 8:25		-9	516.7	606.3	0.2				
6/12/2013 8:26		-8.9	512.6	606.3	0.2				
6/12/2013 8:27		-8.8	516.4	606.3	0.2			515.2	606.3
6/12/2013 8:28		-8.7	320.6	118.1	0.2				
6/12/2013 8:29		-8.7	299	4.3	0.2				
6/12/2013 8:30		-9	301.1	1.9	0.2				
6/12/2013 8:31		-8.6	303.3	1.4	0.2				
6/12/2013 8:32		-8.8	311.1	12.1	0.2			305.2	
6/12/2013 8:33		-9.3	-0.5	488.6	0.2				
6/12/2013 8:34		0.2	-0.9	489.1	0.3				
6/12/2013 8:35		1	-1.1	490.5	0.3	VOC IN CAL			489.8
6/12/2013 8:36		0.8	-0.7	1.2	0.3	0.7			
6/12/2013 8:37		9055.1	0.9	4.7	0.2				
6/12/2013 8:38		9048.7	0.3	1.5	0.2				
6/12/2013 8:39		9028.6	0.2	1.2	0	9044.1			
6/12/2013 8:40		5104	-0.6	1.2	0				
6/12/2013 8:41		5096.6	-0.7	487.3	0				CO2 CAL 0.0
6/12/2013 8:42		5094.4	-0.7	491	10.4	5098.3			
6/12/2013 8:43		3062.9	-1.1	488.6	17.8				489.8
6/12/2013 8:44		3104.2	-1.4	-0.2	17.8				
6/12/2013 8:45		3104.2	-1.2	0.1	18	3090.4			17.9
6/12/2013 8:46				0.1	18				
6/12/2013 8:47				0	16.9				
6/12/2013 8:48				489.5	9.9				
6/12/2013 8:49				489.1	9.7				
6/12/2013 8:50				489.9	9.7				489.5
6/12/2013 8:51					9.7				
6/12/2013 8:52					9.7				
6/12/2013 8:53					9.7				9.7
6/12/2013 8:54					9	2			
6/12/2013 8:55					1.5	0.7			
6/12/2013 8:56									
6/12/2013 8:57									
6/12/2013 8:58									
6/12/2013 8:59									
6/12/2013 9:00									
6/12/2013 9:01									
6/12/2013 9:02									
6/12/2013 9:03									
6/12/2013 9:04									

COMPANY: VECENERGY			VOC IN RANGE: 100 %			VOC OUT RANGE: 1000 PPM			CO RANGE: 1000 PPM			CO2 RANGE: 20 %		
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN					
6/12/2013 9:05														
6/12/2013 9:06														
6/12/2013 9:07														
6/12/2013 9:08														
6/12/2013 9:09														
6/12/2013 9:10														
6/12/2013 9:11														
6/12/2013 9:12														
6/12/2013 9:13														
6/12/2013 9:14														
6/12/2013 9:15														
6/12/2013 9:16														
6/12/2013 9:17														
6/12/2013 9:18														
6/12/2013 9:19														
6/12/2013 9:20														
6/12/2013 9:21														
6/12/2013 9:22														
6/12/2013 9:23														
6/12/2013 9:24														
6/12/2013 9:25														
6/12/2013 9:26														
6/12/2013 9:27														
6/12/2013 9:28														
6/12/2013 9:29														
6/12/2013 9:30														
6/12/2013 9:31														
6/12/2013 9:32														
6/12/2013 9:33														
6/12/2013 9:34														
6/12/2013 9:35														
6/12/2013 9:36														
6/12/2013 9:37														
6/12/2013 9:38														
6/12/2013 9:39														
6/12/2013 9:40														
6/12/2013 9:41														
6/12/2013 9:42														
6/12/2013 9:43														
6/12/2013 9:44														
6/12/2013 9:45														
6/12/2013 9:46														
6/12/2013 9:47														
6/12/2013 9:48														
6/12/2013 9:49														
6/12/2013 9:50														
6/12/2013 9:51														
6/12/2013 9:52														

COMPANY: VECENERGY		VOC IN RANGE:		100	%				
SOURCE: VAPOR COMBUSTION UNIT		VOC OUT RANGE:		1000	PPM				
DATE: 6/12/2013		CO RANGE:		1000	PPM				
		CO2 RANGE:		20	%				
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 9:53									
6/12/2013 9:54									
6/12/2013 9:55									
6/12/2013 9:56									
6/12/2013 9:57									
6/12/2013 9:58									
6/12/2013 9:59									
6/12/2013 10:00									
6/12/2013 10:01									
6/12/2013 10:02									
6/12/2013 10:03									
6/12/2013 10:04									
6/12/2013 10:05									
6/12/2013 10:06									
6/12/2013 10:07									
6/12/2013 10:08									
6/12/2013 10:09									
6/12/2013 10:10									
6/12/2013 10:11									
6/12/2013 10:12									
6/12/2013 10:13									
6/12/2013 10:14									
6/12/2013 10:15									
6/12/2013 10:16									
6/12/2013 10:17									
6/12/2013 10:18									
6/12/2013 10:19									
6/12/2013 10:20									
6/12/2013 10:21									
6/12/2013 10:22		3156.2	-0.3	3	0.1	BEGIN TEST			
6/12/2013 10:23		3187	5.9	1.6	0.1				
6/12/2013 10:24		3281	21.7	5.7	0.1				
6/12/2013 10:25		3245	43.2	84.2	0.6				
6/12/2013 10:26		3115.7	183.3	122.1	1.5				
6/12/2013 10:27		3877.6	8.2	348.2	1.8				
6/12/2013 10:28		3816.2	-0.7	229	5	3467	51.14	157.84	1.80
6/12/2013 10:29		3711.4	46.3	93.6	4.6				
6/12/2013 10:30		3373.2	111.1	427.6	3.1				
6/12/2013 10:31		3365.1	30.7	328.1	2.6				
6/12/2013 10:32		3561.8	-1	708.6	3.4				
6/12/2013 10:33		3834.9	11.1	184	4.6	3569	39.64	348.38	3.66
6/12/2013 10:34		3774.9	104.3	475.4	3.7				
6/12/2013 10:35		3332.3	59.5	296.7	2.1				
6/12/2013 10:36		3437.4	78.1	216.9	2.4				
6/12/2013 10:37		3369.1	66.8	242.3	1.9				
6/12/2013 10:38		2492.6	52.1	163.1	1.6	3281	72.16	278.88	2.34
6/12/2013 10:39		3044.6	70.4	191.6	2.5				
6/12/2013 10:40		3537.9	95	395.9	2.9				

COMPANY: VECENERGY			VOC IN RANGE:		100	%		
SOURCE: VAPOR COMBUSTION UNIT			VOC OUT RANGE:		1000	PPM		
DATE: 6/12/2013			CO RANGE:		1000	PPM		
			CO2 RANGE:		20	%		
TIME	VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 10:41	3933	0.9	350.1	2.5				
6/12/2013 10:42	3150.7	74.5	417.7	3.6				
6/12/2013 10:43	2111.9	53.3	305	2.4	3156	58.82	332.06	2.78
6/12/2013 10:44	1647	65.4	162.6	1.2				
6/12/2013 10:45	2364.8	72.7	145.6	1.5				
6/12/2013 10:46	2485.9	78.7	149.4	1.4				
6/12/2013 10:47	2707.5	42.3	130.4	1				
6/12/2013 10:48	2344.1	65.8	79.3	0.6	2310	64.98	133.46	1.14
6/12/2013 10:49	2424.5	80.8	165	1.4				
6/12/2013 10:50	2305.6	70.8	178.3	1.4				
6/12/2013 10:51	2585.2	156.7	123.1	0.9				
6/12/2013 10:52	1860.8	164.5	308.7	2.4				
6/12/2013 10:53	1527.3	15.7	315.6	3.7	2141	97.70	218.14	1.96
6/12/2013 10:54	1283.6	39.5	364	3.6				
6/12/2013 10:55	1280.9	89.2	360.9	2.9				
6/12/2013 10:56	1531.8	84.3	238.1	2				
6/12/2013 10:57	1199.7	70.3	182.6	1.7				
6/12/2013 10:58	2149.4	70.1	136.8	1.1	1489	70.68	256.48	2.26
6/12/2013 10:59	3051.1	73.6	138.7	1.1				
6/12/2013 11:00	2240.2	52.5	140.7	1.1				
6/12/2013 11:01	1977.2	297.4	70.7	0.5				
6/12/2013 11:02	2046.5	86	68.6	0.7				
6/12/2013 11:03	1897.4	91.8	180.9	1.7	2242	120.26	119.92	1.02
6/12/2013 11:04	1401.6	49.7	189.8	1.9				
6/12/2013 11:05	1999.8	29.7	225.2	2.7				
6/12/2013 11:06	2592.7	4.5	414.5	3.9				
6/12/2013 11:07	2567.7	0.4	303.6	4				
6/12/2013 11:08	2600	13.8	230.8	4.1	2232	19.62	272.78	3.32
6/12/2013 11:09	2330.9	34.4	351.8	3.3				
6/12/2013 11:10	1993.3	78.5	371.5	3.1				
6/12/2013 11:11	2078.4	23.7	246.5	2.2				
6/12/2013 11:12	2115.6	80.1	333.3	2.7				
6/12/2013 11:13	1624.7	17	232	2.2	2029	46.74	307.02	2.70
6/12/2013 11:14	1164	57.2	286.4	3				
6/12/2013 11:15	1638.4	68.9	304.9	2.7				
6/12/2013 11:16	1089.5	37.8	195	2.3				
6/12/2013 11:17	482.8	50.9	158	2.1				
6/12/2013 11:18	296	53	152.2	2	934	53.56	219.30	2.42
6/12/2013 11:19	237.3	62.8	143.1	1.4				
6/12/2013 11:20	170.5	33.3	137.7	1.6				
6/12/2013 11:21	330.6	27.1	139.6	2				
6/12/2013 11:22	252.3	56	182.7	2.6				
6/12/2013 11:23	230.2	60.5	235.4	2.7	244	47.94	167.70	2.06
6/12/2013 11:24	185.6	59	233.3	2.4				
6/12/2013 11:25	171.4	37.8	233.4	2.6				
6/12/2013 11:26	147.3	38.4	223.3	2.7				
6/12/2013 11:27	137.3	39.3	216.4	2.6				
6/12/2013 11:28	129.9	40	211.6	2.6	154	42.90	223.60	2.58

COMPANY: VECENERGY			VOC IN RANGE:		100	%		
SOURCE: VAPOR COMBUSTION UNIT			VOC OUT RANGE:		1000	PPM		
DATE: 6/12/2013			CO RANGE:		1000	PPM		
			CO2 RANGE:		20	%		
TIME	VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 11:29	133.4	77	210.4	2.5				
6/12/2013 11:30	134.7	52	207.6	1.6				
6/12/2013 11:31	149.7	49.1	124.9	1.5				
6/12/2013 11:32	143.3	42.3	119.9	1.5				
6/12/2013 11:33	312.9	49.2	118.9	1.6	175	53.92	156.34	1.74
6/12/2013 11:34	239.1	41.2	119.9	1.6				
6/12/2013 11:35	361.3	38.8	119.7	1.6				
6/12/2013 11:36	1868.2	47.5	116.9	1.6				
6/12/2013 11:37	3323.9	121.2	218	2.4				
6/12/2013 11:38	2934.7	88.3	399	2.3	1745	67.40	194.70	1.90
6/12/2013 11:39	2103.2	62.9	177.2	1.7				
6/12/2013 11:40	1678.5	38.8	138.4	1.2				
6/12/2013 11:41	1494.3	54.4	70.6	0.5				
6/12/2013 11:42	1532.1	55	120.5	1.1				
6/12/2013 11:43	2269.4	62.8	127.2	1.3	1816	54.78	126.78	1.16
6/12/2013 11:44	2317.2	58.6	135.1	1.1				
6/12/2013 11:45	3001.3	54.8	127.5	0.9				
6/12/2013 11:46	2482.5	69.3	128.7	0.9				
6/12/2013 11:47	1616.4	100.7	134.2	1.7				
6/12/2013 11:48	2958.6	97.8	270.3	2.5	2475	76.24	159.16	1.42
6/12/2013 11:49	2708.3	471.4	139.5	0.7				
6/12/2013 11:50	2898.8	99.1	55.6	0.4				
6/12/2013 11:51	2083.2	65.9	158.8	1.5				
6/12/2013 11:52	2589.5	66.6	148.2	1.6				
6/12/2013 11:53	2631.2	60.7	143.1	1	2582	152.74	129.04	1.04
6/12/2013 11:54	1399.1	32.6	133.7	0.9				
6/12/2013 11:55	783.6	49.4	38.9	0.3				
6/12/2013 11:56	656.2	57.9	9.4	0.2				
6/12/2013 11:57	621.2	55.3	8	0.2				
6/12/2013 11:58	605.2	49	8	0.2	813	48.84	39.60	0.36
6/12/2013 11:59	593	51	7.7	0.2				
6/12/2013 12:00	1721.9	67.7	44.4	0.5				
6/12/2013 12:01	2222.3	79.5	143.9	1.6				
6/12/2013 12:02	3014.7	74	151.3	1.2				
6/12/2013 12:03	3382.8	117.5	142.3	1.1	2187	77.94	97.92	0.92
6/12/2013 12:04	3721.1	111.9	196.3	1.7				
6/12/2013 12:05	4074.7	80.2	189.4	1.2				
6/12/2013 12:06	4295.6	181.3	150.1	1				
6/12/2013 12:07	4412.5	7.8	318.9	2.3				
6/12/2013 12:08	3252.8	102.1	394.4	3.7	3951	96.66	249.82	1.98
6/12/2013 12:09	2537.7	91.3	370.7	2.7				
6/12/2013 12:10	1973.2	71.3	207.6	1.8				
6/12/2013 12:11	1102	137.5	161.7	1.5				
6/12/2013 12:12	670.4	76.8	40.7	0.3				
6/12/2013 12:13	559.4	62.7	13	0.2	1369	87.92	158.74	1.30
6/12/2013 12:14	422.7	52	8.4	0.2				
6/12/2013 12:15	551.9	53	7.8	0.2				
6/12/2013 12:16	555.7	52.1	7.7	0.2				

COMPANY: VECENERGY			VOC IN RANGE:		100	%
SOURCE: VAPOR COMBUSTION UNIT			VOC OUT RANGE:		1000	PPM
DATE: 6/12/2013			CO RANGE:		1000	PPM
			CO2 RANGE:		20	%
TIME	VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN
CO 5 MIN	CO2 5 MIN					
6/12/2013 12:17	548.4	43.4	7.6	0.2		
6/12/2013 12:18	536.9	36.8	7.4	0.2	523	47.46
6/12/2013 12:19	1368.2	71	37.7	0.4		
6/12/2013 12:20	2849.4	113.7	147.9	1.6		
6/12/2013 12:21	4103.9	198.3	201.8	1.7		
6/12/2013 12:22	4654.7	197.8	291.4	1.9		
6/12/2013 12:23	4773.7	103.7	300.1	1.7	3550	136.90
6/12/2013 12:24	4868.5	121.6	167.6	1		
6/12/2013 12:25	4904.5	106.4	170.6	1.2		
6/12/2013 12:26	3979.6	112.9	171	1.1		
6/12/2013 12:27	2499.2	42	164.9	1.1		
6/12/2013 12:28	1856.9	56.5	43.9	0.2	3622	87.88
6/12/2013 12:29	1678.8	42.7	11.4	0.1		
6/12/2013 12:30	1606.7	48.6	7.7	0.1		
6/12/2013 12:31	1538.6	52	7.4	0.1		
6/12/2013 12:32	1478.9	55.8	7.7	0.1		
6/12/2013 12:33					1576	49.78
6/12/2013 12:34						8.55
6/12/2013 12:35						0.10
6/12/2013 12:36					INSTRUMENT DRIFT CHECKS	
6/12/2013 12:37					VOC IN	
6/12/2013 12:38					-1.0	
6/12/2013 12:39					3089.3	
6/12/2013 12:40	-1.2				VOC OUT	
6/12/2013 12:41	-0.8				0.2	
6/12/2013 12:42	3088.7				303.8	
6/12/2013 12:43	3089.9				CO CO2	
6/12/2013 12:44					0.9 0.0	
6/12/2013 12:45					1 0	
6/12/2013 12:46	0.2				73.9 0	
6/12/2013 12:47	0.2				2.6 0	
6/12/2013 12:48	303				152.7 0	
6/12/2013 12:49	304.5				485.6 0	
6/12/2013 12:50					486.2 0	
6/12/2013 12:51					0.8	
6/12/2013 12:52					9.4 0	
6/12/2013 12:53					9.5 0	
6/12/2013 12:54					0 0	
6/12/2013 12:55					0 0	
6/12/2013 12:56					0 0	
6/12/2013 12:57					0 0	
6/12/2013 12:58					485.9	
6/12/2013 12:59					0.8	
6/12/2013 13:00					9.5	
6/12/2013 13:01					0	
6/12/2013 13:02					0	
6/12/2013 13:03					0	
6/12/2013 13:04					9.5	

COMPANY: VECENERGY		VOC IN RANGE:		100	%				
SOURCE: VAPOR COMBUSTION UNIT		VOC OUT RANGE:		1000	PPM				
DATE: 6/12/2013		CO RANGE:		1000	PPM				
		CO2 RANGE:		20	%				
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 13:05									
6/12/2013 13:06									
6/12/2013 13:07									
6/12/2013 13:08									
6/12/2013 13:09									
6/12/2013 13:10									
6/12/2013 13:11									
6/12/2013 13:12									
6/12/2013 13:13									
6/12/2013 13:14									
6/12/2013 13:15									
6/12/2013 13:16									
6/12/2013 13:17									
6/12/2013 13:18									
6/12/2013 13:19									
6/12/2013 13:20									
6/12/2013 13:21									
6/12/2013 13:22									
6/12/2013 13:23	1760.4	47.8	1.9	0					
6/12/2013 13:24	1787.2	49.8	10.5	0					
6/12/2013 13:25	1705	91.3	30.3	0.1					
6/12/2013 13:26	3428.7	162.2	176.2	1.5					
6/12/2013 13:27	4601.9	208.1	288.5	1.6					
6/12/2013 13:28	4356.4	2.8	537	2.5	3176	102.8	208.5	1.1	
6/12/2013 13:29	4459.7	45.9	79.9	6.3					
6/12/2013 13:30	3763.1	-1	248.4	4.2					
6/12/2013 13:31	2784	-1.1	16.5	4.6					
6/12/2013 13:32	3109.5	68.7	64.2	4.2					
6/12/2013 13:33	3571.2	92.1	339.4	2.4	3538	40.9	149.7	4.3	
6/12/2013 13:34	3748.5	155.5	210.4	1.3					
6/12/2013 13:35	3925	19.8	429.5	2.1					
6/12/2013 13:36	4107.7	135.5	425.6	2.7					
6/12/2013 13:37	4230.9	116.5	419	2					
6/12/2013 13:38	4211.2	172.8	246.2	1.1	4045	120.0	346.1	1.8	
6/12/2013 13:39	4234.9	20.6	45.5	0.1					
6/12/2013 13:40	4100.8	14.9	14.8	0					
6/12/2013 13:41	3792.2	13.4	7.3	0					
6/12/2013 13:42	3585.4	11	6.8	0					
6/12/2013 13:43	3674.5	33.5	6.8	0	3878	18.7	16.2	0.0	
6/12/2013 13:44	3757.5	46.6	7.5	0					
6/12/2013 13:45	3458.1	40.4	8.1	0					
6/12/2013 13:46	3276.2	307.8	7.6	0					
6/12/2013 13:47	4104.4	7.7	206	1.3					
6/12/2013 13:48	4135.9	3.2	87.7	5.4	3746	81.1	63.4	1.3	
6/12/2013 13:49	4141.7	0.9	268.3	3.9					
6/12/2013 13:50	4261.6	105.4	183.5	3.8					
6/12/2013 13:51	4321.7	101.1	278.9	1.7					
6/12/2013 13:52	4391.4	2.5	287.1	2.9					

COMPANY: VECENERGY		VOC IN RANGE:		100	%				
SOURCE: VAPOR COMBUSTION UNIT		VOC OUT RANGE:		1000	PPM				
DATE: 6/12/2013		CO RANGE:		1000	PPM				
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 13:53		4429.9	-0.3	131.4	3.5	4309	41.9	229.8	3.2
6/12/2013 13:54		4438.9	138.4	24.3	5.1				
6/12/2013 13:55		4091.6	-0.4	272.2	3.2				
6/12/2013 13:56		3835.3	59.8	147	3.9				
6/12/2013 13:57		3648.7	110.6	346.2	2.5				
6/12/2013 13:58		3722	74.3	326.6	1.8	3947	76.5	223.3	3.3
6/12/2013 13:59		3807.4	78.8	415.1	2.1				
6/12/2013 14:00		2454.8	49.3	468.7	2.3				
6/12/2013 14:01		1740.8	56	387.8	2.5				
6/12/2013 14:02		1517.5	53.4	329	2.5				
6/12/2013 14:03		1477.5	61.2	336.9	2.5	2200	59.7	387.5	2.4
6/12/2013 14:04		1853.9	83.6	195.6	1				
6/12/2013 14:05		1978	46.7	62.2	0.2				
6/12/2013 14:06		2013.9	179	65.3	0.2				
6/12/2013 14:07		2105.8	76	100.6	0.6				
6/12/2013 14:08		2212.9	56	117.2	0.5	2033	88.3	108.2	0.5
6/12/2013 14:09		1779.2	92.6	379.5	2.5				
6/12/2013 14:10		1753.7	115.3	290.5	1.6				
6/12/2013 14:11		1240.6	41.3	251.8	1.4				
6/12/2013 14:12		1040.4	166.8	94.5	0.3				
6/12/2013 14:13		1002.4	135.5	42.2	0	1363	110.3	211.7	1.2
6/12/2013 14:14		1818.3	93.6	244.7	1.6				
6/12/2013 14:15		3078.6	64.7	405.3	2.4				
6/12/2013 14:16		3521.2	55.2	417.1	2.6				
6/12/2013 14:17		3709.7	81.7	406.3	2.6				
6/12/2013 14:18		3825.4	117.3	416.5	2	3191	82.5	378.0	2.2
6/12/2013 14:19		3938.2	101.9	252.5	1.2				
6/12/2013 14:20		3990.1	120.9	242.3	1.2				
6/12/2013 14:21		4028.4	159.2	187.9	0.8				
6/12/2013 14:22		3941.7	17.3	339.7	1.9				
6/12/2013 14:23		1994.9	12.3	333.7	3.2	3579	82.3	271.2	1.7
6/12/2013 14:24		1784.5	22.6	389.5	3.5				
6/12/2013 14:25		1669.6	92.7	494	2.9				
6/12/2013 14:26		1171.5	108	296.4	1.7				
6/12/2013 14:27		851.2	114.7	337.9	1.8				
6/12/2013 14:28		726	83.4	321.8	1.9	1241	84.3	367.9	2.4
6/12/2013 14:29		938.7	75.9	254.5	1.5				
6/12/2013 14:30		1789.5	109.7	189.3	1.1				
6/12/2013 14:31		2255.8	46.3	208	1.2				
6/12/2013 14:32		2291.6	84.9	94.3	0.3				
6/12/2013 14:33		251				1505	79.2	186.5	1.0
6/12/2013 14:34									
6/12/2013 14:35									
6/12/2013 14:36									
6/12/2013 14:37									
6/12/2013 14:38									
6/12/2013 14:39									
6/12/2013 14:40									

COMPANY: VECENERGY SOURCE: VAPOR COMBUSTION UNIT DATE: 6/12/2013			VOC IN RANGE: 100 %	VOC OUT RANGE: 1000 PPM	CO RANGE: 1000 PPM	CO2 RANGE: 20 %			
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 14:41									
6/12/2013 14:42									
6/12/2013 14:43									
6/12/2013 14:44									
6/12/2013 14:45									
6/12/2013 14:46									
6/12/2013 14:47									
6/12/2013 14:48									
6/12/2013 14:49									
6/12/2013 14:50									
6/12/2013 14:51									
6/12/2013 14:52									
6/12/2013 14:53									
6/12/2013 15:11									
6/12/2013 15:12									
6/12/2013 15:13									
6/12/2013 15:14									
6/12/2013 15:15									
6/12/2013 15:16									
6/12/2013 15:17									
6/12/2013 15:18									
6/12/2013 15:19									
6/12/2013 15:20									
6/12/2013 15:21									
6/12/2013 15:22									
6/12/2013 15:23									
6/12/2013 15:24									
6/12/2013 15:25									
6/12/2013 15:26									
6/12/2013 15:27									
6/12/2013 15:28									
6/12/2013 15:29									
6/12/2013 15:30									
6/12/2013 15:31									
6/12/2013 15:32									
6/12/2013 15:33									
6/12/2013 15:34									
6/12/2013 15:35									
6/12/2013 15:36									
6/12/2013 15:37									
6/12/2013 15:38									
6/12/2013 15:39									
6/12/2013 15:40									
6/12/2013 15:41									
6/12/2013 15:42									
6/12/2013 15:43									
6/12/2013 15:44									
6/12/2013 15:45									

COMPANY: VECENERGY			VOC IN RANGE:		100	%			
SOURCE: VAPOR COMBUSTION UNIT			VOC OUT RANGE:		1000	PPM			
DATE: 6/12/2013			CO RANGE:		1000	PPM			
			CO2 RANGE:		20	%			
TIME		VOC IN PPM	VOC OUT PPM	CO PPM	CO2 %	VOC IN 5 MIN	VOC OUT 5 MIN	CO 5 MIN	CO2 5 MIN
6/12/2013 15:46									
6/12/2013 15:47									
6/12/2013 15:48		2008.6	40.6	11.2	0				
6/12/2013 15:49		2152.3	183.4	22.6	0.1				
6/12/2013 15:50		2569.2	160.4	336.7	2				
6/12/2013 15:51		2959.3	131.1	495.7	2.4				
6/12/2013 15:52		3085.9	117.4	562.5	2.5	2555	126.6	285.7	1.4
6/12/2013 15:53		3117.4	186.7	593.6	2.4				
6/12/2013 15:54		3242	222.2	340.9	1.5				
6/12/2013 15:55		3505.4	203.8	317.6	1.5				
6/12/2013 15:56		3603.3	196.7	320.9	1.4				
6/12/2013 15:57		3383.6	88.5	590.2	2.4	3370	179.6	432.6	1.8
6/12/2013 15:58		3331.7	40.7	355.7	1.4				
6/12/2013 15:59		3272.1	18.5	49.3	0.2				
6/12/2013 16:00		3199.8	15.8	14.6	0.1				
6/12/2013 16:01		2973.4	12.8	7.6	0.1				
6/12/2013 16:02		2795.8	16.5	6.8	0.1	3115	20.9	86.8	0.4
6/12/2013 16:03		2674	21.3	6.8	0.1				
6/12/2013 16:04		2570.9	4.5	6.7	0.1				
6/12/2013 16:05		2470.4	3.3	4.1	0.1				
6/12/2013 16:06		2433.1	4.2	0.9	0.1				
6/12/2013 16:07		2450.5	4.6	0.8	0	2520	7.6	3.9	0.1
6/12/2013 16:08		2459.7	2.7	0.8	0				
6/12/2013 16:09		2468.1	1.8	0.8	0				
6/12/2013 16:10		2471.9	1.8	0.8	0				
6/12/2013 16:11		2483.6	1.8	0.8	0				
6/12/2013 16:12		2474.2	1.9	0.8	0	2472	2.0	0.8	0.0
6/12/2013 16:13		2466.3	1.6	0.8	0				
6/12/2013 16:14		2484.2	2.2	0.8	0				
6/12/2013 16:15		2467.5	2.3	1.1	0				
6/12/2013 16:16		2487.4	2.7	1.1	0				
6/12/2013 16:17		2495.7	2.9	0.7	0	2480	2.3	0.9	0.0
6/12/2013 16:18		2481.8	284.4	0.5	0				
6/12/2013 16:19		1.5	2.9	1.1	0.1	VOC IN			
6/12/2013 16:20		1.5	0.2	0.6	0	1.5	VOC OUT		
6/12/2013 16:21		2815.5	0.2	0.2	0	0.2	CO		
6/12/2013 16:22		3099.1	289.5	0.3	0			0.25	
6/12/2013 16:23		3098.3	300.3	333.5	0	3098.7	294.9		
6/12/2013 16:24		-10.2	2.8	485.2	0				
6/12/2013 16:25		-16.6	-6.1	490.9	0				
6/12/2013 16:26		-14.2	-5.9	491.7	0				
6/12/2013 16:27		535	-3.5	491.8	0			491.75	0
6/12/2013 16:28		-1.5	-2.2	-0.2	9.2				
6/12/2013 16:29		-0.3	-2.2	-0.2	9.6				9.4
6/12/2013 16:30		-0.3	-2.1	-0.2	9.1				
6/12/2013 16:31		-0.2	-2.2	-0.2	0.4				

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street St. Plant City, Florida 33563 (813) 752-5014

METHOD 25A CALIBRATION

TEST DATA	
DATE	06/12/13
COMPANY	VECENERGY
SOURCE	VAPOR COMBUSTION UNIT - INLET
RUN#S	ALL

INSTRUMENT DATA		
	MONITOR	DAS
MANUFACTURER	CALIF. ANAL.	Eurotherm
MODEL NO.	HFID300	6100
INSTR. NO.		
RANGE (PPM)	10,000	

	predicted	actual
	0	0.7
9035	9044.1	
Slope	1.0009297	

CALIBRATION GASES			
SUPPLIER	AIRGAS	AIRGAS	AIRGAS
CYLINDER #	CC211087	SG902174	SG9103283
CONCENTRATION	3106	5089	9035
EXPIRATION DATE	12/02/13	02/12/15	02/13/15

CALIBRATION ERROR TEST (within 2 hrs. of test)						
Selected Range	10000	PPM				
Adjusted zero gas response	0.7	PPM				
Adjusted span gas response	9044.1	PPM				
Linear Regression Analysis	Slope:	1.00092972	Intercept:	0.7		
Mid-level gas response	Predicted:	5094.4	PPM	Actual:	5098.3	PPM
Low-level gas response	Predicted:	3109.6	PPM	Actual:	3090.4	PPM
RESPONSE TIME TEST						
1)	48 SECONDS	2)	45 SECONDS	3)	50 seconds	
TEST PERIOD						
	Start Time:	1022		Stop Time:	1622	

DRIFT DETERMINATION				
Time	Zero Response (PPM)	Zero Drift % diff.(span)	Span Response (PPM)	Calibration Drift % diff.
1300	-1	-0.02	3089.3	0.0
1624	1.5	0.03	3098.7	0.1

Calibration error must be < 5% of calibration gas value
 Zero and calibration drift must be < 3% of span value

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler Street St. Plant City, Florida 33563 (813) 752-5014

METHOD 25A CALIBRATION

TEST DATA	
DATE	06/12/13
COMPANY	VECENERGY
SOURCE	VAPOR COMBUSTION UNIT - OUTLET
RUN #'S	ALL

INSTRUMENT DATA		
	MONITOR	DAS
MANUFACTURER	CALIF. ANAL.	Eurotherm
MODEL NO.	HFID300	6100
INSTR. NO.		
RANGE (PPM)	1,000	

	predicted	actual
	0	0
	867.3	875.1
	Slope	1.0089934

CALIBRATION GASES			
SUPPLIER	AIRGAS	AIRGAS	AIRGAS
CYLINDER #	CC205293	CC2811789	SG910868
CONCENTRATION	304.4	507	867.3
EXPIRATION DATE	12/02/13	02/12/15	02/13/15

CALIBRATION ERROR TEST (within 2 hrs. of test)						
Selected Range	1000	PPM				
Adjusted zero gas response	0	PPM				
Adjusted span gas response	875.1	PPM				
Linear Regression Analysis	Slope:	1.00899343	Intercept:	0		
Mid-level gas response	Predicted:	511.6	PPM	Actual:	515.2	PPM
Low-level gas response	Predicted:	307.1	PPM	Actual:	305.2	PPM
RESPONSE TIME TEST				% diff.	0.7	
1)	120	SECONDS	2)	121	SECONDS	3)
TEST PERIOD				120 seconds		
	Start Time:	1022		Stop Time:	1622	

DRIFT DETERMINATION				
Time	Zero Response (PPM)	Zero Drift % diff.(span)	Span Response (PPM)	Calibration Drift % diff.
1300	-0.2	0.0	303.8	-0.1
1620	0.2	0.0	294.9	-0.9
		0.0		

0

Calibration error must be < 5% of calibration gas value
 Zero and calibration drift must be < 3% of span value

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler St. Plant City, Florida 33563 (813) 752-5014

CARBON MONOXIDE ANALYZER CALIBRATION DATA

EPA METHOD 10

COMPANY	VECENERGY		
SOURCE	VAPOR COMBUSTION UNIT - INLET		
OPERATOR	KR		
DATE	6/12/13		
RUN #'S	ALL		
INSTRUMENT SERIAL #			
RESPONSE TIME	1.2	Minutes	
INSTRUMENT RANGE	1000	PPM	
CALIBRATION SPAN	945.2	PPM (High Span Gas)	

	Cylinder value (PPM)	Analyzer calibration responses (PPM)	Absolute difference (PPM)	Difference (% of Span)
Zero	0	0.9	0.9	0.1
Mid-range	488.9	491.5	2.6	0.3
High-range	945.2	949.4	4.2	0.4

SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values		Average Bias Response (ppm)	Drift (%)
	Analyzer calibration response (PPM)	System calibration response (PPM)	System Bias (% of Cal. Span)	System calibration response (PPM)	System Bias (% of Cal. Span)		
Run 1	Zero	0.9	0.9	0.0	0	-0.1	0.5
	Upscale	491.5	491.5	0.0	485.9	-0.6	488.7
Run 2	Zero	0.9	0	-0.1	0.25	-0.1	0.1
	Upscale	491.5	485.9	-0.6	491.75	0.0	488.8

$$\text{System Calibration Bias} = \frac{\text{System Cal. Response} - \text{Direct Cal. Response}}{\text{Calibration Span}} \times 100 \longrightarrow \text{Must be} \leq 5\%$$

$$\text{Drift} = \left| \frac{\text{Final System Bias} - \text{Initial System Bias}}{} \right| \longrightarrow \text{Must be} \leq 3\%$$

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

1204 North Wheeler St. Plant City, Florida 33563 (813) 752-5014

CARBON DIOXIDE ANALYZER CALIBRATION DATA

COMPANY	VECENERGY		
SOURCE	VAPOR COMBUSTION UNIT - INLET		
OPERATOR	KR		
DATE	06/12/13		
RUN #'S	ALL		
INSTRUMENT SERIAL #			
RESPONSE TIME	1.1 MINUTES		
INSTRUMENT RANGE	20	%	
CALIBRATION SPAN	17.94	%	(High Span Gas)

	Cylinder value (%)	Analyzer calibration responses (%)	Absolute difference (%)	Difference (% of Span)
Zero	0	0	0	0.0
Mid-range	9.5	10	0.2	1.1
High-range	17.94	17.94	0	0.0

SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values		Final Values		Average Bias Response (%)	Drift (%)
	Analyzer calibration response (%)	System calibration response (%)	System Bias (% of Cal. Span)	System calibration response (%)		
Run 1	Zero	0	0.0	0	0.0	0.0
	Upscale	9.7	9.7	0.0	-1.1	9.6
Run 2	Zero	0	0.0	0	0.0	0.0
	Upscale	9.7	9.5	-1.1	9.4	-1.7

$$\text{System Calibration Bias} = \frac{\text{System Cal. Response} - \text{Direct Cal. Response}}{\text{Calibration Span}} \times 100 \longrightarrow \text{Must be} \leq 5\%$$

$$\text{Drift} = \left| \frac{\text{Final System Bias} - \text{Initial System Bias}}{} \right| \longrightarrow \text{Must be} \leq 3\%$$

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

GAS DILUTION SYSTEM FIELD EVALUATION

COMPANY	VECENERGY
SOURCE	VAPOR COMBUSTION UNIT
DATE	6/12/13
DILUTION INSTRUMENT	ENVIRONICS MODEL 2020
SERIAL #	1899
MEASUREMENT INSTRUMENT	TELEDYNE
	CO ANALYZER
SUPPLY GAS	945.2
MIDRANGE GAS	488.9

SUPPLY GAS (PPM)	MFM #	PREDICTED GAS CONC. (PPM)	INJECTION			AVERAGE (PPM)	ACCEPTABLE RANGE			% DIFFERENCE
			#1 (PPM)	#2 (PPM)	#3 (PPM)		to	to	to	
945.2	2	200	201.3	199.9	200.9	200.7	204.7	to	196.7	0.4%
945.2	2	600	604.4	604.7	606.3	605.1	617.2	to	593.0	0.9%
								to		
								to		
MID RANGE		488.9	489.8	489.8	489.5	489.7	499.5	to	479.9	0.2%

EPA METHOD 205 - VERIFICATION OF GAS DILUTION SYSTEMS FOR FIELD INSTRUMENT CALIBRATIONS
 40 CFR 51, APPENDIX M

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

PRESSURE MEASUREMENT DEVICE CALIBRATION FORM

Device Type	Magnehelic
Range	0 - 5" H ₂ O
Manufacturer	Dwyer
Serial No.	R961205N154
Calibration Date	09/11/12
Calibrated by	K. ROBERTS
Reference Device	Manometer
Measurement Units	" H ₂ O

Magnehelic	Manometer	% Difference*
0.0	0.0	0.0
1.0	1.0	0.0
2.0	2.0	0.0
4.0	4.0	0.0
4.9	5.0	-2.0

* % difference shall not exceed +/- 5%

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

PRESSURE MEASUREMENT DEVICE CALIBRATION FORM

Device Type	Magnehelic
Range	0 - 20" H ₂ O
Manufacturer	Dwyer
Serial No.	R940629LPD24
Calibration Date	09/11/12
Calibrated by	K. Roberts
Reference Device	Slack Tube Manometer
Measurement Units	" H ₂ O

Magnehelic	Manometer	% Difference*
0.0	0.0	0.00
5.0	5.0	0.00
10.0	10.0	0.00
15.0	14.8	1.35
20.0	20.0	0.00

* % difference shall not exceed +/- 5%

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

PRESSURE MEASUREMENT DEVICE CALIBRATION FORM

Device Type	Magnehelic
Range	0 - 20" H ₂ O
Manufacturer	Dwyer
Serial No.	R940629LPB12
Calibration Date	09/11/12
Calibrated by	K. ROBERTS
Reference Device	Manometer
Measurement Units	" H ₂ O

Magnehelic	Manometer	% Difference*
0.0	0.0	0.00
5.0	5.0	0.00
10.0	10.0	0.00
15.0	15.0	0.00
20.1	20.0	0.50

* % difference shall not exceed +/- 5%

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

PRESSURE MEASUREMENT DEVICE CALIBRATION FORM

Device Type	Magnehelic
Range	0 - 20" H ₂ O
Manufacturer	Dwyer
Serial No.	R940629LPD23
Calibration Date	09/11/12
Calibrated by	K. ROBERTS
Reference Device	Manometer
Measurement Units	" H ₂ O

Magnehelic	Manometer	% Difference*
0.0	0.0	0.00
5.0	5.0	0.00
9.9	10.0	-1.00
15.1	15.0	0.67
19.8	20.0	-1.00

* % difference shall not exceed +/- 5%

SOUTHERN ENVIRONMENTAL SCIENCES, INC.

PRESSURE MEASUREMENT DEVICE CALIBRATION FORM

Device Type	Magnehelic
Range	0 - 20" H2O
Manufacturer	Dwyer
Serial No.	R9602025L4
Calibration Date	09/11/12
Calibrated by	K. ROBERTS
Reference Device	Manometer
Measurement Units	" H2O

Magnehelic	Manometer	% Difference*
0.0	0.0	0.00
5.0	5.0	0.00
10.0	10.0	0.00
15.0	15.2	-1.32
20.2	20.0	1.00

* % difference shall not exceed +/- 5%

Southern Environmental Sciences, Inc.

1204 North Wheeler Street Plant City, Florida 33563 (813) 752-5014

TURBINE METER CALIBRATION

Turbine Meter No	94-54464
Pitot Cp	0.99
Calibration Date	08/21/12
Technician	B. Nelson

		Run 1	Run 2	Run 3
Delta P Readings ("H ₂ O)	P1	0.220	0.220	0.200
	P2	0.230	0.240	0.220
	P3	0.275	0.250	0.260
	P4	0.280	0.260	0.260
	P5	0.280	0.290	0.300
	P6	0.280	0.260	0.300
	P7	0.240	0.240	0.240
	P8	0.230	0.240	0.220
Avg. Sq. Rt of Delta P ("H ₂ O)		0.5037	0.4996	0.4988
Temp. Readings (Deg F)	T1	85	85	86
	T2	85	85	86
	T3	85	86	86
	T4	85	86	87
	T5	85	86	87
	T6	85	86	87
	T7	85	86	87
	T8	85	86	87
Avg. Temperature		85	85.75	86.625
Static Pressure ("H ₂ O)		0	0	0
Barometric Pressure ("Hg)		30.08	30.08	30.08
Moisture (%)		2.0	2.0	2.0
Total Pressure ("Hg)		30.08	30.08	30.08
Molecular Weight		28.42	28.42	28.42
Duct Diameter (inches)		6	6	6
Duct Area (sq. ft)		0.1963	0.1963	0.1963
Duct Velocity (ft/min)		34.04	33.79	33.76
Reference Flowrate (ft ³ /hr)		401.0	398.0	397.7
Test Meter Flowrate (ft ³ /hr)		400	400	400
Difference (%)		-0.26	0.49	0.57

Average Difference (%)	0.27
Tolerance (%)	5

SOUTHERN ENVIRONMENTAL SCIENCES, INC.
THERMOMETER CALIBRATIONS
 TEMPERATURE ARE IN DEGREES RANKIN

Calibrated by: TC/DW

Date: 3/6/2013

ID No.	Type	Range	ICE BATH		TEPID WATER		BOILING WATER		HOT OIL	
			Std. Therm.	Temp	Deg or % Diff	Std. Therm.	Temp	Deg or % Diff	Std. Therm.	Deg or % Diff
T1	PT	2000° F	500	498	0.40%	535	532	0.56%	655	-0.61%
T2	PT	2000° F	500	498	0.40%	535	532	0.56%	655	-0.61%
T3	PT	2000° F	500	498	0.40%	535	533	0.37%	655	0.15%
T4	PT	2000° F	500	498	0.40%	535	533	0.37%	655	0.15%
T5	PT	2000° F	500	498	0.40%	535	533	0.37%	655	0.15%
T6	PT	2000° F	500	498	0.40%	535	532	0.56%	655	-0.15%
T7	PT	2000° F	500	498	0.40%	535	532	0.56%	655	-0.15%
T8	PT	2000° F	500	498	0.40%	535	532	0.56%	655	-0.31%
ADAP 1	PT	2000° F	500	497	0.60%	535	532	0.56%	655	-0.31%
ADAP 2	PT	2000° F	500	497	0.60%	535	533	0.37%	655	-0.31%
ADAP 3	PT	2000° F	500	498	0.40%	535	533	0.37%	655	-0.31%
ADAP 4	PT	2000° F	500	498	0.40%	535	533	0.37%	655	-0.46%
2.5PA	PT	2000° F	501	498	0.60%	535	533	0.37%	655	-0.46%
2.5PB	PT	2000° F	501	497	0.80%	535	533	0.37%	655	-0.46%
3P	PT	2000° F	501	499	0.40%	535	533	0.37%	655	-0.31%
3INC	PT	2000° F	501	499	0.40%	535	534	0.19%	655	-0.46%
5A	PT	2000° F	501	499	0.40%	535	534	0.19%	655	-0.61%
5B	PT	2000° F	501	498	0.60%	535	534	0.19%	655	-0.61%
5C	PT	2000° F	501	500	0.20%	535	537	-0.37%	659	-0.61%
5D	PT	2000° F	501	500	0.20%	535	535	0.00%	659	-0.15%
5E	PT	2000° F	501	500	0.20%	535	533	0.37%	661	-0.15%
5VP	PT	2000° F	501	499	0.40%	535	533	0.37%	661	-0.30%
5INC	PT	2000° F	501	503	-0.40%	535	534	0.19%	661	-0.15%
6P	PT	2000° F	501	503	-0.40%	535	538	-0.56%	661	-0.45%
8A	PT	2000° F	501	502	-0.20%	535	536	-0.19%	661	-0.30%
8B	PT	2000° F	501	502	-0.20%	535	536	-0.19%	660	-0.45%
8C	PT	2000° F	501	503	-0.40%	535	536	-0.19%	661	-0.15%
8D	PT	2000° F	501	503	-0.40%	535	532	0.56%	661	-0.15%
10A	PT	2000° F	501	503	-0.40%	535	533	0.37%	660	-0.30%
10B	PT	2000° F	501	503	-0.40%	535	533	0.37%	660	-0.15%

Quality Control Limits: **Impinger Thermometers 2 Deg R, Bimetallic Thermometers (Bm) 5 Deg R, Pyrometers/Thermcouples (PT) 1.5%**

Southern Environmental Sciences, Inc.

1204 North Wheeler Street Plant City, Florida 33566 (813) 752-5014

COMBUSTIBLE GAS DETECTOR CALIBRATION

INSTRUMENT

Manufacturer	Photovac
Model No.	Portable Flame Ionization detector
Serial No.	SES 1

CALIBRATION GAS DATA

	Zero	Span
Gas Type	Zero Air	Methane/air
Concentration (PPM)	0	450
Supplier	Air Products	GASCO

CALIBRATION

	Observed Conc. (%LEL)	Actual Conc. (LEL)	Percent Diff
Zero	0	0	0
Span	448	450	0.4
Response Time	11	SECONDS	
Calibration Date	06/12/13	Technician: Mark Gierke	

Southern Environmental Sciences, Inc.

1204 North Wheeler Street Plant City, Florida 33566 (813) 752-5014

COMBUSTIBLE GAS DETECTOR CALIBRATION

INSTRUMENT

Manufacturer	Photovac
Model No.	Portable Flame Ionization detector
Serial No.	SES 2

CALIBRATION GAS DATA

	Zero	Span
Gas Type	Zero Air	Methane/air
Concentration (PPM)	0	450
Supplier	Air Products	GASCO

CALIBRATION

	Observed Conc. (%LEL)	Actual Conc. (LEL)	Percent Diff
Zero	0	0	0
Span	445	450	1.1
Response Time	11	SECONDS	
Calibration Date	06/12/13	Technician: Mark Gierke	



GASCO AFFILIATES, LLC.

320 Scarlet Blvd.
Oldsmar, FL 34677
(800) 910-0051
fax: (866) 755-8920
www.gascogas.com

CERTIFICATE OF ANALYSIS

Date: June 3, 2013

Customer: AMP-Cherokee Instruments Inc

Order Number: 12311

Lot Number: GAN-150A-450-1

Use Before: 06/03/2017

Component	Specification (+/- 10%)	Analytical Result (+/- 2%)
Methane	450 PPM	465 PPM
Air	Balance	Balance

Cylinder Size: 3.6 Cu. Ft.

Valve: 5/8" -18UNF

Contents: 103 Liter

Pressure: 1000 psig

The calibration gas prepared by Gasco is considered a certified standard. It is prepared by gravimetric, or partial pressure techniques. The calibration standard provided is certified against Gasco's G.M.I.S. (Gas Manufacturer's Intermediate Standard) which is either prepared by weights traceable to the National Institute of Standards and Technology (NIST) or by using NIST Standard Reference Materials where available.

Analyst:

A handwritten signature in black ink that reads "Rebecca Otto".



DocNumber: 000007952

Praxair Distribution Mid-Atlantic
145 Shimersville Rd.
Bethlehem, PA 18015
Telephone: (610) 317-1608
Facsimile: (610) 758-8382

CERTIFICATE OF ANALYSIS / EPA PROTOCOL GAS

Customer & Order Information:

CHEROKEE INSTRUMENTS INC *
901 BRIDGE ST
FUQUAY VARINA NC 275260

Praxair Order Number: 15303079
Customer P. O. Number: 11036
Customer Reference Number:

Fill Date: 12/9/2010
Part Number: NI CD18E-AS
Lot Number: 917034333
Cylinder Style & Outlet: AS CGA 580
Cylinder Pressure & Volume: 2000 psig 140 cu. ft.

Certified Concentration:

Expiration Date:	12/16/2013	NIST Traceable
Cylinder Number:	CC263475	Analytical Uncertainty:
17.94 %	CARBON DIOXIDE	± 1 %
Balance	NITROGEN	

Certification Information: Certification Date: 12/16/2010 Term: 36 Months Expiration Date: 12/16/2013

This cylinder was certified according to the 1997 EPA Traceability Protocol, Document #EPA-600/R-97/121, using Procedure G1
Do Not Use this Standard if Pressure is less than 150 PSIG

Analytical Data: (R=Reference Standard, Z=Zero Gas, C=Gas Candidate)**1 . Component: CARBON DIOXIDE**

Requested Concentration: 18 %
Certified Concentration: 17.94 %
Instrument Used: SIEMENS ULTRAMAT 5E SN: D2-412
Analytical Method: NON-DISPERSIVE INFRARED
Last Mullipoint Calibration: 12/2/2010

First Analysis Data:		Date:	12/16/2010
Z:	0	R:	18.08
R:	18.1	Z:	0
Z:	0	C:	17.94
UOM: %		Mean Test Assay:	17.937 %

Reference Standard Type: GMIS
Ref. Std. Cylinder #: SA18907
Ref. Std. Conc: 18.09 %
Ref. Std. Traceable to SRM #: 2745
SRM Sample #: 9-C-34
SRM Cylinder #: CAL016063

Second Analysis Data:		Date:	
Z:	0	R:	0
R:	0	Z:	0
Z:	0	C:	0
UOM: %		Mean Test Assay:	0 %

Analyzed by:

Robin Morgan ✓

Certified by:

MK 12/21/10
Michelle Kostik



CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0681 Reference Number: 83-124243123-1
 Cylinder Number: CC205933 Cylinder Volume: 144.4 CF
 Laboratory: ASG - Port Allen - LA Cylinder Pressure: 2015 PSIG
 PGVP Number: NONPGVP Valve Outlet: 350
 Gas Code: PPN Certification Date: Dec 02, 2010

Expiration Date: Dec 02, 2018

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/631, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	300.0 PPM	304.4 PPM	G1	+/- 1% NIST Traceable	12/02/2010
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	000519	SG9103755BAL	483.6 PPM PROPANE/NITROGEN		Jul 01, 2013
ANALYTICAL EQUIPMENT					
Instrument/Make/Model		Analytical Principle		Last Multipoint Calibration	
Nicole 6700 AHR0801556 M1C3H8		FTIR		Dec 02, 2010	

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release

20
Airgas

CERTIFICATE OF ANALYSIS Grade of Product: EPA Protocol

Part Number: E02NI99E15A0932 Reference Number: 122-124303002-1
Cylinder Number: CC281789 Cylinder Volume: 144.4 CF
Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22012 Valve Outlet: 350
Gas Code: PPN Certification Date: Feb 13, 2012

Expiration Date: Feb 13, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/631, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which effect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	500.0 PPM	507.0 PPM	G1	+/- 1% NIST Traceable	02/13/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	100605	CC281272	495.3 PPM PROPANE/NITROGEN	+/- 0.5%	Feb 19, 2016
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801333 C3H8	FTIR		Feb 01, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release



CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0477 Reference Number: 122-124303177-1
Cylinder Number: SG9108685BAL Cylinder Volume: 144.4 CF
Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22012 Valve Outlet: 350
Gas Code: PPN Certification Date: Feb 14, 2012

Expiration Date: Feb 14, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/631, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	850.0 PPM	867.3 PPM	G1	+/- 1% NIST Traceable	02/14/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	010506	SG9149357BAL	965.6 PPM PROPANE/NITROGEN	0.50	May 15, 2012
ANALYTICAL EQUIPMENT					
Instrument/Make/Model		Analytical Principle	Last Multipoint Calibration		
Nicolet 6700 AHR0801333 C3H8		FTIR	Feb 01, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0702 Reference Number: 122-124303000-1
 Cylinder Number: CC211087 Cylinder Volume: 144.6 CF
 Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
 PGVP Number: B22012 Valve Outlet: 350
 Gas Code: PPN Certification Date: Feb 15, 2012

Expiration Date: Feb 15, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	3000 PPM	3106 PPM	G1	+/- 1% NIST Traceable	02/15/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	060605	XC024198B	4941 PPM PROPANE/NITROGEN	+/- 0.6%	May 01, 2016
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801333 C3H8	FTIR		Feb 01, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0561 Reference Number: 122-124303008-1
Cylinder Number: SG902174ALB Cylinder Volume: 144.7 CF
Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22012 Valve Outlet: 350
Gas Code: PPN Certification Date: Feb 15, 2012

Expiration Date: Feb 15, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	5000 PPM	5089 PPM	G1	+/- 1% NIST Traceable	02/15/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	060605	XC024198B	4941 PPM PROPANE/NITROGEN	+/- 0.6%	May 01, 2016
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801333 C3H8	FTIR		Feb 01, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release



CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A1028 Reference Number: 83-124272181-1
 Cylinder Number: SG9103283BAL Cylinder Volume: 145.1 CF
 Laboratory: ASG - Port Allen - LA Cylinder Pressure: 2015 PSIG
 PGVP Number: B42011 Valve Outlet: .350
 Gas Code: PPN Certification Date: Jul 06, 2011

Expiration Date: Jul 06, 2019

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
PROPANE	9000 PPM	9035 PPM	G1	+/- 1% NIST Traceable	07/06/2011
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	06060603	XC024146B	0.9748 % PROPANE/NITROGEN	1	May 01, 2016
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801556 C3H8 HC3H8	FTIR		Jun 13, 2011		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release



5

CERTIFICATE OF ANALYSIS Grade of Product: EPA Protocol

Part Number: E02NI99E15A03L6 Reference Number: 122-124323956-1
Cylinder Number: CC275 Cylinder Volume: 144.3 CF
Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22012 Valve Outlet: 350
Gas Code: CO Certification Date: Jul 09, 2012

Expiration Date: Jul 09, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/551, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	490.0 PPM	488.9 PPM	G1	+/- 1% NIST Traceable	06/30/2012, 07/09/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	120603	CC353950	249.3 PPM CARBON MONOXIDE/NITROGEN	+/- 0.4%	Oct 26, 2017
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801549 CO	FTIR		Jun 13, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release



CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number: E02NI99E15A0305 Reference Number: 122-124303001-1
Cylinder Number: CC176634 Cylinder Volume: 144.4 CF
Laboratory: ASG - Durham - NC Cylinder Pressure: 2015 PSIG
PGVP Number: B22012 Valve Outlet: 350
Gas Code: CO Certification Date: Feb 20, 2012

Expiration Date: Feb 20, 2020

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	950.0 PPM	945.2 PPM	G1	+/- 1% NIST Traceable	02/13/2012, 02/20/2012
NITROGEN	Balance				
CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
110603	110603	XC031808B	988.8 PPM CARBON MONOXIDE/NITROGEN	0.40	Dec 13, 2016
ANALYTICAL EQUIPMENT					
Instrument/Make/Model	Analytical Principle		Last Multipoint Calibration		
Nicolet 6700 AHR0801549 CO	FTIR		Jan 26, 2012		

Triad Data Available Upon Request

Notes:

Signature on file

Approved for Release

CERTIFICATE OF ANALYSIS AIR - ULTRA ZERO

Airgas USA, LLC
1620 Tampa East Blvd
Tampa, FL 33619
Office: (813) 626-2905 Fax: (813) 620-0150
www.airgas.com


Part Number: A1 UZ300CT Reference Number: 21-400207457-1
Cylinder Number: W814660 Cylinder Volume: 312.0 CF
Laboratory: ASO - Tampa Plant - FL Cylinder Pressure: 2640 PSIG
Analysis Date: Jun 04, 2013 Valve Outlet: 590
Lot Number: 21-400207457-1

ANALYTICAL RESULTS

Component	Requested Purity	Certified Concentration
AIR		
CO + CO2	< 1 PPM	0.74 PPM
THC	< 0.1 PPM	<LDL 0.02 PPM
Percent Oxygen	20-22 %	21.60 %
Moisture	< 2 PPM	1.251 PPM

Notes:

Impurities verified against analytical standards traceable to NIST by weight and/or analysis.



Approved for Release