

# FUEL METER PROVING CERTIFICATION

STATION: <u>110W-3</u>				DATE: <u>8/5/09</u>	
UNIT NO. / LOCATION OF METER <u>GENERATOR #1</u>		REC. MAN. <u>GRAND</u>	MODEL NO. <u>IT400</u>	SERIAL NO. <u>55837</u>	PRINTER INSTALL YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
TOTALIZER-START: <u>14851.2</u>		TOTALIZER-FINISH: <u>15000.8</u>		TEMPERATURE °F <u>88</u>	
METER MANUFACTURER <u>L/C</u>		MODEL NO. <u>M-7-1</u>	SERIAL NO. <u>522772</u>	RATED FLOW - G.P.M. MIN. <u>10</u> MAX. <u>100</u>	TYPE OF FUEL JETA <input type="checkbox"/> GAS <input type="checkbox"/> AVGAS <input type="checkbox"/> DIESEL <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>
ALL SEALS INTACT BEFORE TEST YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	SEAL NUMBERS / LETTERS BEFORE TEST <u>NEW</u>		PROVER- <u>50</u>		

50 gal. SN #795    
  100 gal. SN #4902    
  525 gal. SN #130854    
  1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	READINGS - UNITS / TENTHS			ADJUSTMENTS	REMARKS
		CU. IN PROVER	METER REGISTER	CU. IN DIFFERENCE		
1	10	0	49.8	+46	14901.0	
2		0	49.7	+96	14950.7	
3		420	50.1	0	15000.8	552.221
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	IF YES, POSITION OF ADJUSTER BEFORE TEST <u>555.559</u>	POSITION OF ADJUSTER AFTER TEST <u>552.221</u>
---	--	---

METER ADJUSTED & REGISTER SEALED AFTER TEST: YES <input checked="" type="checkbox"/>	SEAL NUMBER / LETTERS AFTER TEST <u>MAS/STR</u>	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
--	--	--

ERROR TABLE ERROR % OF 1%	U.S. GALLON PROVER											
	1000		750			500			250			100
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.
1/10	1	231	3/4	175	173	1/2	113	170	1/4	57	120	125

NOTES:

NAME OF MECHANIC: MM [Signature]

DATE: 8/5/09

# FUEL METER PROVING CERTIFICATION

STATION: <u>MDW + Gower</u>				DATE: <u>8/5/09</u>	
UNIT NO. / LOCATION OF METER <u>Generator #2</u>		REC. MAN. <u>GRAND</u>	MODEL NO. <u>IT400</u>	SERIAL NO. <u>55837</u>	PRINTER INSTALL YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
TOTALIZER-START: <u>61723.5</u>		TOTALIZER-FINISH: <u>61823.3</u>		TEMPERATURE °F <u>88</u>	
METER MANUFACTURER <u>LK</u>		MODEL NO. <u>M-7-1</u>	SERIAL NO. <u>522701</u>	RATED FLOW - G.P.M. MIN. <u>10</u> MAX. <u>100</u>	TYPE OF FUEL JETA <input type="checkbox"/> GAS <input type="checkbox"/> AVGAS <input type="checkbox"/> DIESEL <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>
ALL SEALS INTACT BEFORE TEST YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		SEAL NUMBERS / LETTERS BEFORE TEST <u>new</u>		PROVER- <u>50</u>	

50 gal. SN #795    
  100 gal. SN #4902    
  525 gal. SN #130854    
  1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	CU. IN PROVER	READINGS - UNITS / TENTHS		ADJUSTMENTS	REMARKS
			METER REGISTER	CU. IN DIFFERENCE		
1	10	<u>0</u>	<u>49.8</u>	<u>+46</u>	<u>61773.8</u>	
2		<u>0</u>	<u>50.0</u>	<u>0</u>		<u>553.333</u>
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	YES, POSITION OF ADJUSTER BEFORE TEST <u>555.555</u>	POSITION OF ADJUSTER AFTER TEST <u>553.333</u>
METER ADJUSTED & REGISTER SEALED AFTER TEST: <input checked="" type="checkbox"/> YES	SEAL NUMBER / LETTERS AFTER TEST <u>UNPS/STW</u>	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: <input type="checkbox"/> YES <input type="checkbox"/> NO

ERROR TABLE ERROR % OF 1%	U.S. GALLON PROVER															
	1000			750			500			100			50			5
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.
1/10	1	25.1	3/4	.75	1/2	.5	1/10	.1	23	1/20	.05	11	1/20	.05	5	.005

NOTES:

NAME OF MECHANIC/SEALER: <u>MP Salazar</u>	<b>SOUTHERN TRUCK REPAIR &amp; CALIBRATION LLC.</b> 18310 SW 89th Court • Miami, Florida 33157 Ph: 305-302-8334 • Fax: 305-254-8117
---	---

# FUEL METER PROVING CERTIFICATION

STATION: <u>MIDWA Sewer</u>				DATE: <u>8/15/09</u>	
UNIT NO. / LOCATION OF METER <u>Generator #3</u>		REC. MAN. <u>Gerard</u>	MODEL NO. <u>IT400</u>	SERIAL NO. <u>95832</u>	PRINTER INSTALL YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
TOTALIZER-START: <u>3720.4</u>		TOTALIZER-FINISH: <u>3870.4</u>		TEMPERATURE °F <u>69</u>	
METER MANUFACTURER <u>L/C</u>		MODEL NO. <u>M-7-1</u>	SERIAL NO. <u>522770</u>	RATED FLOW - G.P.M. MIN. <u>10</u> MAX. <u>100</u>	
ALL SEALS INTACT BEFORE TEST YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		SEAL NUMBERS / LETTERS BEFORE TEST <u>new</u>		PROVER: <u>50</u>	
TYPE OF FUEL JETA _____ GAS _____ AVGAS _____ DIESEL <input checked="" type="checkbox"/> OTHER _____					

50 gal. SN #795    
  100 gal. SN #4902    
  525 gal. SN #130854    
  1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	READINGS - UNITS / TENTHS			ADJUSTMENTS	REMARKS
		CU. IN PROVER	METER REGISTER	CU. IN DIFFERENCE		
1	10	<u>0</u>	<u>49.3</u>	<u>+46</u>	<u>3770.4</u>	
2		<u>+25</u>	<u>50.0</u>	<u>+25</u>	<u>3820.4</u>	<u>553.333</u>
3		<u>0</u>	<u>50.0</u>	<u>0</u>		
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	IF YES, POSITION OF ADJUSTER BEFORE TEST <u>555.555</u>	POSITION OF ADJUSTER AFTER TEST <u>552.228</u>
METER ADJUSTED & REGISTER SEALED AFTER TEST: <input checked="" type="checkbox"/> YES	SEAL NUMBER / LETTERS AFTER TEST <u>11/23/317</u>	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

ERROR TABLE ERROR % OF 1%	U.S. GALLON PROVER																
	1000		750		500		100		50		5		5		5		
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	
1/10	1	1.	231	3/4	.75	173	1/2	.5	115	1/10	.1	23	1/20	.05	11	1/200	.005

NOTES:

NAME OF MECHANIC/SEALER: <u>W.P. Schenck</u>	<b>SOUTHERN TRUCK REPAIR &amp; CALIBRATION LLC.</b> 18310 SW 89th Court • Miami, Florida 33157 Ph: 305-302-8334 • Fax: 305-254-8017
---	---

# FUEL METER PROVING CERTIFICATION

UNIT NO. / LOCATION OF METER <b>Generator #4</b>				REC. MAN. <b>GRAND</b>	MODEL NO. <b>FT400</b>	SERIAL NO. <b>55537</b>	DATE: <b>5/5/09</b>
TOTALIZER-START: <b>4279.8</b>		TOTALIZER-FINISH: <b>4379.5</b>		TEMPERATURE °F <b>84</b>		PRINTER INSTALL YES <input checked="" type="checkbox"/> NO	
METER MANUFACTURER <b>LC</b>	MODEL NO. <b>M-7-1</b>	SERIAL NO. <b>522769</b>	RATED FLOW - G.P.M. MIN <b>10</b> MAX <b>100</b>		TYPE OF FUEL JETA _____ GAS _____ AVGAS _____ DIESEL <input checked="" type="checkbox"/> _____ OTHER _____		
ALL SEALS INTACT BEFORE TEST YES _____ NO <input checked="" type="checkbox"/>	SEAL NUMBERS / LETTERS BEFORE TEST <b>new</b>		PROVER- <b>50</b>				

50 gal. SN #795    
  100 gal. SN #4902    
  525 gal. SN #130854    
  1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	CU. IN PROVER	READINGS - UNITS / TENTHS		ADJUSTMENTS	REMARKS
			METER REGISTER	CU. IN DIFFERENCE		
1	10	45	49.7	+65	4329.5	
2	10	48	50.0	+8	4379.5	552222
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						

ADJUSTMENT REQUIRED: YES <input checked="" type="checkbox"/> NO	IF YES, POSITION OF ADJUSTER BEFORE TEST <b>555.555</b>	POSITION OF ADJUSTER AFTER TEST <b>552.222</b>
METER ADJUSTED & REGISTER SEALED AFTER TEST: <input checked="" type="checkbox"/> YES	SEAL NUMBER / LETTERS AFTER TEST <b>MP/STK</b>	STATE WEIGHTS & MEASURE REPRESENTATION PRESENT: YES: <input checked="" type="checkbox"/> NO

ERROR TABLE ERROR %	U.S. GALLON PROVER															
	1000			750			500			50			5			
OF 1%	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.		
1/10	1	1.	231	3/4	.75	173	1/2	.5	115	1/10	23	1/20	.05	11	1/200	.005

NOTES:

NAME OF MECHANIC/SEALER: <b>[Signature]</b>	<b>SOUTHERN TRUCK REPAIR &amp; CALIBRATION LLC.</b> 18310 SW 89th Court • Miami, Florida 33157 Ph: 305-302-8334 • Fax: 305-254-8017
--	---

# FUEL METER PROVING CERTIFICATION

STATION: <u>MDL 029</u>				DATE: <u>8/4/09</u>	
UNIT NO. / LOCATION OF METER <u>Generator #5</u>		REC. MAN. <u>Grand</u>	MODEL NO. <u>IT400</u>	SERIAL NO. <u>55832</u>	PRINTER INSTALL YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
TOTALIZER-START: <u>17403</u>		TOTALIZER-FINISH: <u>18969</u>		TEMPERATURE °F <u>88</u>	
METER MANUFACTURER <u>L/C</u>		MODEL NO. <u>M-7-1</u>	SERIAL NO. <u>49229</u>	RATED FLOW - G.P.M. MIN <u>10</u> MAX <u>100</u>	TYPE OF FUEL JETA <input type="checkbox"/> GAS <input type="checkbox"/> AVGAS <input type="checkbox"/> DIESEL <input checked="" type="checkbox"/> OTHER <input type="checkbox"/>
ALL SEALS INTACT BEFORE TEST YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		SEAL NUMBERS / LETTERS BEFORE TEST <u>new</u>		PROVER- <u>50</u>	

50 gal. SN #795    
  100 gal. SN #4902    
  525 gal. SN #130854    
  1000 gal. SN #24219

TEST RUN	FLOW RATE/MIN	CU. IN PROVER	READINGS - UNITS / TENTHS		DIFFERENCE	ADJUSTMENTS	REMARKS
			METER	REGISTER			
1	10	0	49		- 3.14	555.55500	
2		110	50.6	12th	- .75	544.44390	17452
3		0	51.1	11th	- 1.50	538.52601	1795.8
4		0	56.0		7	550.3699	1846.9
5							1896.9
6							
7							
8							
9							
10							
11							
12							
13							
14							

ADJUSTMENT REQUIRED: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	IF YES, POSITION OF ADJUSTER BEFORE TEST <u>555,555</u>	POSITION OF ADJUSTER AFTER TEST <u>550,3699</u>
METER ADJUSTED & REGISTER SEALED AFTER TEST: YES <input checked="" type="checkbox"/>	SEAL NUMBER / LETTERS AFTER TEST <u>MDP3/STRC</u>	STATE WEIGHTS & MEASUREMENT REPRESENTATION PRESENT: YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>

ERROR TABLE ERROR % OF 1%	U.S. GALLONS ON PROVER																
	1000			750			500			100			50			5	
	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	GAL.	CU. IN.	
1/10	1	1.	231	3/4	.75	173	1/2	.5	117	1/10	.1	23	1/20	.05	11.7	1/200	.005

NOTES:

NAME OF MECHANIC/SEALER: <u>W.A. Schwaner</u>	SOURCE: <b>SOLO HERN TRUCK REPAIR &amp; CALIBRATION LLC.</b> 18310 SW 89th Court • Miami, Florida 33157 Ph: 305-302-8334 • Fax: 305-354-8017
--	--