

Tampa Electric Laboratory Services

5012 Causeway Blvd Tampa Fl. 33619 * Ph (813)630-7490 * Fax (813)630-7360 * DOH #E54272

Hardee Power Partner Limited

Matt Drennan

6695 County Road 663 North Bowling Green, FL 33834

mdrennan@inveneryllc.com

Sample Collection Method:

Report Date:

04/12/12 10:56

Sample Information

Client:

Hardee Power Partner Limited

L12C200-01

Lab Sample ID: Sample Description:

Fuel Oil Tank

Oil Project:

Sampled By:

Client

Date and Time Collected:

3/21/12 0:00

Date of Sample Receipt:

3/21/12 8:30

Laboratory Results

Parameter	Result	Units	PQL	Qualifier Code	Dil	Test Method	Analyst	Analysis Date & Time
	Tampa E	lectric Company	, Labora	tory Servi	ces		-	
CHN in Oil								
Nitrogen	0.200	%	0.200		1	ASTM 5291	KAPXJ	3/22/12 12:40
General Chemistry Parameters								
Flashpoint	151	°F	60.0		1	EPA 1010	PXJ	3/26/12 10:32
Potassium	0.0700	mg/kg	0.500	U	1	ASTM D-3605	MCR	4/4/12 9:56
Sodium	0.0500	mg/kg	0.500	U	1	ASTM D-3605	MCR	4/4/12 9:13
General Fuel Parameters								
API Gravity @ 60 Deg. F	35.8	Degrees API	0.01		1	ASTM D-5002	PXJ	3/27/12 15:41
Ash in Oil	0.00100	mass %	0.00100	U	1	ASTM D-482	PXJ	4/2/12 10:00
Gross Heat of Combustion in Oil (HHV)	19503	BTU/Lb	1		1	ASTM D-240	PXJ	4/2/12 10:50
Gross Heat of Combustion in Oil (HHV)	137340	BTU/Gal	1		1	ASTM D-240	PXJ	3/27/12 10:06
Pounds SO2/Million BTU	0.0230	Lbs/MMBTU			1	Calc	SZS	4/2/12 10:50
Pounds/Gallon @ 60 Deg. F	7.042	Lbs/gal	1.000		1	D1250-80 Tbl 8	PXJ	3/27/12 10:06
Relative Density 60/60 Deg F	0.8458	-	0.0001		1	ASTM D-1250	PXJ	3/27/12 15:41
Sulfur, Low Level	0.0227	%	0.0001		1	ASTM D-5453	SZS	3/23/12 16:54
Kinematic Viscosity @ 100 F	2.77	cSt	1.00		1	ASTM D-445	PXJ	3/26/12 13:22
Saybolt Universal Viscosity @ 100F	35.2	SUS	0.100		1	ASTM D-2161	PXJ	3/26/12 13:22
Water and Sediment by Volume	0.0500	% by Volume	0.0500	U	1	ASTM D-2709	PXJ	3/26/12 12:00
Total Metals by SW846 Method 6010B								
Lead	0.0765	mg/kg	0.956	U	1	EPA 6010B	MCR	4/5/12 10:09
Vanadium	0.0430	mg/kg	0.956	U	1	EPA 6010B	MCR	4/5/12 10:09

Comments

U Indicates that the compound was analyzed for but not detected.

I Estimated value

Subcontract Laboratories:



Tampa Electric Laboratory Services

5012 Causeway Blvd Tampa Fl. 33619 * Ph (813)630-7490 * Fax (813)630-7360 * DOH #E54272

Tampa Electric Company, Laboratory Services

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Peggy Penner, Manager, Laboratory Services

MONTHLY OPERATIONS SUMMARY Hardee Power Station - Unit 2B

REPORTING MONTH: January - 2012

	GAS	·	OIL	:
TOTAL HOURS FIRED	6.25	.1	0.00	
QUANTITY OF FUEL FIRED	48020.0	HSCF	0.0	LBS
HEAT INPUT OF FUEL FIRED (1) HEAT INPUT OF FUEL FIRED (1)	5282.2 4758.9	MMBTU (HHV) MMBTU (LHV)	0.0	MMBTU (HHV) MMBTU (LHV)
AVERAGE HEAT INPUT OF FUEL PERMIT LIMIT (@59 f, 60% RH, 14.7 PSIA) (2)	761.4 950.0	MMBTU/hr (LHV) MMBTU/hr (LHV)	0.0 1060.0	MMBTU/hr (LHV) MMBTU/hr (LHV)
AVERAGE SULFUR CONTENT OF FUEL (3) PERMIT LIMIT	0.077 2.000	gr/hcf gr/hcf	0.00	० ० ०
12 MONTH ROLLING HOURS OF OIL FIRED PERMIT LIMIT		(>4	0.00 876 400 trigge	rs stack test on oil)

NOTES:

- ## Indicates value Exceeded the Permit Limit
- (1) HHV/LHV Ratio = 1.11 for Gas and 1.06 for Oil
- (2) See Appendix G-1 of permit to correct for actual ambient conditions.
- (3) Fuel Sulfur content for gas obtained from FGT website (daily average); for oil obtained from EAL lab analysis.

MONTHLY OPERATIONS SUMMARY Hardee Power Station - Unit 2B

REPORTING MONTH: February - 2012

	GAS		OIL	
TOTAL HOURS FIRED	0.00		0.00	
QUANTITY OF FUEL FIRED	0.0	HSCF	0.0	LBS
HEAT INPUT OF FUEL FIRED (1) HEAT INPUT OF FUEL FIRED (1)	0.0	MMBTU (HHV) MMBTU (LHV)	0.0	MMBTU (HHV) MMBTU (LHV)
AVERAGE HEAT INPUT OF FUEL PERMIT LIMIT (@59 f, 60% RH, 14.7 PSIA) (2)	0.0 950.0	MMBTU/hr (LHV) MMBTU/hr (LHV)	0.0 1060.0	MMBTU/hr (LHV) MMBTU/hr (LHV)
AVERAGE SULFUR CONTENT OF FUEL (3) PERMIT LIMIT	0.000	gr/hcf gr/hcf	0.00 0.05	% %
12 MONTH ROLLING HOURS OF OIL FIRED PERMIT LIMIT		(>4	0.00 876 400 trigge	rs stack test on oil)

NOTES:

- ## Indicates value Exceeded the Permit Limit
- (1) HHV/LHV Ratio = 1.11 for Gas and 1.06 for Oil
- (2) See Appendix G-1 of permit to correct for actual ambient conditions.
- (3) Fuel Sulfur content for gas obtained from FGT website (daily average); for oil obtained from EAL lab analysis.

MONTHLY OPERATIONS SUMMARY Hardee Power Station - Unit 2B

REPORTING MONTH: March - 2012

	GAS		OIL	
TOTAL HOURS FIRED	10.50		0.00	
QUANTITY OF FUEL FIRED	83100.0	HSCF	0.0	LBS
HEAT INPUT OF FUEL FIRED (1) HEAT INPUT OF FUEL FIRED (1)	9141.0 8235.2	MMBTU (HHV) MMBTU (LHV)	0.0	MMBTU (HHV) MMBTU (LHV)
AVERAGE HEAT INPUT OF FUEL PERMIT LIMIT (@59 f, 60% RH, 14.7 PSIA) (2)	784.3 950.0	MMBTU/hr (LHV) MMBTU/hr (LHV)	0.0	MMBTU/hr (LHV) MMBTU/hr (LHV)
AVERAGE SULFUR CONTENT OF FUEL (3) PERMIT LIMIT	0.090 2.000	gr/hcf gr/hcf	0.00 0.05	ଚ୍ଚ ଚ୍ଚ
12 MONTH ROLLING HOURS OF OIL FIRED PERMIT LIMIT		(>4	0.00 876 100 trigge:	rs stack test on oil)

NOTES:

- ## Indicates value Exceeded the Permit Limit
- (1) HHV/LHV Ratio = 1.11 for Gas and 1.06 for Oil
- (2) See Appendix G-1 of permit to correct for actual ambient conditions.
- (3) Fuel Sulfur content for gas obtained from FGT website (daily average); for oil obtained from EAL lab analysis.