

Average Values Report
Generated: 6/6/2011 14:33

Company: Vandolah Power Company
Plant: 2394 Vandolah Road
City/St: Wauchula, FL 33873
Source: stack1

Period Start: 6/6/2011 12:00
Period End: 6/6/2011 14:30
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average MW_1 MW	Average NOx_low1 ppm	Average O2_1 %O2	Average Heat_G_751 mmBTU	Average GasFlow751 HSCFH	Average NOxCorrt_1 ppm	Average NOx#mm_751 #/M
06/06/2011 12:00	163.6	9.6	13.46	1644.2	16191.8	7.6	0.028
06/06/2011 12:01	163.8	9.6	13.46	1644.2	16191.8	7.6	0.028
06/06/2011 12:02	164.2	9.6	13.46	1644.2	16270.4	7.6	0.028
06/06/2011 12:03	164.2	9.6	13.46	1644.2	16191.8	7.6	0.028
06/06/2011 12:04	164.0	9.6	13.46	1644.2	16191.8	7.6	0.028
06/06/2011 12:05	164.2	9.6	13.46	1644.2	16270.4	7.6	0.028
06/06/2011 12:06	164.2	9.6	13.46	1644.2	16270.4	7.6	0.028
06/06/2011 12:07	163.5	9.6	13.46	1644.2	16191.8	7.6	0.028
06/06/2011 12:08	163.4	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:09	163.2	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:10	163.4	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:11	163.3	9.4	13.46	1644.2	16270.4	7.5	0.028
06/06/2011 12:12	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:13	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:14	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:15	163.2	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:16	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:17	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:18	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:19	163.3	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:20	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:21	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:22	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:23	163.0	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:24	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:25	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:26	163.1	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:27	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:28	163.1	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:29	163.0	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:30	163.2	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:31	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:32	163.1	9.4	13.46	1644.2	16191.8	7.5	0.028

Period Start:	Average MW_1 MW	Average NOx_low1 ppm	Average O2_1 %O2	Average Heat_G_751 mmBTU	Average GasFlow751 HSCFH	Average NOxCorrt_1 ppm	Average NOx#mm_751 #/M
06/06/2011 12:33	162.8	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:34	163.1	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:35	163.3	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:36	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:37	162.8	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:38	162.5	9.3	13.46	1644.2	16113.2	7.4	0.028
06/06/2011 12:39	162.9	9.3	13.46	1644.2	16113.2	7.4	0.028
06/06/2011 12:40	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:41	163.2	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:42	163.3	9.4	13.46	1644.2	16113.2	7.5	0.028
06/06/2011 12:43	162.9	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:44	162.7	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:45	162.3	9.3	13.46	1644.2	16113.2	7.4	0.028
06/06/2011 12:46	162.9	9.3	13.46	1644.2	16113.2	7.4	0.028
06/06/2011 12:47	163.3	9.3	13.46	1644.2	16113.2	7.4	0.028
06/06/2011 12:48	163.3	9.4	13.47	1644.2	16191.8	7.5	0.028
06/06/2011 12:49	163.3	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:50	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:51	163.4	9.4	13.47	1644.2	16191.8	7.5	0.028
06/06/2011 12:52	163.6	9.4	13.46	1644.2	16270.4	7.5	0.028
06/06/2011 12:53	163.4	9.4	13.47	1644.2	16191.8	7.5	0.028
06/06/2011 12:54	163.2	9.5	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:55	163.4	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:56	163.4	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:57	163.4	9.4	13.47	1644.2	16191.8	7.5	0.028
06/06/2011 12:58	163.2	9.4	13.46	1644.2	16191.8	7.5	0.028
06/06/2011 12:59	163.2	9.3	13.46	1644.2	16191.8	7.4	0.028
06/06/2011 13:00	163.3	9.3	13.46	1640.4	16113.2	7.4	0.028
06/06/2011 13:01	162.7	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:02	163.3	9.3	13.46	1640.4	16191.8	7.4	0.028
06/06/2011 13:03	163.2	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:04	163.3	9.3	13.46	1640.4	16191.8	7.4	0.028
06/06/2011 13:05	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:06	163.3	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:07	163.3	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:08	162.5	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:09	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:10	163.4	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:11	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:12	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:13	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:14	163.3	9.4	13.46	1640.4	16191.8	7.5	0.028

Period Start:	Average MW_1 MW	Average NOx_low1 ppm	Average O2_1 %O2	Average Heat_G_751 mmBTU	Average GasFlow751 HSCFH	Average NOxCorrt_1 ppm	Average NOx#mm_751 #/M
06/06/2011 13:15	163.3	9.5	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:16	163.4	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:17	163.4	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:18	163.1	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:19	163.3	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:20	163.3	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:21	163.2	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:22	163.2	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:23	163.2	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:24	163.4	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:25	163.2	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:26	163.3	9.5	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:27	163.1	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:28	163.1	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:29	163.3	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:30	163.3	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:31	163.1	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:32	163.2	9.4	13.46	1640.4	16191.8	7.5	0.028
06/06/2011 13:33	163.2	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:34	162.9	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:35	163.2	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:36	163.2	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:37	163.2	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:38	163.2	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:39	163.3	9.5	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:40	162.7	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:41	162.5	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:42	163.1	9.5	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:43	162.7	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:44	163.3	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:45	162.9	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:46	163.3	9.5	13.45	1640.4	16191.8	7.5	0.028
06/06/2011 13:47	162.9	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:48	163.1	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:49	162.5	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:50	162.6	9.5	13.45	1640.4	16113.2	7.5	0.028
06/06/2011 13:51	163.1	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:52	162.9	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:53	163.3	9.4	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:54	162.6	9.5	13.46	1640.4	16113.2	7.5	0.028
06/06/2011 13:55	162.7	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:56	163.2	9.4	13.45	1640.4	16113.2	7.4	0.028

Period Start:	Average MW_1 MW	Average NOx_low1 ppm	Average O2_1 %O2	Average Heat_G_751 mmBTU	Average GasFlow751 HSCFH	Average NOxCorrt_1 ppm	Average NOx#mm_751 #/M
06/06/2011 13:57	163.1	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:58	162.9	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 13:59	162.7	9.4	13.45	1640.4	16113.2	7.4	0.028
06/06/2011 14:00	162.7	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:01	162.7	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:02	162.7	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:03	162.5	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:04	162.7	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:05	162.9	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:06	162.5	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:07	162.9	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:08	162.7	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:09	163.1	9.4	13.45	N/A	16113.2	7.4	N/A
06/06/2011 14:10	162.5	9.5	13.45	N/A	16113.2	7.5	N/A
06/06/2011 14:11	162.1	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:12	161.9	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:13	162.3	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:14	162.2	9.3	13.43	N/A	16113.2	7.3	N/A
06/06/2011 14:15	162.2	9.3	13.43	N/A	16113.2	7.3	N/A
06/06/2011 14:16	162.4	9.3	13.43	N/A	16113.2	7.3	N/A
06/06/2011 14:17	162.4	9.6	13.43	N/A	16113.2	7.6	N/A
06/06/2011 14:18	162.2	9.5	13.43	N/A	16113.2	7.5	N/A
06/06/2011 14:19	162.5	9.5	13.43	N/A	16113.2	7.5	N/A
06/06/2011 14:20	162.2	9.5	13.44	N/A	16113.2	7.5	N/A
06/06/2011 14:21	162.2	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:22	162.4	9.4	13.43	N/A	16113.2	7.4	N/A
06/06/2011 14:23	162.2	9.5	13.43	N/A	16113.2	7.5	N/A
06/06/2011 14:24	162.4	9.6	13.43	N/A	16113.2	7.6	N/A
06/06/2011 14:25	162.1	9.5	13.43	N/A	16113.2	7.5	N/A
06/06/2011 14:26	162.2	9.5	13.43	N/A	16113.2	7.5	N/A
06/06/2011 14:27	162.1	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:28	162.1	9.3	13.43	N/A	16113.2	7.3	N/A
06/06/2011 14:29	162.1	9.4	13.44	N/A	16113.2	7.4	N/A
06/06/2011 14:30	162.0	9.4	13.44	N/A	16113.2	7.4	N/A
Daily Average*	163.0	9.4	13.45	1642.3	16153.8	7.5	0.028
Maximum*	164.2	9.6	13.47	1644.2	16270.4	7.6	0.028
	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011
	12:06	14:24	12:57	12:59	12:52	14:24	13:59
Minimum*	161.9	9.3	13.43	1640.4	16113.2	7.3	0.028
	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011
	14:12	14:28	14:28	13:59	14:30	14:28	13:59

Average Values Report
Generated: 6/6/2011 14:35

Company: Vandolah Power Company
Plant: 2394 Vandolah Road
City/St: Wauchula, FL 33873
Source: stack2

Period Start: 6/6/2011 12:00
Period End: 6/6/2011 14:30
Validation Type: 1/1 min
Averaging Period: 1 min
Type: Block Avg

Period Start:	Average MW_2 MW	Average NOx_low2 ppm	Average O2_2 %O2	Average Heat_G_752 mmBTU	Average GasFlow752 HSCFH	Average NOxCorrt_2 ppm	Average NOx#mm_752 #/M
06/06/2011 12:00	101.4	20.0	13.39	1607.1	11868.7	77.4	0.036
06/06/2011 12:01	113.8	18.1	13.37	1607.1	12576.1	14.3	0.036
06/06/2011 12:02	127.0	11.8	17.00	1607.1	13362.2	27.7	0.036
06/06/2011 12:03	139.9	1.2	22.55	1607.1	14305.4	0.0	0.036
06/06/2011 12:04	154.0	0.9	22.56	1607.1	15405.8	0.0	0.036
06/06/2011 12:05	165.6	0.7	22.56	1607.1	16270.4	0.0	0.036
06/06/2011 12:06	166.8	0.6	22.56	1607.1	16349.0	0.0	0.036
06/06/2011 12:07	166.6	10.5	3.54	1607.1	16349.0	3.6	0.036
06/06/2011 12:08	166.4	17.9	0.03	1607.1	16270.4	5.1	0.036
06/06/2011 12:09	165.7	17.8	0.01	1607.1	16191.8	5.0	0.036
06/06/2011 12:10	165.5	17.8	0.00	1607.1	16113.2	5.0	0.036
06/06/2011 12:11	165.5	17.7	0.00	1607.1	16191.8	5.0	0.036
06/06/2011 12:12	165.3	20.0	-0.01	1607.1	16113.2	22.0	0.036
06/06/2011 12:13	164.8	20.0	-0.01	1607.1	16113.2	25.4	0.036
06/06/2011 12:14	164.9	20.0	-0.01	1607.1	16113.2	25.4	0.036
06/06/2011 12:15	165.0	20.0	-0.02	1607.1	16113.2	25.4	0.036
06/06/2011 12:16	164.6	20.0	6.22	1607.1	16113.2	36.2	0.036
06/06/2011 12:17	164.4	11.7	13.43	1607.1	16113.2	9.2	0.036
06/06/2011 12:18	164.2	11.4	13.46	1607.1	16113.2	9.0	0.036
06/06/2011 12:19	164.4	11.2	13.47	1607.1	16034.6	8.9	0.036
06/06/2011 12:20	163.9	11.2	13.48	1607.1	16034.6	8.9	0.036
06/06/2011 12:21	163.5	11.0	13.50	1607.1	16034.6	8.8	0.036
06/06/2011 12:22	163.5	10.9	13.50	1607.1	16034.6	8.7	0.036
06/06/2011 12:23	163.3	10.8	13.50	1607.1	16034.6	8.6	0.036
06/06/2011 12:24	163.3	10.7	13.51	1607.1	16034.6	8.5	0.036
06/06/2011 12:25	163.3	10.6	13.52	1607.1	16034.6	8.5	0.036
06/06/2011 12:26	163.3	10.4	13.53	1607.1	16034.6	8.3	0.036
06/06/2011 12:27	162.6	10.3	13.53	1607.1	15956.0	8.2	0.036
06/06/2011 12:28	163.0	10.2	13.54	1607.1	15956.0	8.2	0.036
06/06/2011 12:29	162.4	10.2	13.55	1607.1	15956.0	8.2	0.036
06/06/2011 12:30	162.2	10.1	13.56	1607.1	15956.0	8.1	0.036
06/06/2011 12:31	162.6	10.1	13.55	1607.1	15956.0	8.1	0.036
06/06/2011 12:32	162.2	10.1	13.56	1607.1	15956.0	8.1	0.036

Period Start:	Average MW_2 MW	Average NOx_low2 ppm	Average O2_2 %O2	Average Heat_G_752 mmBTU	Average GasFlow752 HSCFH	Average NOxCorrt_2 ppm	Average NOx#mm_752 #/M
06/06/2011 12:33	162.2	10.1	13.56	1607.1	15956.0	8.1	0.036
06/06/2011 12:34	162.2	10.1	13.55	1607.1	15956.0	8.1	0.036
06/06/2011 12:35	162.6	10.2	13.56	1607.1	16034.6	8.2	0.036
06/06/2011 12:36	162.6	10.1	13.55	1607.1	15956.0	8.1	0.036
06/06/2011 12:37	162.2	10.1	13.55	1607.1	15956.0	8.1	0.036
06/06/2011 12:38	162.4	10.1	13.55	1607.1	15956.0	8.1	0.036
06/06/2011 12:39	162.2	10.1	13.56	1607.1	15956.0	8.1	0.036
06/06/2011 12:40	162.4	10.0	13.56	1607.1	15956.0	8.0	0.036
06/06/2011 12:41	162.2	9.9	13.56	1607.1	15956.0	8.0	0.036
06/06/2011 12:42	162.2	9.8	13.56	1607.1	15956.0	7.9	0.036
06/06/2011 12:43	162.2	9.8	13.56	1607.1	15956.0	7.9	0.036
06/06/2011 12:44	162.0	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:45	162.0	9.7	13.56	1607.1	15877.4	7.8	0.036
06/06/2011 12:46	162.2	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:47	162.0	9.7	13.57	1607.1	15877.4	7.8	0.036
06/06/2011 12:48	162.2	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:49	162.2	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:50	162.2	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:51	162.2	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:52	163.1	9.8	13.57	1607.1	16034.6	7.9	0.036
06/06/2011 12:53	163.0	9.8	13.57	1607.1	16034.6	7.9	0.036
06/06/2011 12:54	163.3	9.9	13.57	1607.1	16034.6	8.0	0.036
06/06/2011 12:55	162.2	9.8	13.57	1607.1	15956.0	7.9	0.036
06/06/2011 12:56	162.8	9.8	13.57	1607.1	16034.6	7.9	0.036
06/06/2011 12:57	162.6	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:58	162.4	9.7	13.57	1607.1	15956.0	7.8	0.036
06/06/2011 12:59	162.2	9.6	13.58	1607.1	15956.0	7.7	0.036
06/06/2011 13:00	162.2	9.6	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:01	161.8	9.6	13.59	1616.1	15877.4	7.7	0.028
06/06/2011 13:02	162.2	9.5	13.59	1616.1	15877.4	7.7	0.028
06/06/2011 13:03	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:04	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:05	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:06	162.2	9.6	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:07	162.2	9.5	13.57	1616.1	15956.0	7.6	0.028
06/06/2011 13:08	161.8	9.6	13.57	1616.1	15877.4	7.7	0.028
06/06/2011 13:09	162.0	9.6	13.57	1616.1	15956.0	7.7	0.028
06/06/2011 13:10	162.2	9.6	13.57	1616.1	15956.0	7.7	0.028
06/06/2011 13:11	162.2	9.6	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:12	162.2	9.7	13.57	1616.1	15956.0	7.8	0.028
06/06/2011 13:13	162.2	9.7	13.57	1616.1	15956.0	7.8	0.028
06/06/2011 13:14	162.2	9.7	13.57	1616.1	15956.0	7.8	0.028

Period Start:	Average MW_2 MW	Average NOx_low2 ppm	Average O2_2 %O2	Average Heat_G_752 mmBTU	Average GasFlow752 HSCFH	Average NOxCorrt_2 ppm	Average NOx#mm_752 #/M
06/06/2011 13:15	162.2	9.6	13.57	1616.1	15956.0	7.7	0.028
06/06/2011 13:16	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:17	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:18	161.5	9.4	13.59	1616.1	15956.0	7.6	0.028
06/06/2011 13:19	161.2	9.4	13.59	1616.1	15877.4	7.6	0.028
06/06/2011 13:20	162.0	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:21	162.2	9.4	13.59	1616.1	15956.0	7.6	0.028
06/06/2011 13:22	162.2	9.5	13.59	1616.1	15956.0	7.7	0.028
06/06/2011 13:23	162.2	9.4	13.59	1616.1	15956.0	7.6	0.028
06/06/2011 13:24	162.2	9.4	13.59	1616.1	15956.0	7.6	0.028
06/06/2011 13:25	162.2	9.5	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:26	162.0	9.5	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:27	162.2	9.5	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:28	162.2	9.5	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:29	162.2	9.5	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:30	162.2	9.6	13.58	1616.1	15956.0	7.7	0.028
06/06/2011 13:31	162.0	9.5	13.59	1616.1	15877.4	7.7	0.028
06/06/2011 13:32	161.5	9.4	13.59	1616.1	15877.4	7.6	0.028
06/06/2011 13:33	161.5	9.4	13.59	1616.1	15877.4	7.6	0.028
06/06/2011 13:34	161.2	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:35	161.3	9.2	13.59	1616.1	15956.0	7.4	0.028
06/06/2011 13:36	161.5	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:37	161.8	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:38	161.3	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:39	161.9	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:40	161.2	9.4	13.58	1616.1	15798.8	7.6	0.028
06/06/2011 13:41	161.2	9.4	13.57	1616.1	15877.4	7.6	0.028
06/06/2011 13:42	161.2	9.3	13.58	1616.1	15877.4	7.5	0.028
06/06/2011 13:43	161.2	9.4	13.59	1616.1	15877.4	7.6	0.028
06/06/2011 13:44	161.1	9.4	13.58	1616.1	15877.4	7.6	0.028
06/06/2011 13:45	161.1	9.4	13.57	1616.1	15877.4	7.6	0.028
06/06/2011 13:46	161.2	9.4	13.57	1616.1	15798.8	7.6	0.028
06/06/2011 13:47	161.3	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:48	161.1	9.3	13.59	1616.1	15798.8	7.5	0.028
06/06/2011 13:49	160.9	9.3	13.58	1616.1	15877.4	7.5	0.028
06/06/2011 13:50	160.6	9.3	13.58	1616.1	15798.8	7.5	0.028
06/06/2011 13:51	161.1	9.2	13.59	1616.1	15877.4	7.4	0.028
06/06/2011 13:52	161.1	9.2	13.59	1616.1	15877.4	7.4	0.028
06/06/2011 13:53	161.1	9.2	13.59	1616.1	15877.4	7.4	0.028
06/06/2011 13:54	161.2	9.3	13.59	1616.1	15877.4	7.5	0.028
06/06/2011 13:55	161.1	9.3	13.58	1616.1	15798.8	7.5	0.028
06/06/2011 13:56	162.0	9.3	13.59	1616.1	15877.4	7.5	0.028

Period Start:	Average MW_2 MW	Average NOx_low2 ppm	Average O2_2 %O2	Average Heat_G_752 mmBTU	Average GasFlow752 HSCFH	Average NOxCorrt_2 ppm	Average NOx#mm_752 #/M
06/06/2011 13:57	161.3	9.3	13.58	1616.1	15877.4	7.5	0.028
06/06/2011 13:58	161.2	9.4	13.58	1616.1	15877.4	7.6	0.028
06/06/2011 13:59	161.1	9.4	13.58	1616.1	15877.4	7.6	0.028
06/06/2011 14:00	161.1	9.4	13.57	N/A	15877.4	7.6	N/A
06/06/2011 14:01	161.2	9.4	13.57	N/A	15877.4	7.6	N/A
06/06/2011 14:02	161.1	9.4	13.57	N/A	15798.8	7.6	N/A
06/06/2011 14:03	161.2	9.4	13.58	N/A	15877.4	7.6	N/A
06/06/2011 14:04	161.0	9.3	13.57	N/A	15798.8	7.5	N/A
06/06/2011 14:05	161.2	9.3	13.58	N/A	15798.8	7.5	N/A
06/06/2011 14:06	161.1	9.2	13.58	N/A	15877.4	7.4	N/A
06/06/2011 14:07	161.1	9.2	13.58	N/A	15877.4	7.4	N/A
06/06/2011 14:08	161.2	9.3	13.59	N/A	15877.4	7.5	N/A
06/06/2011 14:09	161.1	9.2	13.59	N/A	15877.4	7.4	N/A
06/06/2011 14:10	161.2	9.2	13.59	N/A	15877.4	7.4	N/A
06/06/2011 14:11	161.0	9.2	13.57	N/A	15877.4	7.4	N/A
06/06/2011 14:12	161.0	9.3	13.57	N/A	15798.8	7.5	N/A
06/06/2011 14:13	160.8	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:14	160.8	9.3	13.57	N/A	15877.4	7.5	N/A
06/06/2011 14:15	160.8	9.3	13.57	N/A	15877.4	7.5	N/A
06/06/2011 14:16	161.2	9.3	13.57	N/A	15877.4	7.5	N/A
06/06/2011 14:17	161.2	9.3	13.57	N/A	15798.8	7.5	N/A
06/06/2011 14:18	162.1	9.3	13.57	N/A	15877.4	7.5	N/A
06/06/2011 14:19	161.1	9.3	13.57	N/A	15798.8	7.5	N/A
06/06/2011 14:20	161.0	9.3	13.57	N/A	15877.4	7.5	N/A
06/06/2011 14:21	160.6	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:22	160.1	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:23	160.1	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:24	160.1	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:25	160.1	9.1	13.57	N/A	15720.2	7.3	N/A
06/06/2011 14:26	160.1	9.1	13.57	N/A	15798.8	7.3	N/A
06/06/2011 14:27	160.1	9.1	13.57	N/A	15877.4	7.3	N/A
06/06/2011 14:28	160.4	9.1	13.57	N/A	15798.8	7.3	N/A
06/06/2011 14:29	161.1	9.2	13.57	N/A	15798.8	7.4	N/A
06/06/2011 14:30	160.4	9.3	13.57	N/A	15798.8	7.5	N/A
Daily Average*	161.0	10.1	12.99	1611.6	15856.6	8.7	0.032
Maximum*	166.8	20.0	22.56	1616.1	16349.0	77.4	0.036
	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011
	12:06	12:16	12:06	13:59	12:07	12:00	12:59
Minimum*	101.4	0.6	-0.02	1607.1	11868.7	0.0	0.028
	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011	06/06/2011
	12:00	12:06	12:15	12:59	12:00	12:06	13:59

Vandolah Power Report For 6/1/2010 Thru 6/5/2011

Balance of Plant

Factored Starts Ratio 1.222

Online Time 3329.6

Fuel

FGT Natural Gas Used	94856.0	DTH
PGS Natural Gas Used	5382577.0	DTH
Heater Usage	8007.1	DTH
Liquid Fuel Total	1029400.3	Gal
Gross Heat Rate	10636.2	BTU/KW
Net Heat Rate	10793.0	BTU/KW
North F/O Tank	1883463	Gal
South F/O Tank	1702945	Gal

Electrical

Gross Megawatt Output	527632.6	MWH
Total Parasitic Load	13626.9	MWH
Net Megawatts Purchased	7390.7	MWH
Net Megawatts Produced	517946.4	MWH
Net VARs Produced	45728.2	MVARH
Net VARs Consumed	4370.9	MVARH
Total Requested Energy	519361.0	MWH
Net Test Energy Produced	2760.5	MWH

Water

North Well	3054900	Gal
South Well	2398000	Gal
Potable Well	159700	Gal
Evap Pond Inlet	1887500	Gal
Service Tank	39	Feet
Demin Tank	33.42	Feet

Unit 1

Fired Hours	920.0	Hours
Gas Fired Hours	900.2	Hours
Oil Fired Hours	19.8	Hours
Forced Outage	232.4	Hours
Scheduled Outage	184.4	Hours
Starting Reliability	100.0	

Attempted Starts	86
Successful Starts	86
Fired Aborts	3
Unloaded Trips	2
Loaded Trips	0
Dispatch Starts	83

Fuel Gas Flow	1484114.5	mmBTU
Fuel Oil Flow	34441.9	mmBTU
Megawatts	144354.0	MWH
Megavars	30479.3	MVARH
Gross Heat Rate	10519.7	BTU/KWH
Factored Starts	88.50	

Unit 2

Fired Hours	574.4	Hours
Gas Fired Hours	567.6	Hours
Oil Fired Hours	6.8	Hours
Forced Outage	358.8	Hours
Scheduled Outage	317.0	Hours
Starting Reliability	97.2	

Attempted Starts	71
Successful Starts	69
Fired Aborts	4
Unloaded Trips	3
Loaded Trips	6
Dispatch Starts	66

Fuel Gas Flow	911587.5	mmBTU
Fuel Oil Flow	10976.2	mmBTU
Megawatts	87544.8	MWH
Megavars	16516.9	MVARH
Gross Heat Rate	10538.2	BTU/KWH
Factored Starts	95.34	

Unit 3

Fired Hours	944.7	Hours
Gas Fired Hours	914.0	Hours
Oil Fired Hours	30.7	Hours
Forced Outage	47.6	Hours
Scheduled Outage	399.4	Hours
Starting Reliability	100.0	

Attempted Starts	101
Successful Starts	101
Fired Aborts	3
Unloaded Trips	2
Loaded Trips	2
Dispatch Starts	97

Fuel Gas Flow	1479877.2	mmBTU
Fuel Oil Flow	52528.6	mmBTU
Megawatts	144316.3	MWH
Megavars	32806.2	MVARH
Gross Heat Rate	10618.4	BTU/KWH
Factored Starts	118.36	

Unit 4

Fired Hours	974.2	Hours
Gas Fired Hours	946.2	Hours
Oil Fired Hours	28.0	Hours
Forced Outage	119.6	Hours
Scheduled Outage	303.0	Hours
Starting Reliability	96.4	

Attempted Starts	111
Successful Starts	107
Fired Aborts	5
Unloaded Trips	4
Loaded Trips	2
Dispatch Starts	100

Fuel Gas Flow	1548433.6	mmBTU
Fuel Oil Flow	44619.1	mmBTU
Megawatts	151417.6	MWH
Megavars	27445.4	MVARH
Gross Heat Rate	10520.9	BTU/KWH
Factored Starts	120.73	



Report of Analysis

Client: Vandolah Power Company, LLC	Client Reference Number:
Job Location: Tampa, FL, USA	PO#
Our Reference Number: US470-0004281	

Sample ID: 2011-TAMP-000129-001	Date Taken: 26-February-2011
Sample Designated As: Diesel	Date Submitted: 29-March-2011
Vessel/Location: Vandolah Power, Wauchula, FL	Date Tested: 30-March-2011
Representing: Tank A	Drawn By: Client

Method	Test	Result	Units
ASTM D2274	Oxidation Stability of Distillate Fuels (Accelerated Method)		
	Total Insolubles	0.5	mg/100ml
ASTM D4294	Sulfur Content in Petroleum Products by ED-XRF		
	¹ Sulfur Content	0.0140	Wt %
ASTM D93 - IP 34	Pensky-Martens Closed Cup Flash Point		
	Procedure Used	A	
	Corrected Flash Point	156	°F
ASTM D482	Ash from Petroleum Products		
	Ash	0.001	Wt %
ASTM D240	Heat of Combustion by Bomb Calorimeter		
	Gross Heat of Combustion	19127	BTU/lb
	Gross Heat of Combustion (Calculated)	133258	BTU/gal
ITM 1037	Biologicals		
	Bacteria	Not Detected	
	Fungus	Not Detected	

¹ Out of Scope of the Method

Signed: _____
Intertek
Daniel Thompson, Laboratory Manager

Date: _____

Client: Vandolah Power Company, LLC
Job Location: Tampa, FL, USA
Vessel: Vandolah Power; Wauchula, FL
Our Reference Number: US470-0004204
Lab Reference Number: 2011-TAMP-000039

Client Reference Number:
PO#

Diesel Tank A

Sample ID: 2011-TAMP-000039-001 **Date Taken:** 8-Jan-2011

Method	Test	Result	Unit
ASTM D2274	Total Insolubles	0.6	mg/100ml
ASTM D4294	Sulfur Content	0.0152	Wt %
ASTM D93	Flash Point	156	°F
ASTM D482	Ash Content	<0.001	Wt %
ASTM D240	Gross Heat of Combustion	137687	BTU/lb
ITM 1037	Bacteria	Not Detected	
ITM 1037	Fungus	Not Detected	

Diesel Tank B

Sample ID: 2011-TAMP-000039-002 **Date Taken:** 8-Jan-2011

Method	Test	Result	Unit
ASTM D2274	Total Insolubles	0.5	mg/100ml
ASTM D4294	Sulfur Content	0.0087	Wt %
ASTM D93	Flash Point	162	°F
ASTM D482	Ash Content	<0.001	Wt %
ASTM D240	Gross Heat of Combustion	138447	BTU/lb
ITM 1037	Bacteria	Not Detected	
ITM 1037	Fungus	Not Detected	

¹ Outside Scope of Method

Signed: _____

Intertek
Daniel Thompson, Laboratory Manager

Date: _____