

Quality Assurance Activities
Calibration Error, Bias, and Drift Checks

Unit 1

Linearity Check	NO _x -B	CO-A	O ₂ -A	CO ₂ -A
Analyzer Range (ppmv), O ₂ & CO ₂ in % vol	19.94	9.65	21.96	8.45
Low Level Certified Value (ppm or % vol)	na	na	na	na
Mid Level Certified Value (ppm or % vol)	9.98	5.11	12.05	4.44
High Level Certified Value (ppm or % vol)	19.94	9.65	21.96	8.45
Zero Target (% Span)	0.0	0.0	0.0	0.0
Low Level Target (% Span)	na	na	na	na
Mid Level Target (% Span)	50.1	53.0	54.9	52.5
High Level Target (% Span)	100.0	100.0	100.0	100.0
Zero Observed (% Span)	0.0	0.0	0.0	0.0
Low Level Observed (% Span)	na	na	na	na
Mid Level Observed (% Span)	49.5	52.7	54.7	51.8
High Level Observed (% Span)	100.0	100.0	100.0	100.1
Zero Observed (ppm or % vol)	0.00	0.00	0.00	0.00
Low Level Observed (ppm or % vol)	na	na	na	na
Mid Level Observed (ppm or % vol)	9.88	5.09	12.02	4.38
High Level Observed (ppm or % vol)	19.94	9.65	21.95	8.46
% Difference From Zero to Target	0.0	0.0	0.0	0.0
% Difference From Low to Target	na	na	na	na
% Difference From Mid to Target	-0.5	-0.2	-0.1	-0.7
% Difference From High to Target	0.0	0.0	0.0	0.1
EPA Allowable % Difference from Target	±2% Span	±2% Span	±2% Span	±2% Span
Run U1-Stratification	NO _x -B	CO-A	O ₂ -A	CO ₂ -A
Analyzer Range (ppm), O ₂ & CO ₂ in %	19.94	9.65	21.96	8.45
Calibration Gas Certified Value (ppm or %)	9.98	5.11	21.96	4.44
Target Calibration Gas (% Span)	50.1	53.0	100.0	52.5
Actual Zero Gas from Direct (% Span)	0.0	0.0	0.0	0.0
Actual Calibration Gas from Direct (% Span)	49.5	52.7	100.0	51.8
Initial Readings				
Zero Gas (% Span)	0.2	0.0	0.3	0.2
Calibration Gas (% Span)	48.4	52.4	99.7	51.8
Zero Gas (ppmv)	0.04	0.00	0.07	0.02
Calibration Gas (ppmv)	9.66	5.06	21.90	4.38
Final Readings				
Zero Gas (% Span)	1.7	0.0	0.1	0.5
Calibration Gas (% Span)	48.7	52.6	98.6	51.6
Zero Gas (ppmv)	0.33	0.00	0.03	0.04
Calibration Gas (ppmv)	9.72	5.08	21.65	4.36
Bias and Drift Calculations				
Zero Bias (% Span) (Run-Direct Cal) ≤5%	1.7	0.0	0.1	0.5
Calibration Bias (% Span) ≤5%	-0.8	-0.1	-1.4	-0.2
Zero Drift (% Span) (Run-Run) ≤2 or 3%	-1.5	0.0	0.2	-0.2
Calibration Drift (% Span) ≤2 or 3%	-0.3	-0.2	1.1	0.2
Run Results				
Raw Results (% Span)	47.6	4.9	64.4	44.7
Raw Results (ppmv or % vol)	9.49	0.47	14.14	3.78
Corrected Results (ppmv or % vol)	9.77	0.47	14.24	3.83

Quality Assurance Activities
Calibration Error, Bias, and Drift Checks

Unit 1

Linearity Check	NO _x -B	CO-A	O ₂ -A	CO ₂ -A
Analyzer Range (ppmv), O ₂ & CO ₂ in % vol	19.94	9.65	21.96	8.45
Low Level Certified Value (ppm or % vol)	na	na	na	na
Mid Level Certified Value (ppm or % vol)	9.98	5.11	12.05	4.44
High Level Certified Value (ppm or % vol)	19.94	9.65	21.96	8.45
Zero Target (% Span)	0.0	0.0	0.0	0.0
Low Level Target (% Span)	na	na	na	na
Mid Level Target (% Span)	50.1	53.0	54.9	52.5
High Level Target (% Span)	100.0	100.0	100.0	100.0
Zero Observed (% Span)	0.2	0.0	0.0	0.0
Low Level Observed (% Span)	na	na	na	na
Mid Level Observed (% Span)	50.7	52.3	55.0	52.1
High Level Observed (% Span)	101.0	99.5	100.1	101.1
Zero Observed (ppm or % vol)	0.04	0.00	0.00	0.00
Low Level Observed (ppm or % vol)	na	na	na	na
Mid Level Observed (ppm or % vol)	10.10	5.05	12.07	4.40
High Level Observed (ppm or % vol)	20.14	9.60	21.98	8.54
% Difference From Zero to Target	0.2	0.0	0.0	0.0
% Difference From Low to Target	na	na	na	na
% Difference From Mid to Target	0.6	-0.6	0.1	-0.5
% Difference From High to Target	1.0	-0.5	0.1	1.1
EPA Allowable % Difference from Target	±2% Span	±2% Span	±2% Span	±2% Span
Run U1-C-1A/RA-1	NO_x-B	CO-A	O₂-A	CO₂-A
Analyzer Range (ppm), O ₂ & CO ₂ in %	18.94	9.65	21.96	8.45
Calibration Gas Certified Value (ppm or %)	9.98	5.11	21.96	4.44
Target Calibration Gas (% Span)	52.7	53.0	100.0	52.5
Actual Zero Gas from Direct (% Span)	0.2	0.0	0.0	0.0
Actual Calibration Gas from Direct (% Span)	50.7	52.3	100.1	52.1
Initial Readings				
Zero Gas (% Span)	0.5	0.9	0.1	0.2
Calibration Gas (% Span)	51.5	54.3	98.4	51.8
Zero Gas (ppmv)	0.09	0.09	0.03	0.02
Calibration Gas (ppmv)	9.75	5.24	21.60	4.38
Final Readings				
Zero Gas (% Span)	0.6	0.8	0.1	0.2
Calibration Gas (% Span)	51.7	54.1	98.1	51.6
Zero Gas (ppmv)	0.11	0.08	0.03	0.02
Calibration Gas (ppmv)	9.79	5.22	21.55	4.36
Bias and Drift Calculations				
Zero Bias (% Span) (Run-Direct Cal) ≤5%	0.4	0.8	0.1	0.2
Calibration Bias (% Span) ≤5%	1.0	1.8	-2.0	-0.5
Zero Drift (% Span) (Run-Run) ≤2 or 3%	-0.1	0.1	0.0	0.0
Calibration Drift (% Span) ≤2 or 3%	-0.2	0.2	0.2	0.2
Run Results				
Raw Results (% Span)	50.6	1.9	62.9	45.7
Raw Results (ppmv or % vol)	9.58	0.18	13.82	3.86
Corrected Results (ppmv or % vol)	9.78	0.09	14.06	3.92

Certificate of Analysis

Vessel / Shore Tank :	Seminole Inventory	Sample Submitted By :	Seminole Electric
Product :	# 2 Diesel Fuel Oil	Analysis Performed By :	IAC Tampa
Client Reference :	NONE	Date Sampled :	23-Aug-2011
Terminal / Port / Office :	Midulla Generating Station	Date Reported :	30-Aug-2011
Job ID :	TA17142	Submission ID :	2011-018-00433
Sample Details :			
Comments :			


		08.23.11	06.25.11	07.25.11	07.26.11
Sample Description		CT-1	CT1	CT 1 FO Run	CT 2 FO Run
Sample Number		00433-001	00433-002	00433-003	00433-004
Method	Test	Result	Result	Result	Result
ASTM D4052	API Gravity	36.1	36.1	36.1	36.1
	Density at 15°C , kg/m3	843.9	844.0	844.0	844.0
ASTM D240	Gross Heat of Combustion , BTU/lb	19520	19788	19428	19689
	Unit Conversion , BTU/gal	137226	139110	136579	138414
	Net Heat of Combustion , BTU/lb	18306	18556	18196	18457
	Net Heat of Combustion Unit Conversion	128691	130449	127918	129753
^{IAC} ASTM D5291 Method A	Hydrogen , mass %	13.3	13.5	13.5	13.5
ASTM D7039-07 (EPA Correlated)	Sulfur Content , ppm (mg/kg) / mass %	189 / 0.0189	79.9 / 0.0080	79.6 / 0.0080	80.7 / 0.0081

		08.18.11	08.18.11	08.19.11	07.21.11
Sample Description		4A	4B	5A	6B
Sample Number		00433-005	00433-006	00433-007	00433-008
Method	Test	Result	Result	Result	Result
ASTM D4052	API Gravity	36.1	36.1	36.1	36.1
	Density at 15°C , kg/m3	844.0	844.0	843.8	844.0
ASTM D240	Gross Heat of Combustion , BTU/lb	19695	19679	19166	19351
	Unit Conversion , BTU/gal	138456	138343	134737	136038
	Net Heat of Combustion , BTU/lb	18463	18466	17943	18128
	Net Heat of Combustion Unit Conversion	129795	129746	126139	127440
^{IAC} ASTM D5291 Method A	Hydrogen , mass %	13.5	13.4	13.4	13.4
ASTM D7039-07 (EPA Correlated)	Sulfur Content , ppm (mg/kg) / mass %	67.0 / 0.0087	63.5 / 0.0084	168 / 0.0168	86.7 / 0.0087

		08.18.11	08.19.11	07.21.11	08.18.11
Sample Description		6B	7B	8A	8A
Sample Number		00433-009	00433-010	00433-011	00433-012
Method	Test	Result	Result	Result	Result
ASTM D4052	API Gravity	36.1	36.1	36.1	36.1
	Density at 15°C , kg/m3	844.0	843.8	844.0	844.0
ASTM D240	Gross Heat of Combustion , BTU/lb	19559	19303	19701	19684
	Unit Conversion , BTU/gal	137500	135700	138498	138379
	Net Heat of Combustion , BTU/lb	16322	18090	18479	18462
	Net Heat of Combustion Unit Conversion	126804	127173	129907	129785
^{IAC} ASTM D5291 Method A	Hydrogen , mass %	13.5	13.3	13.4	13.4
ASTM D7039-07 (EPA Correlated)	Sulfur Content , ppm (mg/kg) / mass %	82.2 / 0.0082	164 / 0.0164	86.7 / 0.0087	84.6 / 0.0085

^{IAC} Analysis performed by alternative IAC laboratory.

For Inspectorate:



Craig Spears, Laboratory Manager

Average Values Report
Generated: 9/27/2011 10:21

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/01/2011 00:00	1.00	1087	0.00	N/A	1087	0.00	N/A	0.00	N/A	N/A
08/01/2011 01:00	1.00	1085	0.00	N/A	1085	0.00	N/A	0.00	N/A	N/A
08/01/2011 02:00	1.00	1086	0.00	N/A	1086	0.00	N/A	0.00	N/A	N/A
08/01/2011 03:00	1.00	1085	0.00	N/A	1085	0.00	N/A	0.00	N/A	N/A
08/01/2011 04:00	1.00	1130	0.00	N/A	1130	0.00	N/A	0.00	N/A	N/A
08/01/2011 05:00	1.00	1175	0.00	N/A	1175	0.00	N/A	0.00	N/A	N/A
08/01/2011 06:00	1.00	1245	0.00	N/A	1245	0.00	N/A	0.00	N/A	N/A
08/01/2011 07:00	1.00	1275	0.00	N/A	1275	0.00	N/A	0.00	N/A	N/A
08/01/2011 08:00	1.00	1408	0.00	N/A	1408	0.00	N/A	0.00	N/A	N/A
08/01/2011 09:00	1.00	1737	0.00	N/A	1737	0.00	N/A	0.00	N/A	N/A
08/01/2011 10:00	1.00	1722	0.00	N/A	1722	0.00	N/A	0.00	N/A	N/A
08/01/2011 11:00	1.00	1711	0.00	N/A	1711	0.00	N/A	0.00	N/A	N/A
08/01/2011 12:00	1.00	1703	0.00	N/A	1703	0.00	N/A	0.00	N/A	N/A
08/01/2011 13:00	1.00	1699	0.00	N/A	1699	0.00	N/A	0.00	N/A	N/A
08/01/2011 14:00	1.00	1623	0.00	N/A	1623	0.00	N/A	0.00	N/A	N/A
08/01/2011 15:00	1.00	1716	0.00	N/A	1716	0.00	N/A	0.00	N/A	N/A
08/01/2011 16:00	1.00	1472	0.00	N/A	1472	0.00	N/A	0.00	N/A	N/A
08/01/2011 17:00	1.00	907	0.00	N/A	907	0.00	N/A	0.00	N/A	N/A
08/01/2011 18:00	1.00	988	0.00	N/A	988	0.00	N/A	0.00	N/A	N/A
08/01/2011 19:00	1.00	1074	0.00	N/A	1074	0.00	N/A	0.00	N/A	N/A
08/01/2011 20:00	1.00	1074	0.00	N/A	1074	0.00	N/A	0.00	N/A	N/A
08/01/2011 21:00	1.00	1074	0.00	N/A	1074	0.00	N/A	0.00	N/A	N/A
08/01/2011 22:00	1.00	1077	0.00	N/A	1077	0.00	N/A	0.00	N/A	N/A
08/01/2011 23:00	1.00	1083	0.00	N/A	1083	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1302	0.00	N/A	1302	0.00	N/A	0.00	N/A	N/A
Maximum*	1.00	1737	0.00	N/A	1737	0.00	N/A	0.00	N/A	N/A
	08/01/2011	08/01/2011			08/01/2011					
	23:00	9:00			9:00					
Minimum*	1.00	907	0.00	N/A	907	0.00	N/A	0.00	N/A	N/A
	08/01/2011	08/01/2011	08/01/2011		08/01/2011	08/01/2011		08/01/2011		
	23:00	17:00	23:00		17:00	23:00		23:00		
Total*	24.00	31236	0.00	0	31236	0.00	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:21

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/02/2011 00:00	1.00	1082	0.00	N/A	1082	0.00	N/A	0.00	N/A	N/A
08/02/2011 01:00	1.00	1082	0.00	N/A	1082	0.00	N/A	0.00	N/A	N/A
08/02/2011 02:00	1.00	1082	0.00	N/A	1082	N/A	N/A	N/A	N/A	N/A
08/02/2011 03:00	1.00	1081	0.00	N/A	1081	N/A	N/A	N/A	N/A	N/A
08/02/2011 04:00	1.00	1196	0.00	N/A	1196	0.00	N/A	0.00	N/A	N/A
08/02/2011 05:00	1.00	1227	0.00	N/A	1227	0.00	N/A	0.00	N/A	N/A
08/02/2011 06:00	1.00	1548	0.00	N/A	1548	0.00	N/A	0.00	N/A	N/A
08/02/2011 07:00	1.00	1775	0.00	N/A	1775	0.00	N/A	0.00	N/A	N/A
08/02/2011 08:00	1.00	1760	0.00	N/A	1760	0.00	N/A	0.00	N/A	N/A
08/02/2011 09:00	1.00	1738	0.00	N/A	1738	0.35	N/A	0.00	N/A	N/A
08/02/2011 10:00	1.00	1727	0.00	N/A	1727	0.32	N/A	0.00	N/A	N/A
08/02/2011 11:00	1.00	1528	0.00	N/A	1528	1.00	N/A	0.00	N/A	N/A
08/02/2011 12:00	1.00	1231	0.00	N/A	1231	1.00	N/A	0.00	N/A	N/A
08/02/2011 13:00	1.00	1229	0.00	N/A	1229	1.00	N/A	0.00	N/A	N/A
08/02/2011 14:00	1.00	1230	0.00	N/A	1230	1.00	N/A	0.00	N/A	N/A
08/02/2011 15:00	1.00	1231	0.00	N/A	1231	1.00	N/A	0.00	N/A	N/A
08/02/2011 16:00	1.00	1232	0.00	N/A	1232	1.00	N/A	0.00	N/A	N/A
08/02/2011 17:00	1.00	1231	0.00	N/A	1231	1.00	N/A	0.00	N/A	N/A
08/02/2011 18:00	1.00	1533	0.00	N/A	1533	0.23	N/A	0.00	N/A	N/A
08/02/2011 19:00	1.00	1742	0.00	N/A	1742	0.00	N/A	0.00	N/A	N/A
08/02/2011 20:00	1.00	1743	0.00	N/A	1743	0.00	N/A	0.00	N/A	N/A
08/02/2011 21:00	1.00	1743	0.00	N/A	1743	0.00	N/A	0.00	N/A	N/A
08/02/2011 22:00	1.00	1667	0.00	N/A	1667	0.00	N/A	0.00	N/A	N/A
08/02/2011 23:00	1.00	1227	0.00	N/A	1227	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1411	0.00	N/A	1411	0.36	N/A	0.00	N/A	N/A
Maximum*	1.00	1775	0.00	N/A	1775	1.00	N/A	0.00	N/A	N/A
	08/02/2011	08/02/2011			08/02/2011	08/02/2011				
	23:00	7:00			7:00	17:00				
Minimum*	1.00	1081	0.00	N/A	1081	0.00	N/A	0.00	N/A	N/A
	08/02/2011	08/02/2011	08/02/2011		08/02/2011	08/02/2011		08/02/2011		
	23:00	3:00	23:00		3:00	23:00		23:00		
Total*	24.00	33865	0.00	0	33865	7.90	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:21

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/03/2011 00:00	1.00	1103	0.00	N/A	1103	0.00	N/A	0.00	N/A	N/A
08/03/2011 01:00	1.00	1073	0.00	N/A	1073	0.00	N/A	0.00	N/A	N/A
08/03/2011 02:00	1.00	1073	0.00	N/A	1073	0.00	N/A	0.00	N/A	N/A
08/03/2011 03:00	1.00	1087	0.00	N/A	1087	0.00	N/A	0.00	N/A	N/A
08/03/2011 04:00	1.00	1197	0.00	N/A	1197	0.43	N/A	0.00	N/A	N/A
08/03/2011 05:00	1.00	1353	0.00	N/A	1353	1.00	N/A	0.00	N/A	N/A
08/03/2011 06:00	1.00	1232	0.00	N/A	1232	1.00	N/A	0.00	N/A	N/A
08/03/2011 07:00	1.00	1230	0.00	N/A	1230	1.00	N/A	0.00	N/A	N/A
08/03/2011 08:00	1.00	1231	0.00	N/A	1231	1.00	N/A	0.00	N/A	N/A
08/03/2011 09:00	1.00	1225	0.00	N/A	1225	1.00	N/A	0.00	N/A	N/A
08/03/2011 10:00	1.00	1224	0.00	N/A	1224	1.00	N/A	0.00	N/A	N/A
08/03/2011 11:00	1.00	1224	0.00	N/A	1224	1.00	N/A	0.00	N/A	N/A
08/03/2011 12:00	1.00	1217	0.00	N/A	1217	1.00	N/A	0.00	N/A	N/A
08/03/2011 13:00	1.00	1428	0.00	N/A	1428	1.00	N/A	0.00	N/A	N/A
08/03/2011 14:00	1.00	1712	0.00	N/A	1712	1.00	N/A	0.00	N/A	N/A
08/03/2011 15:00	1.00	1722	0.00	N/A	1722	1.00	N/A	0.00	N/A	N/A
08/03/2011 16:00	1.00	1337	0.00	N/A	1337	1.00	N/A	0.00	N/A	N/A
08/03/2011 17:00	1.00	1060	0.00	N/A	1060	1.00	N/A	0.00	N/A	N/A
08/03/2011 18:00	1.00	1077	0.00	N/A	1077	1.00	N/A	0.00	N/A	N/A
08/03/2011 19:00	1.00	1077	0.00	N/A	1077	1.00	N/A	0.00	N/A	N/A
08/03/2011 20:00	1.00	1077	0.00	N/A	1077	1.00	N/A	0.00	N/A	N/A
08/03/2011 21:00	1.00	1078	0.00	N/A	1078	1.00	N/A	0.00	N/A	N/A
08/03/2011 22:00	1.00	1139	0.00	N/A	1139	1.00	N/A	0.00	N/A	N/A
08/03/2011 23:00	1.00	1336	0.00	N/A	1336	1.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1230	0.00	N/A	1230	0.81	N/A	0.00	N/A	N/A
Maximum*	1.00	1722	0.00	N/A	1722	1.00	N/A	0.00	N/A	N/A
	08/03/2011	08/03/2011			08/03/2011	08/03/2011				
	23:00	15:00			15:00	23:00				
Minimum*	1.00	1060	0.00	N/A	1060	0.00	N/A	0.00	N/A	N/A
	08/03/2011	08/03/2011	08/03/2011		08/03/2011	08/03/2011		08/03/2011		
	23:00	17:00	23:00		17:00	3:00		23:00		
Total*	24.00	29512	0.00	0	29512	19.43	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/04/2011 00:00	1.00	1353	0.00	N/A	1353	1.00	N/A	0.00	N/A	N/A
08/04/2011 01:00	1.00	1381	0.00	N/A	1381	1.00	N/A	0.00	N/A	N/A
08/04/2011 02:00	1.00	1279	0.00	N/A	1279	1.00	N/A	0.00	N/A	N/A
08/04/2011 03:00	1.00	1217	0.00	N/A	1217	1.00	N/A	0.00	N/A	N/A
08/04/2011 04:00	1.00	1283	0.00	N/A	1283	1.00	N/A	0.00	N/A	N/A
08/04/2011 05:00	1.00	1484	0.00	N/A	1484	1.00	N/A	0.00	N/A	N/A
08/04/2011 06:00	1.00	1625	0.00	N/A	1625	1.00	N/A	0.00	N/A	N/A
08/04/2011 07:00	1.00	1692	0.00	N/A	1692	1.00	N/A	0.00	N/A	N/A
08/04/2011 08:00	1.00	1690	0.00	N/A	1690	1.00	N/A	0.00	N/A	N/A
08/04/2011 09:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/04/2011 10:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/04/2011 11:00	1.00	1712	0.00	N/A	1712	1.00	N/A	0.00	N/A	N/A
08/04/2011 12:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/04/2011 13:00	1.00	1710	0.00	N/A	1710	1.00	N/A	0.00	N/A	N/A
08/04/2011 14:00	1.00	1704	0.00	N/A	1704	1.00	N/A	0.00	N/A	N/A
08/04/2011 15:00	1.00	1705	0.00	N/A	1705	1.00	N/A	0.00	N/A	N/A
08/04/2011 16:00	1.00	1705	0.00	N/A	1705	1.00	N/A	0.00	N/A	N/A
08/04/2011 17:00	1.00	1709	0.00	N/A	1709	1.00	N/A	0.00	N/A	N/A
08/04/2011 18:00	1.00	1721	0.00	N/A	1721	1.00	N/A	0.00	N/A	N/A
08/04/2011 19:00	1.00	1726	0.00	N/A	1726	1.00	N/A	0.00	N/A	N/A
08/04/2011 20:00	1.00	1725	0.00	N/A	1725	1.00	N/A	0.00	N/A	N/A
08/04/2011 21:00	1.00	1727	0.00	N/A	1727	1.00	N/A	0.00	N/A	N/A
08/04/2011 22:00	1.00	1728	0.00	N/A	1728	1.00	N/A	0.00	N/A	N/A
08/04/2011 23:00	1.00	1634	0.00	N/A	1634	1.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1611	0.00	N/A	1611	1.00	N/A	0.00	N/A	N/A
Maximum*	1.00	1728	0.00	N/A	1728	1.00	N/A	0.00	N/A	N/A
	08/04/2011	08/04/2011			08/04/2011	08/04/2011				
	23:00	22:00			22:00	23:00				
Minimum*	1.00	1217	0.00	N/A	1217	1.00	N/A	0.00	N/A	N/A
	08/04/2011	08/04/2011	08/04/2011		08/04/2011	08/04/2011		08/04/2011		
	23:00	3:00	23:00		3:00	23:00		23:00		
Total*	24.00	38653	0.00	0	38653	24.00	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/05/2011 00:00	1.00	1538	0.00	N/A	1538	1.00	N/A	0.00	N/A	N/A
08/05/2011 01:00	1.00	1429	0.00	N/A	1429	1.00	N/A	0.00	N/A	N/A
08/05/2011 02:00	1.00	1305	0.00	N/A	1305	1.00	N/A	0.00	N/A	N/A
08/05/2011 03:00	1.00	1276	0.00	N/A	1276	1.00	N/A	0.00	N/A	N/A
08/05/2011 04:00	1.00	1337	0.00	N/A	1337	1.00	N/A	0.00	N/A	N/A
08/05/2011 05:00	1.00	1374	0.00	N/A	1374	1.00	N/A	0.00	N/A	N/A
08/05/2011 06:00	1.00	1245	0.00	N/A	1245	1.00	N/A	0.00	N/A	N/A
08/05/2011 07:00	1.00	1440	0.00	N/A	1440	1.00	N/A	0.00	N/A	N/A
08/05/2011 08:00	1.00	1710	0.00	N/A	1710	1.00	N/A	0.00	N/A	N/A
08/05/2011 09:00	1.00	1703	0.00	N/A	1703	1.00	N/A	0.00	N/A	N/A
08/05/2011 10:00	1.00	1701	0.00	N/A	1701	1.00	N/A	0.00	N/A	N/A
08/05/2011 11:00	1.00	1700	0.00	N/A	1700	1.00	N/A	0.00	N/A	N/A
08/05/2011 12:00	1.00	1697	0.00	N/A	1697	1.00	N/A	0.00	N/A	N/A
08/05/2011 13:00	1.00	1693	0.00	N/A	1693	1.00	N/A	0.00	N/A	N/A
08/05/2011 14:00	1.00	1702	0.00	N/A	1702	1.00	N/A	0.00	N/A	N/A
08/05/2011 15:00	1.00	1704	0.00	N/A	1704	1.00	N/A	0.00	N/A	N/A
08/05/2011 16:00	1.00	1709	0.00	N/A	1709	1.00	N/A	0.00	N/A	N/A
08/05/2011 17:00	1.00	1719	0.00	N/A	1719	1.00	N/A	0.00	N/A	N/A
08/05/2011 18:00	1.00	1720	0.00	N/A	1720	1.00	N/A	0.00	N/A	N/A
08/05/2011 19:00	1.00	1720	0.00	N/A	1720	1.00	N/A	0.00	N/A	N/A
08/05/2011 20:00	1.00	1723	0.00	N/A	1723	1.00	N/A	0.00	N/A	N/A
08/05/2011 21:00	1.00	1724	0.00	N/A	1724	1.00	N/A	0.00	N/A	N/A
08/05/2011 22:00	1.00	1688	0.00	N/A	1688	1.00	N/A	0.00	N/A	N/A
08/05/2011 23:00	1.00	1585	0.00	N/A	1585	1.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1589	0.00	N/A	1589	1.00	N/A	0.00	N/A	N/A
Maximum*	1.00	1724	0.00	N/A	1724	1.00	N/A	0.00	N/A	N/A
	08/05/2011	08/05/2011			08/05/2011	08/05/2011				
	23:00	21:00			21:00	23:00				
Minimum*	1.00	1245	0.00	N/A	1245	1.00	N/A	0.00	N/A	N/A
	08/05/2011	08/05/2011	08/05/2011		08/05/2011	08/05/2011		08/05/2011		
	23:00	6:00	23:00		6:00	23:00		23:00		
Total*	24.00	38142	0.00	0	38142	24.00	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/06/2011 00:00	1.00	1465	0.00	N/A	1465	1.00	N/A	0.00	N/A	N/A
08/06/2011 01:00	1.00	1306	0.00	N/A	1306	1.00	N/A	0.00	N/A	N/A
08/06/2011 02:00	1.00	1259	0.00	N/A	1259	1.00	N/A	0.00	N/A	N/A
08/06/2011 03:00	1.00	1123	0.00	N/A	1123	1.00	N/A	0.00	N/A	N/A
08/06/2011 04:00	1.00	1099	0.00	N/A	1099	1.00	N/A	0.00	N/A	N/A
08/06/2011 05:00	1.00	1103	0.00	N/A	1103	1.00	N/A	0.00	N/A	N/A
08/06/2011 06:00	1.00	1400	0.00	N/A	1400	1.00	N/A	0.00	N/A	N/A
08/06/2011 07:00	1.00	1334	0.00	N/A	1334	1.00	N/A	0.00	N/A	N/A
08/06/2011 08:00	1.00	1474	0.00	N/A	1474	1.00	N/A	0.00	N/A	N/A
08/06/2011 09:00	1.00	1378	0.00	N/A	1378	1.00	N/A	0.00	N/A	N/A
08/06/2011 10:00	1.00	1630	0.00	N/A	1630	1.00	N/A	0.00	N/A	N/A
08/06/2011 11:00	1.00	1476	0.00	N/A	1476	1.00	N/A	0.00	N/A	N/A
08/06/2011 12:00	1.00	1463	0.00	N/A	1463	1.00	N/A	0.00	N/A	N/A
08/06/2011 13:00	1.00	1523	0.00	N/A	1523	1.00	N/A	0.00	N/A	N/A
08/06/2011 14:00	1.00	1586	0.00	N/A	1586	1.00	N/A	0.00	N/A	N/A
08/06/2011 15:00	1.00	1671	0.00	N/A	1671	1.00	N/A	0.00	N/A	N/A
08/06/2011 16:00	1.00	1672	0.00	N/A	1672	1.00	N/A	0.00	N/A	N/A
08/06/2011 17:00	1.00	1673	0.00	N/A	1673	1.00	N/A	0.00	N/A	N/A
08/06/2011 18:00	1.00	1673	0.00	N/A	1673	1.00	N/A	0.00	N/A	N/A
08/06/2011 19:00	1.00	1673	0.00	N/A	1673	1.00	N/A	0.00	N/A	N/A
08/06/2011 20:00	1.00	1648	0.00	N/A	1648	1.00	N/A	0.00	N/A	N/A
08/06/2011 21:00	1.00	1557	0.00	N/A	1557	1.00	N/A	0.00	N/A	N/A
08/06/2011 22:00	1.00	1232	0.00	N/A	1232	1.00	N/A	0.00	N/A	N/A
08/06/2011 23:00	1.00	1250	0.00	N/A	1250	1.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1445	0.00	N/A	1445	1.00	N/A	0.00	N/A	N/A
Maximum*	1.00	1673	0.00	N/A	1673	1.00	N/A	0.00	N/A	N/A
	08/06/2011	08/06/2011			08/06/2011	08/06/2011				
	23:00	19:00			19:00	23:00				
Minimum*	1.00	1099	0.00	N/A	1099	1.00	N/A	0.00	N/A	N/A
	08/06/2011	08/06/2011	08/06/2011		08/06/2011	08/06/2011		08/06/2011		
	23:00	4:00	23:00		4:00	23:00		23:00		
Total*	24.00	34668	0.00	0	34668	24.00	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/07/2011 00:00	1.00	1386	0.00	N/A	1386	0.27	N/A	0.00	N/A	N/A
08/07/2011 01:00	1.00	1510	0.00	N/A	1510	0.00	N/A	0.00	N/A	N/A
08/07/2011 02:00	1.00	1629	0.00	N/A	1629	0.00	N/A	0.00	N/A	N/A
08/07/2011 03:00	1.00	1481	0.00	N/A	1481	0.00	N/A	0.00	N/A	N/A
08/07/2011 04:00	1.00	1360	0.00	N/A	1360	0.00	N/A	0.00	N/A	N/A
08/07/2011 05:00	1.00	1353	0.00	N/A	1353	0.28	N/A	0.00	N/A	N/A
08/07/2011 06:00	1.00	1324	0.00	N/A	1324	1.00	N/A	0.00	N/A	N/A
08/07/2011 07:00	1.00	1230	0.00	N/A	1230	1.00	N/A	0.00	N/A	N/A
08/07/2011 08:00	1.00	1620	0.00	N/A	1620	1.00	N/A	0.00	N/A	N/A
08/07/2011 09:00	1.00	1632	0.00	N/A	1632	1.00	N/A	0.00	N/A	N/A
08/07/2011 10:00	1.00	1570	0.00	N/A	1570	1.00	N/A	0.00	N/A	N/A
08/07/2011 11:00	1.00	1670	0.00	N/A	1670	1.00	N/A	0.00	N/A	N/A
08/07/2011 12:00	1.00	1647	0.00	N/A	1647	1.00	N/A	0.00	N/A	N/A
08/07/2011 13:00	1.00	1572	0.00	N/A	1572	1.00	N/A	0.00	N/A	N/A
08/07/2011 14:00	1.00	1497	0.00	N/A	1497	1.00	N/A	0.00	N/A	N/A
08/07/2011 15:00	1.00	1482	0.00	N/A	1482	1.00	N/A	0.00	N/A	N/A
08/07/2011 16:00	1.00	1650	0.00	N/A	1650	1.00	N/A	0.00	N/A	N/A
08/07/2011 17:00	1.00	1488	0.00	N/A	1488	1.00	N/A	0.00	N/A	N/A
08/07/2011 18:00	1.00	1667	0.00	N/A	1667	1.00	N/A	0.00	N/A	N/A
08/07/2011 19:00	1.00	1604	0.00	N/A	1604	1.00	N/A	0.00	N/A	N/A
08/07/2011 20:00	1.00	1498	0.00	N/A	1498	1.00	N/A	0.00	N/A	N/A
08/07/2011 21:00	1.00	1537	0.00	N/A	1537	1.00	N/A	0.00	N/A	N/A
08/07/2011 22:00	1.00	1162	0.00	N/A	1162	1.00	N/A	0.00	N/A	N/A
08/07/2011 23:00	1.00	1380	0.00	N/A	1380	0.10	N/A	0.00	N/A	N/A
Daily Average*	1.00	1498	0.00	N/A	1498	0.74	N/A	0.00	N/A	N/A
Maximum*	1.00	1670	0.00	N/A	1670	1.00	N/A	0.00	N/A	N/A
	08/07/2011	08/07/2011			08/07/2011	08/07/2011				
	23:00	11:00			11:00	22:00				
Minimum*	1.00	1162	0.00	N/A	1162	0.00	N/A	0.00	N/A	N/A
	08/07/2011	08/07/2011	08/07/2011		08/07/2011	08/07/2011		08/07/2011		
	23:00	22:00	23:00		22:00	4:00		23:00		
Total*	24.00	35949	0.00	0	35949	17.65	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/08/2011 00:00	1.00	1154	0.00	N/A	1154	0.00	N/A	0.00	N/A	N/A
08/08/2011 01:00	1.00	1277	0.00	N/A	1277	0.00	N/A	0.00	N/A	N/A
08/08/2011 02:00	1.00	1437	0.00	N/A	1437	0.00	N/A	0.00	N/A	N/A
08/08/2011 03:00	1.00	1388	0.00	N/A	1388	0.00	N/A	0.00	N/A	N/A
08/08/2011 04:00	1.00	1504	0.00	N/A	1504	0.00	N/A	0.00	N/A	N/A
08/08/2011 05:00	1.00	1652	0.00	N/A	1652	0.12	N/A	0.00	N/A	N/A
08/08/2011 06:00	1.00	1693	0.00	N/A	1693	1.00	N/A	0.00	N/A	N/A
08/08/2011 07:00	1.00	1238	0.00	N/A	1238	1.00	N/A	0.00	N/A	N/A
08/08/2011 08:00	1.00	1445	0.00	N/A	1445	1.00	N/A	0.00	N/A	N/A
08/08/2011 09:00	1.00	1635	0.00	N/A	1635	1.00	N/A	0.00	N/A	N/A
08/08/2011 10:00	1.00	1700	0.00	N/A	1700	1.00	N/A	0.00	N/A	N/A
08/08/2011 11:00	1.00	1701	0.00	N/A	1701	1.00	N/A	0.00	N/A	N/A
08/08/2011 12:00	1.00	1707	0.00	N/A	1707	1.00	N/A	0.00	N/A	N/A
08/08/2011 13:00	1.00	1709	0.00	N/A	1709	1.00	N/A	0.00	N/A	N/A
08/08/2011 14:00	1.00	1707	0.00	N/A	1707	1.00	N/A	0.00	N/A	N/A
08/08/2011 15:00	1.00	1704	0.00	N/A	1704	1.00	N/A	0.00	N/A	N/A
08/08/2011 16:00	1.00	1702	0.00	N/A	1702	1.00	N/A	0.00	N/A	N/A
08/08/2011 17:00	1.00	1708	0.00	N/A	1708	1.00	N/A	0.00	N/A	N/A
08/08/2011 18:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/08/2011 19:00	1.00	1359	0.00	N/A	1359	1.00	N/A	0.00	N/A	N/A
08/08/2011 20:00	1.00	1500	0.00	N/A	1500	1.00	N/A	0.00	N/A	N/A
08/08/2011 21:00	1.00	1233	0.00	N/A	1233	1.00	N/A	0.00	N/A	N/A
08/08/2011 22:00	1.00	1339	0.00	N/A	1339	0.25	N/A	0.00	N/A	N/A
08/08/2011 23:00	1.00	1585	0.00	N/A	1585	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1533	0.00	N/A	1533	0.68	N/A	0.00	N/A	N/A
Maximum*	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
	08/08/2011	08/08/2011			08/08/2011	08/08/2011				
	23:00	18:00			18:00	21:00				
Minimum*	1.00	1154	0.00	N/A	1154	0.00	N/A	0.00	N/A	N/A
	08/08/2011	08/08/2011	08/08/2011		08/08/2011	08/08/2011		08/08/2011		
	23:00	0:00	23:00		0:00	23:00		23:00		
Total*	24.00	36788	0.00	0	36788	16.37	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/09/2011 00:00	1.00	1265	0.00	N/A	1265	0.00	N/A	0.00	N/A	N/A
08/09/2011 01:00	1.00	1446	0.00	N/A	1446	0.00	N/A	0.00	N/A	N/A
08/09/2011 02:00	1.00	1204	0.00	N/A	1204	0.00	N/A	0.00	N/A	N/A
08/09/2011 03:00	1.00	1274	0.00	N/A	1274	0.00	N/A	0.00	N/A	N/A
08/09/2011 04:00	1.00	1670	0.00	N/A	1670	0.00	N/A	0.00	N/A	N/A
08/09/2011 05:00	1.00	1570	0.00	N/A	1570	0.00	N/A	0.00	N/A	N/A
08/09/2011 06:00	1.00	1685	0.00	N/A	1685	0.13	N/A	0.00	N/A	N/A
08/09/2011 07:00	1.00	1305	0.00	N/A	1305	1.00	N/A	0.00	N/A	N/A
08/09/2011 08:00	1.00	1202	0.00	N/A	1202	1.00	N/A	0.00	N/A	N/A
08/09/2011 09:00	1.00	1525	0.00	N/A	1525	1.00	N/A	0.00	N/A	N/A
08/09/2011 10:00	1.00	1624	0.00	N/A	1624	1.00	N/A	0.00	N/A	N/A
08/09/2011 11:00	1.00	1252	0.00	N/A	1252	1.00	N/A	0.00	N/A	N/A
08/09/2011 12:00	1.00	1177	0.00	N/A	1177	1.00	N/A	0.00	N/A	N/A
08/09/2011 13:00	1.00	1101	0.00	N/A	1101	1.00	N/A	0.00	N/A	N/A
08/09/2011 14:00	1.00	1106	0.00	N/A	1106	1.00	N/A	0.00	N/A	N/A
08/09/2011 15:00	1.00	1096	0.00	N/A	1096	1.00	N/A	0.00	N/A	N/A
08/09/2011 16:00	1.00	1090	0.00	N/A	1090	1.00	N/A	0.00	N/A	N/A
08/09/2011 17:00	1.00	1085	0.00	N/A	1085	1.00	N/A	0.00	N/A	N/A
08/09/2011 18:00	1.00	1111	0.00	N/A	1111	1.00	N/A	0.00	N/A	N/A
08/09/2011 19:00	1.00	1347	0.00	N/A	1347	1.00	N/A	0.00	N/A	N/A
08/09/2011 20:00	1.00	1282	0.00	N/A	1282	1.00	N/A	0.00	N/A	N/A
08/09/2011 21:00	1.00	1265	0.00	N/A	1265	0.07	N/A	0.00	N/A	N/A
08/09/2011 22:00	1.00	1377	0.00	N/A	1377	0.00	N/A	0.00	N/A	N/A
08/09/2011 23:00	1.00	1410	0.00	N/A	1410	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1311	0.00	N/A	1311	0.59	N/A	0.00	N/A	N/A
Maximum*	1.00	1685	0.00	N/A	1685	1.00	N/A	0.00	N/A	N/A
	08/09/2011	08/09/2011			08/09/2011	08/09/2011				
	23:00	6:00			6:00	20:00				
Minimum*	1.00	1085	0.00	N/A	1085	0.00	N/A	0.00	N/A	N/A
	08/09/2011	08/09/2011	08/09/2011		08/09/2011	08/09/2011		08/09/2011		
	23:00	17:00	23:00		17:00	23:00		23:00		
Total*	24.00	31469	0.00	0	31469	14.20	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/10/2011 00:00	1.00	1171	0.00	N/A	1171	0.00	N/A	0.00	N/A	N/A
08/10/2011 01:00	1.00	1213	0.00	N/A	1213	0.00	N/A	0.00	N/A	N/A
08/10/2011 02:00	1.00	1193	0.00	N/A	1193	0.00	N/A	0.00	N/A	N/A
08/10/2011 03:00	1.00	1177	0.00	N/A	1177	0.00	N/A	0.00	N/A	N/A
08/10/2011 04:00	1.00	1285	0.00	N/A	1285	0.00	N/A	0.00	N/A	N/A
08/10/2011 05:00	1.00	1238	0.00	N/A	1238	0.00	N/A	0.00	N/A	N/A
08/10/2011 06:00	1.00	1212	0.00	N/A	1212	0.10	N/A	0.00	N/A	N/A
08/10/2011 07:00	1.00	1345	0.00	N/A	1345	1.00	N/A	0.00	N/A	N/A
08/10/2011 08:00	1.00	1216	0.00	N/A	1216	1.00	N/A	0.00	N/A	N/A
08/10/2011 09:00	1.00	1336	0.00	N/A	1336	1.00	N/A	0.00	N/A	N/A
08/10/2011 10:00	1.00	1620	0.00	N/A	1620	1.00	N/A	0.00	N/A	N/A
08/10/2011 11:00	1.00	1660	0.00	N/A	1660	1.00	N/A	0.00	N/A	N/A
08/10/2011 12:00	1.00	1719	0.00	N/A	1719	1.00	N/A	0.00	N/A	N/A
08/10/2011 13:00	1.00	1744	0.00	N/A	1744	1.00	N/A	0.00	N/A	N/A
08/10/2011 14:00	1.00	1737	0.00	N/A	1737	1.00	N/A	0.00	N/A	N/A
08/10/2011 15:00	1.00	1741	0.00	N/A	1741	1.00	N/A	0.00	N/A	N/A
08/10/2011 16:00	1.00	1742	0.00	N/A	1742	1.00	N/A	0.00	N/A	N/A
08/10/2011 17:00	1.00	1741	0.00	N/A	1741	1.00	N/A	0.00	N/A	N/A
08/10/2011 18:00	1.00	1741	0.00	N/A	1741	1.00	N/A	0.00	N/A	N/A
08/10/2011 19:00	1.00	1743	0.00	N/A	1743	1.00	N/A	0.00	N/A	N/A
08/10/2011 20:00	1.00	1746	0.00	N/A	1746	1.00	N/A	0.00	N/A	N/A
08/10/2011 21:00	1.00	1349	0.00	N/A	1349	1.00	N/A	0.00	N/A	N/A
08/10/2011 22:00	1.00	1397	0.00	N/A	1397	0.03	N/A	0.00	N/A	N/A
08/10/2011 23:00	1.00	1452	0.00	N/A	1452	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1480	0.00	N/A	1480	0.63	N/A	0.00	N/A	N/A
Maximum*	1.00	1746	0.00	N/A	1746	1.00	N/A	0.00	N/A	N/A
	08/10/2011	08/10/2011			08/10/2011	08/10/2011				
	23:00	20:00			20:00	21:00				
Minimum*	1.00	1171	0.00	N/A	1171	0.00	N/A	0.00	N/A	N/A
	08/10/2011	08/10/2011	08/10/2011		08/10/2011	08/10/2011		08/10/2011		
	23:00	0:00	23:00		0:00	23:00		23:00		
Total*	24.00	35518	0.00	0	35518	15.13	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/11/2011 00:00	1.00	1319	0.00	N/A	1319	0.00	N/A	0.00	N/A	N/A
08/11/2011 01:00	1.00	1192	0.00	N/A	1192	0.00	N/A	0.00	N/A	N/A
08/11/2011 02:00	1.00	1322	0.00	N/A	1322	0.00	N/A	0.00	N/A	N/A
08/11/2011 03:00	1.00	1334	0.00	N/A	1334	0.00	N/A	0.00	N/A	N/A
08/11/2011 04:00	1.00	1526	0.00	N/A	1526	0.00	N/A	0.00	N/A	N/A
08/11/2011 05:00	1.00	1746	0.00	N/A	1746	0.08	N/A	0.00	N/A	N/A
08/11/2011 06:00	1.00	1556	0.00	N/A	1556	1.00	N/A	0.00	N/A	N/A
08/11/2011 07:00	1.00	1208	0.00	N/A	1208	1.00	N/A	0.00	N/A	N/A
08/11/2011 08:00	1.00	1303	0.00	N/A	1303	1.00	N/A	0.00	N/A	N/A
08/11/2011 09:00	1.00	1655	0.00	N/A	1655	1.00	N/A	0.00	N/A	N/A
08/11/2011 10:00	1.00	1671	0.00	N/A	1671	1.00	N/A	0.00	N/A	N/A
08/11/2011 11:00	1.00	1662	0.00	N/A	1662	1.00	N/A	0.00	N/A	N/A
08/11/2011 12:00	1.00	1665	0.00	N/A	1665	1.00	N/A	0.00	N/A	N/A
08/11/2011 13:00	1.00	1685	0.00	N/A	1685	1.00	N/A	0.00	N/A	N/A
08/11/2011 14:00	1.00	1690	0.00	N/A	1690	1.00	N/A	0.00	N/A	N/A
08/11/2011 15:00	1.00	1692	0.00	N/A	1692	1.00	N/A	0.00	N/A	N/A
08/11/2011 16:00	1.00	1691	0.00	N/A	1691	1.00	N/A	0.00	N/A	N/A
08/11/2011 17:00	1.00	1635	0.00	N/A	1635	1.00	N/A	0.00	N/A	N/A
08/11/2011 18:00	1.00	1696	0.00	N/A	1696	1.00	N/A	0.00	N/A	N/A
08/11/2011 19:00	1.00	1708	0.00	N/A	1708	1.00	N/A	0.00	N/A	N/A
08/11/2011 20:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/11/2011 21:00	1.00	1723	0.00	N/A	1723	1.00	N/A	0.00	N/A	N/A
08/11/2011 22:00	1.00	1321	0.00	N/A	1321	1.00	N/A	0.00	N/A	N/A
08/11/2011 23:00	1.00	1348	0.00	N/A	1348	0.20	N/A	0.00	N/A	N/A
Daily Average*	1.00	1544	0.00	N/A	1544	0.72	N/A	0.00	N/A	N/A
Maximum*	1.00	1746	0.00	N/A	1746	1.00	N/A	0.00	N/A	N/A
	08/11/2011	08/11/2011			08/11/2011	08/11/2011				
	23:00	5:00			5:00	22:00				
Minimum*	1.00	1192	0.00	N/A	1192	0.00	N/A	0.00	N/A	N/A
	08/11/2011	08/11/2011	08/11/2011		08/11/2011	08/11/2011		08/11/2011		
	23:00	1:00	23:00		1:00	4:00		23:00		
Total*	24.00	37059	0.00	0	37059	17.28	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/12/2011 00:00	1.00	1548	0.00	N/A	1548	0.00	N/A	0.00	N/A	N/A
08/12/2011 01:00	1.00	1694	0.00	N/A	1694	0.00	N/A	0.00	N/A	N/A
08/12/2011 02:00	1.00	1272	0.00	N/A	1272	0.00	N/A	0.00	N/A	N/A
08/12/2011 03:00	1.00	1154	0.00	N/A	1154	0.00	N/A	0.00	N/A	N/A
08/12/2011 04:00	1.00	1301	0.00	N/A	1301	0.00	N/A	0.00	N/A	N/A
08/12/2011 05:00	1.00	1694	0.00	N/A	1694	0.05	N/A	0.00	N/A	N/A
08/12/2011 06:00	1.00	1448	0.00	N/A	1448	1.00	N/A	0.00	N/A	N/A
08/12/2011 07:00	1.00	1207	0.00	N/A	1207	1.00	N/A	0.00	N/A	N/A
08/12/2011 08:00	1.00	1438	0.00	N/A	1438	1.00	N/A	0.00	N/A	N/A
08/12/2011 09:00	1.00	1574	0.00	N/A	1574	1.00	N/A	0.00	N/A	N/A
08/12/2011 10:00	1.00	1699	0.00	N/A	1699	1.00	N/A	0.00	N/A	N/A
08/12/2011 11:00	1.00	1700	0.00	N/A	1700	1.00	N/A	0.00	N/A	N/A
08/12/2011 12:00	1.00	1698	0.00	N/A	1698	1.00	N/A	0.00	N/A	N/A
08/12/2011 13:00	1.00	1698	0.00	N/A	1698	1.00	N/A	0.00	N/A	N/A
08/12/2011 14:00	1.00	1695	0.00	N/A	1695	1.00	N/A	0.00	N/A	N/A
08/12/2011 15:00	1.00	1690	0.00	N/A	1690	1.00	N/A	0.00	N/A	N/A
08/12/2011 16:00	1.00	1685	0.00	N/A	1685	1.00	N/A	0.00	N/A	N/A
08/12/2011 17:00	1.00	1682	0.00	N/A	1682	1.00	N/A	0.00	N/A	N/A
08/12/2011 18:00	1.00	1688	0.00	N/A	1688	1.00	N/A	0.00	N/A	N/A
08/12/2011 19:00	1.00	1647	0.00	N/A	1647	1.00	N/A	0.00	N/A	N/A
08/12/2011 20:00	1.00	1665	0.00	N/A	1665	1.00	N/A	0.00	N/A	N/A
08/12/2011 21:00	1.00	1529	0.00	N/A	1529	1.00	N/A	0.00	N/A	N/A
08/12/2011 22:00	1.00	1201	0.00	N/A	1201	1.00	N/A	0.00	N/A	N/A
08/12/2011 23:00	1.00	1489	0.00	N/A	1489	0.25	N/A	0.00	N/A	N/A
Daily Average*	1.00	1546	0.00	N/A	1546	0.72	N/A	0.00	N/A	N/A
Maximum*	1.00	1700	0.00	N/A	1700	1.00	N/A	0.00	N/A	N/A
	08/12/2011	08/12/2011			08/12/2011	08/12/2011				
	23:00	11:00			11:00	22:00				
Minimum*	1.00	1154	0.00	N/A	1154	0.00	N/A	0.00	N/A	N/A
	08/12/2011	08/12/2011	08/12/2011		08/12/2011	08/12/2011		08/12/2011		
	23:00	3:00	23:00		3:00	4:00		23:00		
Total*	24.00	37096	0.00	0	37096	17.30	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/13/2011 00:00	1.00	1537	0.00	N/A	1537	0.00	N/A	0.00	N/A	N/A
08/13/2011 01:00	1.00	1488	0.00	N/A	1488	0.00	N/A	0.00	N/A	N/A
08/13/2011 02:00	1.00	1624	0.00	N/A	1624	0.00	N/A	0.00	N/A	N/A
08/13/2011 03:00	1.00	1500	0.00	N/A	1500	0.00	N/A	0.00	N/A	N/A
08/13/2011 04:00	1.00	1414	0.00	N/A	1414	0.00	N/A	0.00	N/A	N/A
08/13/2011 05:00	1.00	1441	0.00	N/A	1441	0.00	N/A	0.00	N/A	N/A
08/13/2011 06:00	1.00	1497	0.00	N/A	1497	0.13	N/A	0.00	N/A	N/A
08/13/2011 07:00	1.00	1450	0.00	N/A	1450	1.00	N/A	0.00	N/A	N/A
08/13/2011 08:00	1.00	1230	0.00	N/A	1230	1.00	N/A	0.00	N/A	N/A
08/13/2011 09:00	1.00	1313	0.00	N/A	1313	1.00	N/A	0.00	N/A	N/A
08/13/2011 10:00	1.00	1599	0.00	N/A	1599	1.00	N/A	0.00	N/A	N/A
08/13/2011 11:00	1.00	1720	0.00	N/A	1720	1.00	N/A	0.00	N/A	N/A
08/13/2011 12:00	1.00	1714	0.00	N/A	1714	1.00	N/A	0.00	N/A	N/A
08/13/2011 13:00	1.00	1702	0.00	N/A	1702	1.00	N/A	0.00	N/A	N/A
08/13/2011 14:00	1.00	1699	0.00	N/A	1699	1.00	N/A	0.00	N/A	N/A
08/13/2011 15:00	1.00	1695	0.00	N/A	1695	1.00	N/A	0.00	N/A	N/A
08/13/2011 16:00	1.00	1694	0.00	N/A	1694	1.00	N/A	0.00	N/A	N/A
08/13/2011 17:00	1.00	1702	0.00	N/A	1702	1.00	N/A	0.00	N/A	N/A
08/13/2011 18:00	1.00	1701	0.00	N/A	1701	1.00	N/A	0.00	N/A	N/A
08/13/2011 19:00	1.00	1704	0.00	N/A	1704	1.00	N/A	0.00	N/A	N/A
08/13/2011 20:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/13/2011 21:00	1.00	1665	0.00	N/A	1665	1.00	N/A	0.00	N/A	N/A
08/13/2011 22:00	1.00	1160	0.00	N/A	1160	1.00	N/A	0.00	N/A	N/A
08/13/2011 23:00	1.00	1547	0.00	N/A	1547	0.18	N/A	0.00	N/A	N/A
Daily Average*	1.00	1563	0.00	N/A	1563	0.68	N/A	0.00	N/A	N/A
Maximum*	1.00	1720	0.00	N/A	1720	1.00	N/A	0.00	N/A	N/A
	08/13/2011	08/13/2011			08/13/2011	08/13/2011				
	23:00	11:00			11:00	22:00				
Minimum*	1.00	1160	0.00	N/A	1160	0.00	N/A	0.00	N/A	N/A
	08/13/2011	08/13/2011	08/13/2011		08/13/2011	08/13/2011		08/13/2011		
	23:00	22:00	23:00		22:00	5:00		23:00		
Total*	24.00	37507	0.00	0	37507	16.31	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/14/2011 00:00	1.00	1675	0.00	N/A	1675	0.00	N/A	0.00	N/A	N/A
08/14/2011 01:00	1.00	1544	0.00	N/A	1544	0.00	N/A	0.00	N/A	N/A
08/14/2011 02:00	1.00	1724	0.00	N/A	1724	0.00	N/A	0.00	N/A	N/A
08/14/2011 03:00	1.00	1677	0.00	N/A	1677	0.00	N/A	0.00	N/A	N/A
08/14/2011 04:00	1.00	1556	0.00	N/A	1556	0.00	N/A	0.00	N/A	N/A
08/14/2011 05:00	1.00	1623	0.00	N/A	1623	0.00	N/A	0.00	N/A	N/A
08/14/2011 06:00	1.00	1637	0.00	N/A	1637	0.00	N/A	0.00	N/A	N/A
08/14/2011 07:00	1.00	1550	0.00	N/A	1550	0.98	N/A	0.00	N/A	N/A
08/14/2011 08:00	1.00	1241	0.00	N/A	1241	1.00	N/A	0.00	N/A	N/A
08/14/2011 09:00	1.00	1554	0.00	N/A	1554	1.00	N/A	0.00	N/A	N/A
08/14/2011 10:00	1.00	1627	0.00	N/A	1627	1.00	N/A	0.00	N/A	N/A
08/14/2011 11:00	1.00	1676	0.00	N/A	1676	1.00	N/A	0.00	N/A	N/A
08/14/2011 12:00	1.00	1694	0.00	N/A	1694	1.00	N/A	0.00	N/A	N/A
08/14/2011 13:00	1.00	1696	0.00	N/A	1696	1.00	N/A	0.00	N/A	N/A
08/14/2011 14:00	1.00	1712	0.00	N/A	1712	1.00	N/A	0.00	N/A	N/A
08/14/2011 15:00	1.00	1726	0.00	N/A	1726	1.00	N/A	0.00	N/A	N/A
08/14/2011 16:00	1.00	1725	0.00	N/A	1725	1.00	N/A	0.00	N/A	N/A
08/14/2011 17:00	1.00	1721	0.00	N/A	1721	1.00	N/A	0.00	N/A	N/A
08/14/2011 18:00	1.00	1660	0.00	N/A	1660	1.00	N/A	0.00	N/A	N/A
08/14/2011 19:00	1.00	1677	0.00	N/A	1677	1.00	N/A	0.00	N/A	N/A
08/14/2011 20:00	1.00	1672	0.00	N/A	1672	1.00	N/A	0.00	N/A	N/A
08/14/2011 21:00	1.00	1602	0.00	N/A	1602	1.00	N/A	0.00	N/A	N/A
08/14/2011 22:00	1.00	1210	0.00	N/A	1210	1.00	N/A	0.00	N/A	N/A
08/14/2011 23:00	1.00	1365	0.00	N/A	1365	0.17	N/A	0.00	N/A	N/A
Daily Average*	1.00	1606	0.00	N/A	1606	0.67	N/A	0.00	N/A	N/A
Maximum*	1.00	1726	0.00	N/A	1726	1.00	N/A	0.00	N/A	N/A
	08/14/2011	08/14/2011			08/14/2011	08/14/2011				
	23:00	15:00			15:00	22:00				
Minimum*	1.00	1210	0.00	N/A	1210	0.00	N/A	0.00	N/A	N/A
	08/14/2011	08/14/2011	08/14/2011		08/14/2011	08/14/2011		08/14/2011		
	23:00	22:00	23:00		22:00	6:00		23:00		
Total*	24.00	38544	0.00	0	38544	16.15	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/15/2011 00:00	1.00	1672	0.00	N/A	1672	0.00	N/A	0.00	N/A	N/A
08/15/2011 01:00	1.00	1576	0.00	N/A	1576	0.00	N/A	0.00	N/A	N/A
08/15/2011 02:00	1.00	1609	0.00	N/A	1609	0.00	N/A	0.00	N/A	N/A
08/15/2011 03:00	1.00	1576	0.00	N/A	1576	0.00	N/A	0.00	N/A	N/A
08/15/2011 04:00	1.00	1655	0.00	N/A	1655	0.00	N/A	0.00	N/A	N/A
08/15/2011 05:00	1.00	1622	0.00	N/A	1622	0.00	N/A	0.00	N/A	N/A
08/15/2011 06:00	1.00	1520	0.00	N/A	1520	1.00	N/A	0.00	N/A	N/A
08/15/2011 07:00	1.00	1212	0.00	N/A	1212	1.00	N/A	0.00	N/A	N/A
08/15/2011 08:00	1.00	1245	0.00	N/A	1245	1.00	N/A	0.00	N/A	N/A
08/15/2011 09:00	1.00	1648	0.00	N/A	1648	1.00	N/A	0.00	N/A	N/A
08/15/2011 10:00	1.00	1724	0.00	N/A	1724	1.00	N/A	0.00	N/A	N/A
08/15/2011 11:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/15/2011 12:00	1.00	1704	0.00	N/A	1704	1.00	N/A	0.00	N/A	N/A
08/15/2011 13:00	1.00	1699	0.00	N/A	1699	1.00	N/A	0.00	N/A	N/A
08/15/2011 14:00	1.00	1698	0.00	N/A	1698	1.00	N/A	0.00	N/A	N/A
08/15/2011 15:00	1.00	1699	0.00	N/A	1699	1.00	N/A	0.00	N/A	N/A
08/15/2011 16:00	1.00	1699	0.00	N/A	1699	1.00	N/A	0.00	N/A	N/A
08/15/2011 17:00	1.00	1701	0.00	N/A	1701	1.00	N/A	0.00	N/A	N/A
08/15/2011 18:00	1.00	1703	0.00	N/A	1703	1.00	N/A	0.00	N/A	N/A
08/15/2011 19:00	1.00	1711	0.00	N/A	1711	1.00	N/A	0.00	N/A	N/A
08/15/2011 20:00	1.00	1717	0.00	N/A	1717	1.00	N/A	0.00	N/A	N/A
08/15/2011 21:00	1.00	1715	0.00	N/A	1715	1.00	N/A	0.00	N/A	N/A
08/15/2011 22:00	1.00	1322	0.00	N/A	1322	1.00	N/A	0.00	N/A	N/A
08/15/2011 23:00	1.00	1453	0.00	N/A	1453	0.20	N/A	0.00	N/A	N/A
Daily Average*	1.00	1608	0.00	N/A	1608	0.72	N/A	0.00	N/A	N/A
Maximum*	1.00	1724	0.00	N/A	1724	1.00	N/A	0.00	N/A	N/A
	08/15/2011	08/15/2011			08/15/2011	08/15/2011				
	23:00	10:00			10:00	22:00				
Minimum*	1.00	1212	0.00	N/A	1212	0.00	N/A	0.00	N/A	N/A
	08/15/2011	08/15/2011	08/15/2011		08/15/2011	08/15/2011		08/15/2011		
	23:00	7:00	23:00		7:00	5:00		23:00		
Total*	24.00	38591	0.00	0	38591	17.20	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:22

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/16/2011 00:00	1.00	1726	0.00	N/A	1726	0.00	N/A	0.00	N/A	N/A
08/16/2011 01:00	1.00	1677	0.00	N/A	1677	0.00	N/A	0.00	N/A	N/A
08/16/2011 02:00	1.00	1718	0.00	N/A	1718	0.00	N/A	0.00	N/A	N/A
08/16/2011 03:00	1.00	1725	0.00	N/A	1725	0.00	N/A	0.00	N/A	N/A
08/16/2011 04:00	1.00	1740	0.00	N/A	1740	0.00	N/A	0.00	N/A	N/A
08/16/2011 05:00	1.00	1752	0.00	N/A	1752	0.02	N/A	0.00	N/A	N/A
08/16/2011 06:00	1.00	1568	0.00	N/A	1568	1.00	N/A	0.00	N/A	N/A
08/16/2011 07:00	1.00	1214	0.00	N/A	1214	1.00	N/A	0.00	N/A	N/A
08/16/2011 08:00	1.00	1138	0.00	N/A	1138	1.00	N/A	0.00	N/A	N/A
08/16/2011 09:00	1.00	1402	0.00	N/A	1402	1.00	N/A	0.00	N/A	N/A
08/16/2011 10:00	1.00	1692	0.00	N/A	1692	1.00	N/A	0.00	N/A	N/A
08/16/2011 11:00	1.00	1710	0.00	N/A	1710	1.00	N/A	0.00	N/A	N/A
08/16/2011 12:00	1.00	1705	0.00	N/A	1705	1.00	N/A	0.00	N/A	N/A
08/16/2011 13:00	1.00	1710	0.00	N/A	1710	1.00	N/A	0.00	N/A	N/A
08/16/2011 14:00	1.00	1714	0.00	N/A	1714	1.00	N/A	0.00	N/A	N/A
08/16/2011 15:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/16/2011 16:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/16/2011 17:00	1.00	1714	0.00	N/A	1714	1.00	N/A	0.00	N/A	N/A
08/16/2011 18:00	1.00	1713	0.00	N/A	1713	1.00	N/A	0.00	N/A	N/A
08/16/2011 19:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/16/2011 20:00	1.00	1716	0.00	N/A	1716	1.00	N/A	0.00	N/A	N/A
08/16/2011 21:00	1.00	1320	0.00	N/A	1320	1.00	N/A	0.00	N/A	N/A
08/16/2011 22:00	1.00	1284	0.00	N/A	1284	0.17	N/A	0.00	N/A	N/A
08/16/2011 23:00	1.00	1518	0.00	N/A	1518	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1609	0.00	N/A	1609	0.67	N/A	0.00	N/A	N/A
Maximum*	1.00	1752	0.00	N/A	1752	1.00	N/A	0.00	N/A	N/A
	08/16/2011	08/16/2011			08/16/2011	08/16/2011				
	23:00	5:00			5:00	21:00				
Minimum*	1.00	1138	0.00	N/A	1138	0.00	N/A	0.00	N/A	N/A
	08/16/2011	08/16/2011	08/16/2011		08/16/2011	08/16/2011		08/16/2011		
	23:00	8:00	23:00		8:00	23:00		23:00		
Total*	24.00	38604	0.00	0	38604	16.19	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/17/2011 00:00	1.00	1497	0.00	N/A	1497	0.00	N/A	0.00	N/A	N/A
08/17/2011 01:00	1.00	1474	0.00	N/A	1474	0.00	N/A	0.00	N/A	N/A
08/17/2011 02:00	1.00	1273	0.00	N/A	1273	0.00	N/A	0.00	N/A	N/A
08/17/2011 03:00	1.00	1315	0.00	N/A	1315	0.00	N/A	0.00	N/A	N/A
08/17/2011 04:00	1.00	1348	0.00	N/A	1348	0.00	N/A	0.00	N/A	N/A
08/17/2011 05:00	1.00	1647	0.00	N/A	1647	0.23	N/A	0.00	N/A	N/A
08/17/2011 06:00	1.00	1304	0.00	N/A	1304	1.00	N/A	0.00	N/A	N/A
08/17/2011 07:00	1.00	1183	0.00	N/A	1183	1.00	N/A	0.00	N/A	N/A
08/17/2011 08:00	1.00	1224	0.00	N/A	1224	1.00	N/A	0.00	N/A	N/A
08/17/2011 09:00	1.00	1632	0.00	N/A	1632	1.00	N/A	0.00	N/A	N/A
08/17/2011 10:00	1.00	1717	0.00	N/A	1717	1.00	N/A	0.00	N/A	N/A
08/17/2011 11:00	1.00	1713	0.00	N/A	1713	1.00	N/A	0.00	N/A	N/A
08/17/2011 12:00	1.00	1713	0.00	N/A	1713	1.00	N/A	0.00	N/A	N/A
08/17/2011 13:00	1.00	1709	0.00	N/A	1709	1.00	N/A	0.00	N/A	N/A
08/17/2011 14:00	1.00	1703	0.00	N/A	1703	0.87	N/A	0.00	N/A	N/A
08/17/2011 15:00	1.00	1699	0.00	N/A	1699	0.33	N/A	0.00	N/A	N/A
08/17/2011 16:00	0.98	1691	0.00	N/A	1691	0.27	N/A	0.00	N/A	N/A
08/17/2011 17:00	1.00	1726	0.00	N/A	1726	0.75	N/A	0.00	N/A	N/A
08/17/2011 18:00	1.00	1602	0.00	N/A	1602	1.00	N/A	0.00	N/A	N/A
08/17/2011 19:00	1.00	1607	0.00	N/A	1607	1.00	N/A	0.00	N/A	N/A
08/17/2011 20:00	1.00	1634	0.00	N/A	1634	1.00	N/A	0.00	N/A	N/A
08/17/2011 21:00	1.00	1271	0.00	N/A	1271	1.00	N/A	0.00	N/A	N/A
08/17/2011 22:00	1.00	1247	0.00	N/A	1247	0.18	N/A	0.00	N/A	N/A
08/17/2011 23:00	1.00	1539	0.00	N/A	1539	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1520	0.00	N/A	1520	0.61	N/A	0.00	N/A	N/A
Maximum*	1.00	1726	0.00	N/A	1726	1.00	N/A	0.00	N/A	N/A
	08/17/2011	08/17/2011			08/17/2011	08/17/2011				
	23:00	17:00			17:00	21:00				
Minimum*	0.98	1183	0.00	N/A	1183	0.00	N/A	0.00	N/A	N/A
	08/17/2011	08/17/2011	08/17/2011		08/17/2011	08/17/2011		08/17/2011		
	16:00	7:00	23:00		7:00	23:00		23:00		
Total*	23.98	36468	0.00	0	36468	14.63	0	0.00	0	0

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/18/2011 00:00	1.00	1609	0.00	N/A	1609	0.00	N/A	0.00	N/A	N/A
08/18/2011 01:00	1.00	1439	0.00	N/A	1439	0.00	N/A	0.00	N/A	N/A
08/18/2011 02:00	1.00	1593	0.00	N/A	1593	0.00	N/A	0.00	N/A	N/A
08/18/2011 03:00	1.00	1476	0.00	N/A	1476	0.00	N/A	0.00	N/A	N/A
08/18/2011 04:00	1.00	1262	0.00	N/A	1262	0.00	N/A	0.00	N/A	N/A
08/18/2011 05:00	1.00	1412	0.00	N/A	1412	0.00	N/A	0.00	N/A	N/A
08/18/2011 06:00	1.00	1630	0.00	N/A	1630	0.22	N/A	0.00	N/A	N/A
08/18/2011 07:00	1.00	1589	0.00	N/A	1589	1.00	N/A	0.00	N/A	N/A
08/18/2011 08:00	1.00	1183	0.00	N/A	1183	1.00	N/A	0.00	N/A	N/A
08/18/2011 09:00	1.00	1572	0.00	N/A	1572	1.00	N/A	0.00	N/A	N/A
08/18/2011 10:00	1.00	1699	0.00	N/A	1699	0.98	1706	0.00	N/A	1706
08/18/2011 11:00	1.00	1709	0.00	N/A	1709	1.00	1715	0.00	N/A	1715
08/18/2011 12:00	1.00	1709	0.00	N/A	1709	1.00	1713	0.00	N/A	1713
08/18/2011 13:00	1.00	1707	0.00	N/A	1707	1.00	1708	0.00	N/A	1708
08/18/2011 14:00	1.00	1703	0.00	N/A	1703	1.00	1701	0.00	N/A	1701
08/18/2011 15:00	1.00	1702	0.00	N/A	1702	1.00	1698	0.00	N/A	1698
08/18/2011 16:00	1.00	1702	0.00	N/A	1702	1.00	1698	0.00	N/A	1698
08/18/2011 17:00	1.00	1712	0.00	N/A	1712	1.00	1712	0.00	N/A	1712
08/18/2011 18:00	1.00	1741	0.00	N/A	1741	1.00	1744	0.00	N/A	1744
08/18/2011 19:00	1.00	1688	0.00	N/A	1688	1.00	1695	0.00	N/A	1695
08/18/2011 20:00	1.00	1567	0.00	N/A	1567	1.00	1575	0.00	N/A	1575
08/18/2011 21:00	1.00	1253	0.00	N/A	1253	1.00	1164	0.00	N/A	1164
08/18/2011 22:00	1.00	1220	0.00	N/A	1220	0.10	611	0.00	N/A	611
08/18/2011 23:00	1.00	1370	0.00	N/A	1370	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1552	0.00	N/A	1552	0.64	1572	0.00	N/A	1572
Maximum*	1.00	1741	0.00	N/A	1741	1.00	1744	0.00	N/A	1744
	08/18/2011	08/18/2011			08/18/2011	08/18/2011	08/18/2011			08/18/2011
	23:00	18:00			18:00	21:00	18:00			18:00
Minimum*	1.00	1183	0.00	N/A	1183	0.00	611	0.00	N/A	611
	08/18/2011	08/18/2011	08/18/2011		08/18/2011	08/18/2011	08/18/2011	08/18/2011		08/18/2011
	23:00	8:00	23:00		8:00	23:00	22:00	23:00		22:00
Total*	24.00	37247	0.00	0	37247	15.30	20440	0.00	0	20440

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/19/2011 00:00	1.00	1442	0.00	N/A	1442	0.00	N/A	0.00	N/A	N/A
08/19/2011 01:00	1.00	1483	0.00	N/A	1483	0.00	N/A	0.00	N/A	N/A
08/19/2011 02:00	1.00	1533	0.00	N/A	1533	0.00	N/A	0.00	N/A	N/A
08/19/2011 03:00	1.00	1492	0.00	N/A	1492	0.00	N/A	0.00	N/A	N/A
08/19/2011 04:00	1.00	1275	0.00	N/A	1275	0.00	N/A	0.00	N/A	N/A
08/19/2011 05:00	1.00	1378	0.00	N/A	1378	0.00	N/A	0.00	N/A	N/A
08/19/2011 06:00	1.00	1615	0.00	N/A	1615	0.23	344	0.00	N/A	344
08/19/2011 07:00	1.00	1455	0.00	N/A	1455	1.00	869	0.00	N/A	869
08/19/2011 08:00	1.00	1221	0.00	N/A	1221	1.00	1213	0.00	N/A	1213
08/19/2011 09:00	1.00	1441	0.00	N/A	1441	1.00	1450	0.00	N/A	1450
08/19/2011 10:00	1.00	1710	0.00	N/A	1710	1.00	1721	0.00	N/A	1721
08/19/2011 11:00	1.00	1707	0.00	N/A	1707	1.00	1715	0.00	N/A	1715
08/19/2011 12:00	1.00	1709	0.00	N/A	1709	1.00	1711	0.00	N/A	1711
08/19/2011 13:00	1.00	1712	0.00	N/A	1712	1.00	1707	0.00	N/A	1707
08/19/2011 14:00	1.00	1705	0.00	N/A	1705	1.00	1700	0.00	N/A	1700
08/19/2011 15:00	1.00	1704	0.00	N/A	1704	1.00	1697	0.00	N/A	1697
08/19/2011 16:00	1.00	1713	0.00	N/A	1713	1.00	1712	0.00	N/A	1712
08/19/2011 17:00	1.00	1714	0.00	N/A	1714	1.00	1719	0.00	N/A	1719
08/19/2011 18:00	1.00	1713	0.00	N/A	1713	1.00	1717	0.00	N/A	1717
08/19/2011 19:00	1.00	1714	0.00	N/A	1714	1.00	1717	0.00	N/A	1717
08/19/2011 20:00	1.00	1708	0.00	N/A	1708	1.00	1713	0.00	N/A	1713
08/19/2011 21:00	1.00	1309	0.00	N/A	1309	1.00	1337	0.00	N/A	1337
08/19/2011 22:00	0.23	716	0.00	N/A	716	1.00	1584	0.00	N/A	1584
08/19/2011 23:00	0.00	N/A	0.00	N/A	N/A	1.00	1587	0.00	N/A	1587
Daily Average*	0.93	1529	0.00	N/A	1529	0.72	1512	0.00	N/A	1512
Maximum*	1.00	1714	0.00	N/A	1714	1.00	1721	0.00	N/A	1721
	08/19/2011	08/19/2011			08/19/2011	08/19/2011	08/19/2011			08/19/2011
	21:00	19:00			19:00	23:00	10:00			10:00
Minimum*	0.00	716	0.00	N/A	716	0.00	344	0.00	N/A	344
	08/19/2011	08/19/2011	08/19/2011		08/19/2011	08/19/2011	08/19/2011	08/19/2011		08/19/2011
	23:00	22:00	23:00		22:00	5:00	6:00	23:00		6:00
Total*	22.23	35169	0.00	0	35169	17.23	27213	0.00	0	27213

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/20/2011 00:00	0.00	N/A	0.00	N/A	N/A	1.00	1270	0.00	N/A	1270
08/20/2011 01:00	0.00	N/A	0.00	N/A	N/A	1.00	1295	0.00	N/A	1295
08/20/2011 02:00	0.00	N/A	0.00	N/A	N/A	1.00	1287	0.00	N/A	1287
08/20/2011 03:00	0.00	N/A	0.00	N/A	N/A	1.00	1204	0.00	N/A	1204
08/20/2011 04:00	0.00	N/A	0.00	N/A	N/A	1.00	1184	0.00	N/A	1184
08/20/2011 05:00	0.00	N/A	0.00	N/A	N/A	1.00	1311	0.00	N/A	1311
08/20/2011 06:00	0.02	1	0.00	N/A	1	1.00	1371	0.00	N/A	1371
08/20/2011 07:00	1.00	713	0.00	N/A	713	1.00	1626	0.00	N/A	1626
08/20/2011 08:00	1.00	1216	0.00	N/A	1216	1.00	1221	0.00	N/A	1221
08/20/2011 09:00	1.00	1642	0.00	N/A	1642	1.00	1647	0.00	N/A	1647
08/20/2011 10:00	1.00	1713	0.00	N/A	1713	1.00	1718	0.00	N/A	1718
08/20/2011 11:00	1.00	1710	0.00	N/A	1710	1.00	1714	0.00	N/A	1714
08/20/2011 12:00	1.00	1711	0.00	N/A	1711	1.00	1713	0.00	N/A	1713
08/20/2011 13:00	1.00	1711	0.00	N/A	1711	1.00	1711	0.00	N/A	1711
08/20/2011 14:00	1.00	1712	0.00	N/A	1712	1.00	1716	0.00	N/A	1716
08/20/2011 15:00	1.00	1722	0.00	N/A	1722	1.00	1728	0.00	N/A	1728
08/20/2011 16:00	1.00	1713	0.00	N/A	1713	1.00	1726	0.00	N/A	1726
08/20/2011 17:00	1.00	1641	0.00	N/A	1641	1.00	1658	0.00	N/A	1658
08/20/2011 18:00	1.00	1325	0.00	N/A	1325	1.00	1329	0.00	N/A	1329
08/20/2011 19:00	1.00	1540	0.00	N/A	1540	1.00	1557	0.00	N/A	1557
08/20/2011 20:00	1.00	1613	0.00	N/A	1613	1.00	1632	0.00	N/A	1632
08/20/2011 21:00	1.00	1268	0.00	N/A	1268	1.00	1268	0.00	N/A	1268
08/20/2011 22:00	1.00	1255	0.00	N/A	1255	0.60	1007	0.00	N/A	1007
08/20/2011 23:00	1.00	1316	0.00	N/A	1316	0.00	N/A	0.00	N/A	N/A
Daily Average*	0.71	1418	0.00	N/A	1418	0.94	1474	0.00	N/A	1474
Maximum*	1.00	1722	0.00	N/A	1722	1.00	1728	0.00	N/A	1728
	08/20/2011	08/20/2011			08/20/2011	08/20/2011	08/20/2011			08/20/2011
	23:00	15:00			15:00	21:00	15:00			15:00
Minimum*	0.00	1	0.00	N/A	1	0.00	1007	0.00	N/A	1007
	08/20/2011	08/20/2011	08/20/2011		08/20/2011	08/20/2011	08/20/2011	08/20/2011		08/20/2011
	5:00	6:00	23:00		6:00	23:00	22:00	23:00		22:00
Total*	17.02	25522	0.00	0	25522	22.60	33893	0.00	0	33893

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/21/2011 00:00	1.00	1254	0.00	N/A	1254	0.00	N/A	0.00	N/A	N/A
08/21/2011 01:00	1.00	1231	0.00	N/A	1231	0.00	N/A	0.00	N/A	N/A
08/21/2011 02:00	1.00	1246	0.00	N/A	1246	0.00	N/A	0.00	N/A	N/A
08/21/2011 03:00	1.00	1250	0.00	N/A	1250	0.00	N/A	0.00	N/A	N/A
08/21/2011 04:00	1.00	1210	0.00	N/A	1210	0.00	N/A	0.00	N/A	N/A
08/21/2011 05:00	1.00	1331	0.00	N/A	1331	0.00	N/A	0.00	N/A	N/A
08/21/2011 06:00	1.00	1498	0.00	N/A	1498	0.12	162	0.00	N/A	162
08/21/2011 07:00	1.00	1573	0.00	N/A	1573	1.00	773	0.00	N/A	773
08/21/2011 08:00	1.00	1231	0.00	N/A	1231	1.00	1225	0.00	N/A	1225
08/21/2011 09:00	1.00	1660	0.00	N/A	1660	1.00	1671	0.00	N/A	1671
08/21/2011 10:00	1.00	1708	0.00	N/A	1708	1.00	1716	0.00	N/A	1716
08/21/2011 11:00	1.00	1707	0.00	N/A	1707	1.00	1707	0.00	N/A	1707
08/21/2011 12:00	1.00	1707	0.00	N/A	1707	1.00	1703	0.00	N/A	1703
08/21/2011 13:00	1.00	1703	0.00	N/A	1703	1.00	1694	0.00	N/A	1694
08/21/2011 14:00	1.00	1704	0.00	N/A	1704	1.00	1701	0.00	N/A	1701
08/21/2011 15:00	1.00	1704	0.00	N/A	1704	1.00	1696	0.00	N/A	1696
08/21/2011 16:00	1.00	1700	0.00	N/A	1700	1.00	1686	0.00	N/A	1686
08/21/2011 17:00	1.00	1703	0.00	N/A	1703	1.00	1695	0.00	N/A	1695
08/21/2011 18:00	1.00	1710	0.00	N/A	1710	1.00	1718	0.00	N/A	1718
08/21/2011 19:00	1.00	1731	0.00	N/A	1731	1.00	1734	0.00	N/A	1734
08/21/2011 20:00	1.00	1666	0.00	N/A	1666	1.00	1674	0.00	N/A	1674
08/21/2011 21:00	1.00	1281	0.00	N/A	1281	1.00	1271	0.00	N/A	1271
08/21/2011 22:00	1.00	1268	0.00	N/A	1268	0.30	778	0.00	N/A	778
08/21/2011 23:00	1.00	1365	0.00	N/A	1365	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1506	0.00	N/A	1506	0.64	1447	0.00	N/A	1447
Maximum*	1.00	1731	0.00	N/A	1731	1.00	1734	0.00	N/A	1734
	08/21/2011	08/21/2011			08/21/2011	08/21/2011	08/21/2011			08/21/2011
	23:00	19:00			19:00	21:00	19:00			19:00
Minimum*	1.00	1210	0.00	N/A	1210	0.00	162	0.00	N/A	162
	08/21/2011	08/21/2011	08/21/2011		08/21/2011	08/21/2011	08/21/2011	08/21/2011		08/21/2011
	23:00	4:00	23:00		4:00	23:00	6:00	23:00		6:00
Total*	24.00	36141	0.00	0	36141	15.42	24604	0.00	0	24604

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/22/2011 00:00	1.00	1238	0.00	N/A	1238	0.00	N/A	0.00	N/A	N/A
08/22/2011 01:00	1.00	1328	0.00	N/A	1328	0.00	N/A	0.00	N/A	N/A
08/22/2011 02:00	1.00	1302	0.00	N/A	1302	0.00	N/A	0.00	N/A	N/A
08/22/2011 03:00	1.00	1210	0.00	N/A	1210	0.00	N/A	0.00	N/A	N/A
08/22/2011 04:00	1.00	1330	0.00	N/A	1330	0.00	N/A	0.00	N/A	N/A
08/22/2011 05:00	1.00	1588	0.00	N/A	1588	0.23	344	0.00	N/A	344
08/22/2011 06:00	1.00	1392	0.00	N/A	1392	1.00	863	0.00	N/A	863
08/22/2011 07:00	1.00	1209	0.00	N/A	1209	1.00	1198	0.00	N/A	1198
08/22/2011 08:00	1.00	1166	0.00	N/A	1166	1.00	1153	0.00	N/A	1153
08/22/2011 09:00	1.00	1615	0.00	N/A	1615	1.00	1628	0.00	N/A	1628
08/22/2011 10:00	1.00	1696	0.00	N/A	1696	1.00	1700	0.00	N/A	1700
08/22/2011 11:00	1.00	1712	0.00	N/A	1712	1.00	1710	0.00	N/A	1710
08/22/2011 12:00	1.00	1714	0.00	N/A	1714	1.00	1709	0.00	N/A	1709
08/22/2011 13:00	1.00	1709	0.00	N/A	1709	1.00	1693	0.00	N/A	1693
08/22/2011 14:00	1.00	1701	0.00	N/A	1701	1.00	1688	0.00	N/A	1688
08/22/2011 15:00	1.00	1701	0.00	N/A	1701	1.00	1686	0.00	N/A	1686
08/22/2011 16:00	1.00	1720	0.00	N/A	1720	1.00	1714	0.00	N/A	1714
08/22/2011 17:00	1.00	1713	0.00	N/A	1713	1.00	1698	0.00	N/A	1698
08/22/2011 18:00	1.00	1719	0.00	N/A	1719	1.00	1694	0.00	N/A	1694
08/22/2011 19:00	1.00	1721	0.00	N/A	1721	1.00	1713	0.00	N/A	1713
08/22/2011 20:00	1.00	1720	0.00	N/A	1720	1.00	1715	0.00	N/A	1715
08/22/2011 21:00	1.00	1560	0.00	N/A	1560	1.00	1568	0.00	N/A	1568
08/22/2011 22:00	1.00	1252	0.00	N/A	1252	1.00	1223	0.00	N/A	1223
08/22/2011 23:00	1.00	1331	0.00	N/A	1331	0.23	712	0.00	N/A	712
Daily Average*	1.00	1514	0.00	N/A	1514	0.73	1443	0.00	N/A	1443
Maximum*	1.00	1721	0.00	N/A	1721	1.00	1715	0.00	N/A	1715
	08/22/2011	08/22/2011			08/22/2011	08/22/2011	08/22/2011			08/22/2011
	23:00	19:00			19:00	22:00	20:00			20:00
Minimum*	1.00	1166	0.00	N/A	1166	0.00	344	0.00	N/A	344
	08/22/2011	08/22/2011	08/22/2011		08/22/2011	08/22/2011	08/22/2011	08/22/2011		08/22/2011
	23:00	8:00	23:00		8:00	4:00	5:00	23:00		5:00
Total*	24.00	36347	0.00	0	36347	17.46	27409	0.00	0	27409

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/23/2011 00:00	1.00	1302	0.00	N/A	1302	0.00	N/A	0.00	N/A	N/A
08/23/2011 01:00	1.00	1333	0.00	N/A	1333	0.00	N/A	0.00	N/A	N/A
08/23/2011 02:00	1.00	1251	0.00	N/A	1251	0.00	N/A	0.00	N/A	N/A
08/23/2011 03:00	1.00	1232	0.00	N/A	1232	0.00	N/A	0.00	N/A	N/A
08/23/2011 04:00	1.00	1373	0.00	N/A	1373	0.00	N/A	0.00	N/A	N/A
08/23/2011 05:00	1.00	1542	0.00	N/A	1542	0.25	372	0.00	N/A	372
08/23/2011 06:00	1.00	1334	0.00	N/A	1334	1.00	884	0.00	N/A	884
08/23/2011 07:00	1.00	1197	0.00	N/A	1197	1.00	1186	0.00	N/A	1186
08/23/2011 08:00	1.00	1295	0.00	N/A	1295	1.00	1298	0.00	N/A	1298
08/23/2011 09:00	1.00	1632	0.00	N/A	1632	1.00	1643	0.00	N/A	1643
08/23/2011 10:00	1.00	1705	0.00	N/A	1705	1.00	1704	0.00	N/A	1704
08/23/2011 11:00	1.00	1713	0.00	N/A	1713	1.00	1707	0.00	N/A	1707
08/23/2011 12:00	1.00	1704	0.00	N/A	1704	1.00	1697	0.00	N/A	1697
08/23/2011 13:00	1.00	1694	0.00	N/A	1694	1.00	1680	0.00	N/A	1680
08/23/2011 14:00	1.00	1700	0.00	N/A	1700	1.00	1686	0.00	N/A	1686
08/23/2011 15:00	1.00	1360	0.00	N/A	1360	1.00	1350	0.00	N/A	1350
08/23/2011 16:00	1.00	1076	0.00	N/A	1076	1.00	1058	0.00	N/A	1058
08/23/2011 17:00	1.00	1078	0.00	N/A	1078	1.00	1056	0.00	N/A	1056
08/23/2011 18:00	1.00	1076	0.00	N/A	1076	1.00	1057	0.00	N/A	1057
08/23/2011 19:00	1.00	1073	0.00	N/A	1073	1.00	1057	0.00	N/A	1057
08/23/2011 20:00	1.00	1074	0.00	N/A	1074	1.00	1058	0.00	N/A	1058
08/23/2011 21:00	1.00	991	0.00	N/A	991	1.00	1115	0.00	N/A	1115
08/23/2011 22:00	0.18	807	0.83	473	529	1.00	1225	0.00	N/A	1225
08/23/2011 23:00	0.40	753	0.53	478	590	1.00	1227	0.00	N/A	1227
Daily Average*	0.94	1304	0.06	476	1286	0.76	1266	0.00	N/A	1266
Maximum*	1.00	1713	0.83	478	1713	1.00	1707	0.00	N/A	1707
Minimum*	0.18	753	0.00	473	529	0.00	372	0.00	N/A	372
Total*	22.58	31295	1.36	951	30854	18.25	24060	0.00	0	24060

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/24/2011 00:00	0.00	N/A	0.00	N/A	N/A	1.00	1186	0.00	N/A	1186
08/24/2011 01:00	0.00	N/A	0.00	N/A	N/A	1.00	1289	0.00	N/A	1289
08/24/2011 02:00	0.00	N/A	0.00	N/A	N/A	1.00	1141	0.00	N/A	1141
08/24/2011 03:00	0.00	N/A	0.00	N/A	N/A	1.00	1146	0.00	N/A	1146
08/24/2011 04:00	0.00	N/A	0.00	N/A	N/A	1.00	1288	0.00	N/A	1288
08/24/2011 05:00	0.00	N/A	0.00	N/A	N/A	1.00	1623	0.00	N/A	1623
08/24/2011 06:00	0.00	N/A	0.00	N/A	N/A	1.00	1338	0.00	N/A	1338
08/24/2011 07:00	0.27	375	0.00	N/A	375	1.00	1495	0.00	N/A	1495
08/24/2011 08:00	1.00	900	0.00	N/A	900	1.00	1360	0.00	N/A	1360
08/24/2011 09:00	1.00	1206	0.00	N/A	1206	1.00	1199	0.00	N/A	1199
08/24/2011 10:00	1.00	1586	0.00	N/A	1586	1.00	1595	0.00	N/A	1595
08/24/2011 11:00	1.00	1569	0.00	N/A	1569	1.00	1580	0.00	N/A	1580
08/24/2011 12:00	1.00	1563	0.00	N/A	1563	1.00	1573	0.00	N/A	1573
08/24/2011 13:00	1.00	1669	0.00	N/A	1669	1.00	1658	0.00	N/A	1658
08/24/2011 14:00	1.00	1701	0.00	N/A	1701	1.00	1685	0.00	N/A	1685
08/24/2011 15:00	1.00	1704	0.00	N/A	1704	1.00	1692	0.00	N/A	1692
08/24/2011 16:00	1.00	1706	0.00	N/A	1706	1.00	1716	0.00	N/A	1716
08/24/2011 17:00	1.00	1715	0.00	N/A	1715	1.00	1722	0.00	N/A	1722
08/24/2011 18:00	1.00	1718	0.00	N/A	1718	1.00	1721	0.00	N/A	1721
08/24/2011 19:00	1.00	1724	0.00	N/A	1724	1.00	1729	0.00	N/A	1729
08/24/2011 20:00	1.00	1665	0.00	N/A	1665	1.00	1672	0.00	N/A	1672
08/24/2011 21:00	1.00	1203	0.00	N/A	1203	0.80	1028	0.20	294	879
08/24/2011 22:00	1.00	1230	0.00	N/A	1230	0.00	N/A	1.00	511	511
08/24/2011 23:00	1.00	1229	0.00	N/A	1229	0.40	727	0.13	239	613
Daily Average*	0.68	1439	0.00	N/A	1439	0.93	1442	0.06	348	1392
Maximum*	1.00	1724	0.00	N/A	1724	1.00	1729	1.00	511	1729
	08/24/2011	08/24/2011			08/24/2011	08/24/2011	08/24/2011	08/24/2011	08/24/2011	08/24/2011
	23:00	19:00			19:00	20:00	19:00	22:00	22:00	19:00
Minimum*	0.00	375	0.00	N/A	375	0.00	727	0.00	239	511
	08/24/2011	08/24/2011	08/24/2011		08/24/2011	08/24/2011	08/24/2011	08/24/2011	08/24/2011	08/24/2011
	6:00	7:00	23:00		7:00	22:00	23:00	20:00	23:00	22:00
Total*	16.27	24463	0.00	0	24463	22.20	33163	1.33	1044	33411

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/25/2011 00:00	1.00	1196	0.00	N/A	1196	0.00	N/A	0.00	N/A	N/A
08/25/2011 01:00	1.00	1406	0.00	N/A	1406	0.00	N/A	0.00	N/A	N/A
08/25/2011 02:00	1.00	1411	0.00	N/A	1411	0.00	N/A	0.00	N/A	N/A
08/25/2011 03:00	1.00	1377	0.00	N/A	1377	0.00	N/A	0.00	N/A	N/A
08/25/2011 04:00	1.00	1315	0.00	N/A	1315	0.00	N/A	0.00	N/A	N/A
08/25/2011 05:00	1.00	1612	0.00	N/A	1612	0.00	N/A	0.00	N/A	N/A
08/25/2011 06:00	1.00	1601	0.00	N/A	1601	0.23	346	0.00	N/A	346
08/25/2011 07:00	1.00	1378	0.00	N/A	1378	1.00	822	0.00	N/A	822
08/25/2011 08:00	1.00	1223	0.00	N/A	1223	1.00	1124	0.00	N/A	1124
08/25/2011 09:00	1.00	1366	0.00	N/A	1366	1.00	1376	0.00	N/A	1376
08/25/2011 10:00	1.00	1613	0.00	N/A	1613	1.00	1622	0.00	N/A	1622
08/25/2011 11:00	1.00	1683	0.00	N/A	1683	1.00	1673	0.00	N/A	1673
08/25/2011 12:00	1.00	1686	0.00	N/A	1686	1.00	1669	0.00	N/A	1669
08/25/2011 13:00	1.00	1599	0.00	N/A	1599	1.00	1606	0.00	N/A	1606
08/25/2011 14:00	1.00	1652	0.00	N/A	1652	1.00	1662	0.00	N/A	1662
08/25/2011 15:00	1.00	1683	0.00	N/A	1683	1.00	1677	0.00	N/A	1677
08/25/2011 16:00	1.00	1684	0.00	N/A	1684	1.00	1672	0.00	N/A	1672
08/25/2011 17:00	1.00	1689	0.00	N/A	1689	1.00	1681	0.00	N/A	1681
08/25/2011 18:00	1.00	1689	0.00	N/A	1689	1.00	1688	0.00	N/A	1688
08/25/2011 19:00	1.00	1688	0.00	N/A	1688	1.00	1696	0.00	N/A	1696
08/25/2011 20:00	1.00	1692	0.00	N/A	1692	1.00	1702	0.00	N/A	1702
08/25/2011 21:00	1.00	1553	0.00	N/A	1553	1.00	1567	0.00	N/A	1567
08/25/2011 22:00	1.00	1159	0.00	N/A	1159	1.00	1106	0.00	N/A	1106
08/25/2011 23:00	1.00	1252	0.00	N/A	1252	0.23	691	0.00	N/A	691
Daily Average*	1.00	1509	0.00	N/A	1509	0.69	1410	0.00	N/A	1410
Maximum*	1.00	1692	0.00	N/A	1692	1.00	1702	0.00	N/A	1702
	08/25/2011	08/25/2011			08/25/2011	08/25/2011	08/25/2011			08/25/2011
	23:00	20:00			20:00	22:00	20:00			20:00
Minimum*	1.00	1159	0.00	N/A	1159	0.00	346	0.00	N/A	346
	08/25/2011	08/25/2011	08/25/2011		08/25/2011	08/25/2011	08/25/2011	08/25/2011		08/25/2011
	23:00	22:00	23:00		22:00	5:00	6:00	23:00		6:00
Total*	24.00	36207	0.00	0	36207	16.46	25380	0.00	0	25380

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/26/2011 00:00	1.00	1517	0.00	N/A	1517	0.00	N/A	0.00	N/A	N/A
08/26/2011 01:00	1.00	1400	0.00	N/A	1400	0.00	N/A	0.00	N/A	N/A
08/26/2011 02:00	1.00	1531	0.00	N/A	1531	0.00	N/A	0.00	N/A	N/A
08/26/2011 03:00	1.00	1547	0.00	N/A	1547	0.00	N/A	0.00	N/A	N/A
08/26/2011 04:00	1.00	1339	0.00	N/A	1339	0.00	N/A	0.00	N/A	N/A
08/26/2011 05:00	1.00	1652	0.00	N/A	1652	0.23	343	0.00	N/A	343
08/26/2011 06:00	1.00	1227	0.00	N/A	1227	1.00	869	0.00	N/A	869
08/26/2011 07:00	1.00	1169	0.00	N/A	1169	1.00	1160	0.00	N/A	1160
08/26/2011 08:00	1.00	1433	0.00	N/A	1433	1.00	1444	0.00	N/A	1444
08/26/2011 09:00	1.00	1574	0.00	N/A	1574	1.00	1589	0.00	N/A	1589
08/26/2011 10:00	1.00	1541	0.00	N/A	1541	1.00	1555	0.00	N/A	1555
08/26/2011 11:00	1.00	1684	0.00	N/A	1684	1.00	1682	0.00	N/A	1682
08/26/2011 12:00	1.00	1692	0.00	N/A	1692	1.00	1678	0.00	N/A	1678
08/26/2011 13:00	1.00	1689	0.00	N/A	1689	1.00	1676	0.00	N/A	1676
08/26/2011 14:00	1.00	1688	0.00	N/A	1688	1.00	1677	0.00	N/A	1677
08/26/2011 15:00	1.00	1690	0.00	N/A	1690	1.00	1682	0.00	N/A	1682
08/26/2011 16:00	1.00	1693	0.00	N/A	1693	1.00	1684	0.00	N/A	1684
08/26/2011 17:00	1.00	1697	0.00	N/A	1697	1.00	1691	0.00	N/A	1691
08/26/2011 18:00	1.00	1701	0.00	N/A	1701	1.00	1707	0.00	N/A	1707
08/26/2011 19:00	1.00	1710	0.00	N/A	1710	1.00	1719	0.00	N/A	1719
08/26/2011 20:00	1.00	1713	0.00	N/A	1713	1.00	1721	0.00	N/A	1721
08/26/2011 21:00	1.00	1539	0.00	N/A	1539	1.00	1549	0.00	N/A	1549
08/26/2011 22:00	1.00	1381	0.00	N/A	1381	1.00	1387	0.00	N/A	1387
08/26/2011 23:00	1.00	1324	0.00	N/A	1324	1.00	1324	0.00	N/A	1324
Daily Average*	1.00	1547	0.00	N/A	1547	0.76	1481	0.00	N/A	1481
Maximum*	1.00	1713	0.00	N/A	1713	1.00	1721	0.00	N/A	1721
	08/26/2011	08/26/2011			08/26/2011	08/26/2011	08/26/2011			08/26/2011
	23:00	20:00			20:00	23:00	20:00			20:00
Minimum*	1.00	1169	0.00	N/A	1169	0.00	343	0.00	N/A	343
	08/26/2011	08/26/2011	08/26/2011		08/26/2011	08/26/2011	08/26/2011	08/26/2011		08/26/2011
	23:00	7:00	23:00		7:00	4:00	5:00	23:00		5:00
Total*	24.00	37131	0.00	0	37131	18.23	28137	0.00	0	28137

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/27/2011 00:00	1.00	1235	0.00	N/A	1235	0.32	783	0.00	N/A	783
08/27/2011 01:00	1.00	1484	0.00	N/A	1484	0.00	N/A	0.00	N/A	N/A
08/27/2011 02:00	1.00	1591	0.00	N/A	1591	0.00	N/A	0.00	N/A	N/A
08/27/2011 03:00	1.00	1519	0.00	N/A	1519	0.00	N/A	0.00	N/A	N/A
08/27/2011 04:00	1.00	1489	0.00	N/A	1489	0.00	N/A	0.00	N/A	N/A
08/27/2011 05:00	1.00	1548	0.00	N/A	1548	0.17	261	0.00	N/A	261
08/27/2011 06:00	1.00	1477	0.00	N/A	1477	1.00	844	0.00	N/A	844
08/27/2011 07:00	1.00	1210	0.00	N/A	1210	1.00	1202	0.00	N/A	1202
08/27/2011 08:00	1.00	1512	0.00	N/A	1512	1.00	1524	0.00	N/A	1524
08/27/2011 09:00	1.00	1694	0.00	N/A	1694	1.00	1699	0.00	N/A	1699
08/27/2011 10:00	1.00	1696	0.00	N/A	1696	1.00	1693	0.00	N/A	1693
08/27/2011 11:00	1.00	1691	0.00	N/A	1691	1.00	1686	0.00	N/A	1686
08/27/2011 12:00	1.00	1685	0.00	N/A	1685	1.00	1687	0.00	N/A	1687
08/27/2011 13:00	1.00	1685	0.00	N/A	1685	1.00	1681	0.00	N/A	1681
08/27/2011 14:00	1.00	1684	0.00	N/A	1684	1.00	1680	0.00	N/A	1680
08/27/2011 15:00	1.00	1683	0.00	N/A	1683	1.00	1684	0.00	N/A	1684
08/27/2011 16:00	1.00	1693	0.00	N/A	1693	1.00	1695	0.00	N/A	1695
08/27/2011 17:00	1.00	1697	0.00	N/A	1697	1.00	1705	0.00	N/A	1705
08/27/2011 18:00	1.00	1697	0.00	N/A	1697	1.00	1707	0.00	N/A	1707
08/27/2011 19:00	1.00	1699	0.00	N/A	1699	1.00	1710	0.00	N/A	1710
08/27/2011 20:00	1.00	1701	0.00	N/A	1701	1.00	1713	0.00	N/A	1713
08/27/2011 21:00	1.00	1691	0.00	N/A	1691	1.00	1702	0.00	N/A	1702
08/27/2011 22:00	1.00	1363	0.00	N/A	1363	1.00	1371	0.00	N/A	1371
08/27/2011 23:00	1.00	1174	0.00	N/A	1174	1.00	1151	0.00	N/A	1151
Daily Average*	1.00	1567	0.00	N/A	1567	0.77	1459	0.00	N/A	1459
Maximum*	1.00	1701	0.00	N/A	1701	1.00	1713	0.00	N/A	1713
	08/27/2011	08/27/2011			08/27/2011	08/27/2011	08/27/2011			08/27/2011
	23:00	20:00			20:00	23:00	20:00			20:00
Minimum*	1.00	1174	0.00	N/A	1174	0.00	261	0.00	N/A	261
	08/27/2011	08/27/2011	08/27/2011		08/27/2011	08/27/2011	08/27/2011	08/27/2011		08/27/2011
	23:00	23:00	23:00		23:00	4:00	5:00	23:00		5:00
Total*	24.00	37598	0.00	0	37598	18.49	29178	0.00	0	29178

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/28/2011 00:00	1.00	1382	0.00	N/A	1382	0.33	767	0.00	N/A	767
08/28/2011 01:00	1.00	1643	0.00	N/A	1643	0.00	N/A	0.00	N/A	N/A
08/28/2011 02:00	1.00	1596	0.00	N/A	1596	0.00	N/A	0.00	N/A	N/A
08/28/2011 03:00	1.00	1199	0.00	N/A	1199	0.00	N/A	0.00	N/A	N/A
08/28/2011 04:00	1.00	1440	0.00	N/A	1440	0.00	N/A	0.00	N/A	N/A
08/28/2011 05:00	1.00	1389	0.00	N/A	1389	0.10	154	0.00	N/A	154
08/28/2011 06:00	1.00	1111	0.00	N/A	1111	1.00	775	0.00	N/A	775
08/28/2011 07:00	1.00	1166	0.00	N/A	1166	1.00	1158	0.00	N/A	1158
08/28/2011 08:00	1.00	1258	0.00	N/A	1258	1.00	1260	0.00	N/A	1260
08/28/2011 09:00	1.00	1491	0.00	N/A	1491	1.00	1506	0.00	N/A	1506
08/28/2011 10:00	1.00	1589	0.00	N/A	1589	1.00	1602	0.00	N/A	1602
08/28/2011 11:00	1.00	1654	0.00	N/A	1654	1.00	1667	0.00	N/A	1667
08/28/2011 12:00	1.00	1569	0.00	N/A	1569	1.00	1581	0.00	N/A	1581
08/28/2011 13:00	1.00	1678	0.00	N/A	1678	1.00	1682	0.00	N/A	1682
08/28/2011 14:00	1.00	1688	0.00	N/A	1688	1.00	1700	0.00	N/A	1700
08/28/2011 15:00	1.00	1692	0.00	N/A	1692	1.00	1702	0.00	N/A	1702
08/28/2011 16:00	1.00	1693	0.00	N/A	1693	1.00	1694	0.00	N/A	1694
08/28/2011 17:00	1.00	1699	0.00	N/A	1699	1.00	1701	0.00	N/A	1701
08/28/2011 18:00	1.00	1700	0.00	N/A	1700	1.00	1709	0.00	N/A	1709
08/28/2011 19:00	1.00	1702	0.00	N/A	1702	1.00	1710	0.00	N/A	1710
08/28/2011 20:00	1.00	1670	0.00	N/A	1670	1.00	1680	0.00	N/A	1680
08/28/2011 21:00	1.00	1702	0.00	N/A	1702	1.00	1713	0.00	N/A	1713
08/28/2011 22:00	1.00	1609	0.00	N/A	1609	1.00	1621	0.00	N/A	1621
08/28/2011 23:00	1.00	1246	0.00	N/A	1246	1.00	1203	0.00	N/A	1203
Daily Average*	1.00	1524	0.00	N/A	1524	0.77	1429	0.00	N/A	1429
Maximum*	1.00	1702	0.00	N/A	1702	1.00	1713	0.00	N/A	1713
	08/28/2011	08/28/2011			08/28/2011	08/28/2011	08/28/2011			08/28/2011
	23:00	21:00			21:00	23:00	21:00			21:00
Minimum*	1.00	1111	0.00	N/A	1111	0.00	154	0.00	N/A	154
	08/28/2011	08/28/2011	08/28/2011		08/28/2011	08/28/2011	08/28/2011	08/28/2011		08/28/2011
	23:00	6:00	23:00		6:00	4:00	5:00	23:00		5:00
Total*	24.00	36566	0.00	0	36566	18.43	28585	0.00	0	28585

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:23

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/29/2011 00:00	1.00	1371	0.00	N/A	1371	0.22	687	0.00	N/A	687
08/29/2011 01:00	1.00	1227	0.00	N/A	1227	0.00	N/A	0.00	N/A	N/A
08/29/2011 02:00	1.00	1178	0.00	N/A	1178	0.00	N/A	0.00	N/A	N/A
08/29/2011 03:00	1.00	1151	0.00	N/A	1151	0.00	N/A	0.00	N/A	N/A
08/29/2011 04:00	1.00	1211	0.00	N/A	1211	0.00	N/A	0.00	N/A	N/A
08/29/2011 05:00	1.00	1249	0.00	N/A	1249	0.08	114	0.00	N/A	114
08/29/2011 06:00	1.00	1323	0.00	N/A	1323	1.00	763	0.00	N/A	763
08/29/2011 07:00	1.00	1185	0.00	N/A	1185	1.00	1178	0.00	N/A	1178
08/29/2011 08:00	1.00	1296	0.00	N/A	1296	1.00	1295	0.00	N/A	1295
08/29/2011 09:00	1.00	1673	0.00	N/A	1673	1.00	1680	0.00	N/A	1680
08/29/2011 10:00	1.00	1709	0.00	N/A	1709	1.00	1716	0.00	N/A	1716
08/29/2011 11:00	1.00	1708	0.00	N/A	1708	1.00	1714	0.00	N/A	1714
08/29/2011 12:00	1.00	1722	0.00	N/A	1722	1.00	1729	0.00	N/A	1729
08/29/2011 13:00	1.00	1735	0.00	N/A	1735	1.00	1742	0.00	N/A	1742
08/29/2011 14:00	1.00	1738	0.00	N/A	1738	1.00	1746	0.00	N/A	1746
08/29/2011 15:00	1.00	1743	0.00	N/A	1743	1.00	1750	0.00	N/A	1750
08/29/2011 16:00	1.00	1742	0.00	N/A	1742	1.00	1749	0.00	N/A	1749
08/29/2011 17:00	1.00	1740	0.00	N/A	1740	1.00	1749	0.00	N/A	1749
08/29/2011 18:00	1.00	1740	0.00	N/A	1740	1.00	1748	0.00	N/A	1748
08/29/2011 19:00	1.00	1741	0.00	N/A	1741	1.00	1746	0.00	N/A	1746
08/29/2011 20:00	1.00	1734	0.00	N/A	1734	1.00	1741	0.00	N/A	1741
08/29/2011 21:00	1.00	1732	0.00	N/A	1732	1.00	1740	0.00	N/A	1740
08/29/2011 22:00	1.00	1574	0.00	N/A	1574	1.00	1583	0.00	N/A	1583
08/29/2011 23:00	1.00	1353	0.00	N/A	1353	1.00	1359	0.00	N/A	1359
Daily Average*	1.00	1524	0.00	N/A	1524	0.76	1476	0.00	N/A	1476
Maximum*	1.00	1743	0.00	N/A	1743	1.00	1750	0.00	N/A	1750
	08/29/2011	08/29/2011			08/29/2011	08/29/2011	08/29/2011			08/29/2011
	23:00	15:00			15:00	23:00	15:00			15:00
Minimum*	1.00	1151	0.00	N/A	1151	0.00	114	0.00	N/A	114
	08/29/2011	08/29/2011	08/29/2011		08/29/2011	08/29/2011	08/29/2011	08/29/2011		08/29/2011
	23:00	3:00	23:00		3:00	4:00	5:00	23:00		5:00
Total*	24.00	36575	0.00	0	36575	18.30	29529	0.00	0	29529

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:24

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/30/2011 00:00	1.00	1400	0.00	N/A	1400	1.00	1408	0.00	N/A	1408
08/30/2011 01:00	1.00	1122	0.00	N/A	1122	1.00	1107	0.00	N/A	1107
08/30/2011 02:00	1.00	1109	0.00	N/A	1109	1.00	1091	0.00	N/A	1091
08/30/2011 03:00	1.00	1151	0.00	N/A	1151	1.00	1138	0.00	N/A	1138
08/30/2011 04:00	1.00	1133	0.00	N/A	1133	1.00	1118	0.00	N/A	1118
08/30/2011 05:00	1.00	1121	0.00	N/A	1121	1.00	1106	0.00	N/A	1106
08/30/2011 06:00	1.00	1149	0.00	N/A	1149	1.00	1136	0.00	N/A	1136
08/30/2011 07:00	1.00	1088	0.00	N/A	1088	1.00	1072	0.00	N/A	1072
08/30/2011 08:00	1.00	1141	0.00	N/A	1141	1.00	1129	0.00	N/A	1129
08/30/2011 09:00	1.00	1237	0.00	N/A	1237	1.00	1235	0.00	N/A	1235
08/30/2011 10:00	1.00	1557	0.00	N/A	1557	1.00	1570	0.00	N/A	1570
08/30/2011 11:00	1.00	1693	0.00	N/A	1693	1.00	1704	0.00	N/A	1704
08/30/2011 12:00	1.00	1721	0.00	N/A	1721	1.00	1729	0.00	N/A	1729
08/30/2011 13:00	1.00	1691	0.00	N/A	1691	1.00	1701	0.00	N/A	1701
08/30/2011 14:00	1.00	1674	0.00	N/A	1674	1.00	1684	0.00	N/A	1684
08/30/2011 15:00	1.00	1641	0.00	N/A	1641	1.00	1653	0.00	N/A	1653
08/30/2011 16:00	1.00	1670	0.00	N/A	1670	1.00	1681	0.00	N/A	1681
08/30/2011 17:00	1.00	1709	0.00	N/A	1709	1.00	1718	0.00	N/A	1718
08/30/2011 18:00	1.00	1710	0.00	N/A	1710	1.00	1721	0.00	N/A	1721
08/30/2011 19:00	1.00	1712	0.00	N/A	1712	1.00	1723	0.00	N/A	1723
08/30/2011 20:00	1.00	1480	0.00	N/A	1480	1.00	1490	0.00	N/A	1490
08/30/2011 21:00	1.00	1268	0.00	N/A	1268	1.00	1268	0.00	N/A	1268
08/30/2011 22:00	1.00	1169	0.00	N/A	1169	1.00	1035	0.00	N/A	1035
08/30/2011 23:00	1.00	1652	0.00	N/A	1652	0.03	618	0.00	N/A	618
Daily Average*	1.00	1417	0.00	N/A	1417	0.96	1368	0.00	N/A	1368
Maximum*	1.00	1721	0.00	N/A	1721	1.00	1729	0.00	N/A	1729
	08/30/2011	08/30/2011			08/30/2011	08/30/2011	08/30/2011			08/30/2011
	23:00	12:00			12:00	22:00	12:00			12:00
Minimum*	1.00	1088	0.00	N/A	1088	0.03	618	0.00	N/A	618
	08/30/2011	08/30/2011	08/30/2011		08/30/2011	08/30/2011	08/30/2011	08/30/2011		08/30/2011
	23:00	7:00	23:00		7:00	23:00	23:00	23:00		23:00
Total*	24.00	33998	0.00	0	33998	23.03	32835	0.00	0	32835

* Does not include Invalid Averaging Periods ("N/A")

Average Values Report
Generated: 9/27/2011 10:24

Company: Semiole Electric
Plant: 6697 N. County Road
City/St: Bowling Green , FL 33834
Source: CT1, CT2

Period Start: 8/1/2011 00:00
Period End: 8/31/2011 23:59
Validation Type: 40CFR75 Subpart B
Averaging Period: 1 hr
Type: Block Avg

Period Start:	Total 1GasHour 1=Gas	Total 1HI_Gas MB/Hr	Total 1OilHour 1=Oil	Total 1HI_Oil MB/Hr	Total 1HI_Total MB/Hr	Total 2GasHour 1=Gas	Total 2HI_Gas MB/Hr	Total 2OilHour 1=Oil	Total 2HI_Oil MB/Hr	Total 2HI_Total MB/Hr
08/31/2011 00:00	1.00	1315	0.00	N/A	1315	0.00	N/A	0.00	N/A	N/A
08/31/2011 01:00	1.00	1231	0.00	N/A	1231	0.00	N/A	0.00	N/A	N/A
08/31/2011 02:00	1.00	1214	0.00	N/A	1214	0.00	N/A	0.00	N/A	N/A
08/31/2011 03:00	1.00	1271	0.00	N/A	1271	0.00	N/A	0.00	N/A	N/A
08/31/2011 04:00	1.00	1348	0.00	N/A	1348	0.00	N/A	0.00	N/A	N/A
08/31/2011 05:00	1.00	1713	0.00	N/A	1713	0.00	N/A	0.00	N/A	N/A
08/31/2011 06:00	1.00	1737	0.00	N/A	1737	0.20	299	0.00	N/A	299
08/31/2011 07:00	1.00	1518	0.00	N/A	1518	1.00	847	0.00	N/A	847
08/31/2011 08:00	1.00	1234	0.00	N/A	1234	1.00	1230	0.00	N/A	1230
08/31/2011 09:00	1.00	1340	0.00	N/A	1340	1.00	1348	0.00	N/A	1348
08/31/2011 10:00	1.00	1611	0.00	N/A	1611	1.00	1629	0.00	N/A	1629
08/31/2011 11:00	1.00	1653	0.00	N/A	1653	1.00	1666	0.00	N/A	1666
08/31/2011 12:00	1.00	1726	0.00	N/A	1726	1.00	1737	0.00	N/A	1737
08/31/2011 13:00	1.00	1713	0.00	N/A	1713	1.00	1722	0.00	N/A	1722
08/31/2011 14:00	1.00	1712	0.00	N/A	1712	1.00	1721	0.00	N/A	1721
08/31/2011 15:00	1.00	1709	0.00	N/A	1709	1.00	1720	0.00	N/A	1720
08/31/2011 16:00	1.00	1710	0.00	N/A	1710	1.00	1721	0.00	N/A	1721
08/31/2011 17:00	1.00	1712	0.00	N/A	1712	1.00	1724	0.00	N/A	1724
08/31/2011 18:00	1.00	1715	0.00	N/A	1715	1.00	1726	0.00	N/A	1726
08/31/2011 19:00	1.00	1716	0.00	N/A	1716	1.00	1725	0.00	N/A	1725
08/31/2011 20:00	1.00	1609	0.00	N/A	1609	1.00	1616	0.00	N/A	1616
08/31/2011 21:00	1.00	1172	0.00	N/A	1172	1.00	1160	0.00	N/A	1160
08/31/2011 22:00	1.00	1422	0.00	N/A	1422	0.37	846	0.00	N/A	846
08/31/2011 23:00	1.00	1233	0.00	N/A	1233	0.00	N/A	0.00	N/A	N/A
Daily Average*	1.00	1514	0.00	N/A	1514	0.65	1437	0.00	N/A	1437
Maximum*	1.00	1737	0.00	N/A	1737	1.00	1737	0.00	N/A	1737
	08/31/2011	08/31/2011			08/31/2011	08/31/2011	08/31/2011			08/31/2011
	23:00	6:00			6:00	21:00	12:00			12:00
Minimum*	1.00	1172	0.00	N/A	1172	0.00	299	0.00	N/A	299
	08/31/2011	08/31/2011	08/31/2011		08/31/2011	08/31/2011	08/31/2011	08/31/2011		08/31/2011
	23:00	21:00	23:00		21:00	23:00	6:00	23:00		6:00
Total*	24.00	36334	0.00	0	36334	15.57	24437	0.00	0	24437
Final Average*	0.98	1494	0.00	476	1493	0.72	1440	0.00	348	1436
Maximum*	1.00	1775	0.83	478	1775	1.00	1750	1.00	511	1750
	08/31/2011	08/02/2011	08/23/2011	08/23/2011	08/02/2011	08/31/2011	08/29/2011	08/24/2011	08/24/2011	08/29/2011
	23:00	7:00	22:00	23:00	7:00	21:00	15:00	22:00	22:00	15:00
Minimum*	0.00	1	0.00	473	1	0.00	114	0.00	239	114
	08/24/2011	08/20/2011	08/31/2011	08/23/2011	08/20/2011	08/31/2011	08/29/2011	08/31/2011	08/24/2011	08/29/2011
	6:00	6:00	23:00	22:00	6:00	23:00	5:00	23:00	23:00	5:00
Total*	726.08	1090262	1.36	951	1089821	534.71	388863	1.33	1044	389111

* Does not include Invalid Averaging Periods ("N/A")