

Hillsborough County Resource Recovery 9/30/2010 Inspection Records Data

MWC UNIT#	Date	Max Steam Flow (k#/hr)	Max B/H Temp (°F)	Avg. Carbon Rate (lbs/hr)
Unit 1	8/31/2010	86.3	308	17.7
	8/24/2010	94.5	307	21
	6/26/2010	92.4	307	18.4
	6/12/2010	86.8	307	18.8
	2/27/2010	100	305	18.4
	2/14/2010	93.6	309	20.2
	8/31/2010	90.7	307	17.4
	8/24/2010	Offline - Planned Outage		
8/13/2010	98.7	304	18.8	
Unit 2	6/20/2010	Malfunction - Notified Department & Report Excess Emissions		
	6/19/2010	86.2	302	18.7
	6/5/2010	95	299	18.7
	2/25/2010	99.3	300	24.1
	2/21/2010	Planned Outage - 2/12/2010-2/25/2010		
	2/12/2010	94.7	300	20.1
Unit 3	8/31/2010	91.2	306	17.7
	8/16/2010	96.6	305	18.5
	6/30/2010	91.9	305	18.4
	6/20/2010	97.1	300	18.8
	2/19/2010	93.9	305	18.2
	2/5/2010	94.3	305	20
Unit 4	8/31/2010	156.2	305	27.5
	8/8/2010	172.8	305	27.6
	6/24/2010	168.9	306	27.6
	6/14/2010	186.5	305	27.5
	2/20/2010	172.7	306	27.5
	2/10/2010	172.8	305	27.5