

TABLE 1. CONTINUOUS EMISSION MONITOR CERTIFICATION
 VERO BEACH MUNICIPAL POWER PLANT
 UNIT 4
 VERO BEACH, FLORIDA
 JULY 20, 2005

RUN NO.	START TIME	END TIME	NOx LB/MMBTU		
			RM	M	DIFF
1	10:00	10:21	0.103	0.104	-0.001
2	10:28	10:49	0.106	0.107	-0.001
3	10:58	11:19	0.106	0.107	-0.001
4	11:27	11:48	0.108	0.108	0.000
5	11:55	12:16	-0.001		-0.001
6		0:21	#DIV/0!		#DIV/0!
7		0:21	#DIV/0!		#DIV/0!
8		0:21	#DIV/0!		#DIV/0!
9		0:21	#DIV/0!		#DIV/0!
AVERAGE:			#DIV/0!	0.1065	#DIV/0!

TOTAL DATA POINTS USED:	9
T-VALUE:	2.306
STANDARD DEVIATION:	#DIV/0!
CONFIDENCE COEFFICIENT:	#DIV/0!
RELATIVE ACCURACY:	#DIV/0!
BIAS ADJUSTMENT FACTOR:	#DIV/0!

TABLE 1. CONTINUOUS EMISSION MONITOR CERTIFICATION

VERO BEACH MUNICIPAL POWER PLANT
 UNIT 3
 VERO BEACH, FLORIDA
 7/19/2005

<u>RUN NO.</u>	<u>START TIME</u>	<u>END TIME</u>	<u>NOx LB/MMBTU</u>		
			<u>RM</u>	<u>M</u>	<u>DIFF</u>
1	8:59	9:20	0.136	0.142	-0.006
2	9:28	9:49	0.142	0.148	-0.006
3	9:58	10:19	0.138	0.144	-0.006
4	10:27	10:48	0.135	0.140	-0.005
5	10:56	11:17	0.135	0.141	-0.006
6	11:24	11:45	0.133	0.139	-0.006
7	11:56	12:17	0.132	0.137	-0.005
8	12:25	12:46	0.132	0.137	-0.005
9	12:55	13:16	<u>0.130</u>	<u>0.135</u>	<u>-0.005</u>
AVERAGE:			0.1348	0.1403	-0.0056

TOTAL DATA POINTS USED:	9
T-VALUE:	2.306
STANDARD DEVIATION:	0.0005
CONFIDENCE COEFFICIENT:	0.0004
RELATIVE ACCURACY:	4.42
BIAS ADJUSTMENT FACTOR:	NA