

General Average Report

Reporting Period: 07/20/2005 to 07/20/2005

Site Name: UNIT4

Time of Report: 07/20/05 12:18

Data Averaging Type: 1m

Rolling Average Interval: 1

Date	Time	LOADMW (MW )	RGASFLOW (KSCFH )	O2 (PCT )	GASGCV (BTU/SCF )	NOX#/MM (LB/MMBTU)	HEATIN (MMBTU/HR)
07/20/05	11:55	55.3	605.732	3.0	1059.0	0.108	641.5
	11:56	55.4	605.584	3.0	1059.0	0.109	641.5
	11:57	55.4	605.513	3.0	1059.0	0.110	641.3
	11:58	55.4	605.873	3.0	1059.0	0.109	641.7
	11:59	55.4	606.232	2.9	1059.0	0.108	642.0
	12:00	55.3	606.624	3.0	1059.0	0.109	642.5
	12:01	55.3	606.735	2.9	1059.0	0.107	642.5
	12:02	55.3	606.770	2.9	1059.0	0.108	642.6
	12:03	55.4	606.481	3.0	1059.0	0.109	642.3
	12:04	55.4	605.952	3.0	1059.0	0.108	641.8
	12:05	55.4	605.365	3.0	1059.0	0.108	641.2
	12:06	55.3	606.048	3.0	1059.0	0.108	641.7
	12:07	55.3	606.323	3.0	1059.0	0.108	642.1
	12:08	55.3	606.251	3.0	1059.0	0.108	642.2
	12:09	55.3	606.697	3.0	1059.0	0.108	642.5
	12:10	55.3	606.714	3.0	1059.0	0.107	642.7
	12:11	55.3	606.749	2.9	1059.0	0.107	642.6
	12:12	55.3	606.362	3.0	1059.0	0.108	642.3
	12:13	55.3	605.694	3.0	1059.0	0.108	641.5
	12:14	55.3	605.578	3.0	1059.0	0.109	641.3
	12:15	55.4	605.460	3.0	1059.0	0.109	641.2

*Row 5*  
*Q*

---

Average =	55.3	606.130	3.0	1059.0	0.108	642.0
Maximum =	55.4	606.770	3.0	1059.0	0.110	642.7
Minimum =	55.3	605.365	2.9	1059.0	0.107	641.2
Possible Values =	21	21	21	21	21	21
Included Values =	21	21	21	21	21	21
Total =	1162.2	12728.737	62.5	22239.2	2.273	13481.0

- \* - excluded values (missing, OOC, invalid, suspect)
- < - missing
- T - out-of-control
- I - invalid
- S - suspect
- H - exceedance
- F - stack not operating
- B - invalid (PADER)
- U - missing data substituted
- 999 - missing value
- 888 - value could not be calculated