

MDC Version 4.1  
 Monthly Summary Report  
 VERO BEACH MUNICIPAL (693)

Unit ID: 3

YEAR: 2003

QUARTER: 2

Totals for All Hours:

Number of Operating Hrs:	99
Operating Time (hrs):	89.54
Reported HI (mmBtu):	21992
Calculated HI (mmBtu):	21992
Reported SO2 (tons):	1.9
Calculated SO2 (tons):	1.9
Reported NOx Rate (lb/mmBtu):	0.152
Calculated NOx Rate (lb/mmBtu):	0.152
Reported NOx Mass (tons):	Not Rptd
Calculated NOx Mass (tons):	2.0
Reported CO2 Mass (tons):	1499.2

MDC Version 4.1  
Monthly Summary Report  
VERO BEACH MUNICIPAL (693)

Unit ID: 4

YEAR: 2003

QUARTER: 2

Totals for All Hours:

Number of Operating Hrs:	173
Operating Time (hrs):	157.14
Reported HI (mmBtu):	55710
Calculated HI (mmBtu):	55709
Reported SO2 (tons):	5.8
Calculated SO2 (tons):	5.8
Reported NOx Rate (lb/mmBtu):	0.146
Calculated NOx Rate (lb/mmBtu):	0.146
Reported NOx Mass (tons):	Not Rptd
Calculated NOx Mass (tons):	4.7
Reported CO2 Mass (tons):	3810.2

MDC Version 4.1  
Monthly Summary Report  
VERO BEACH MUNICIPAL (693)

Unit ID: \*\*5

YEAR: 2003

QUARTER: 2

Totals for All Hours:

Number of Operating Hrs:	216	
Operating Time (hrs):	194.96	
Reported HI (mmBtu):	69064	
Calculated HI (mmBtu):	69064	
Reported SO2 (tons):	0.0	
Calculated SO2 (tons):	0.0	
Reported NOx Rate (lb/mmBtu):	0.030	
Calculated NOx Rate (lb/mmBtu):	0.030	
Reported NOx Mass (tons):		Not Rptd
Calculated NOx Mass (tons):		1.0
Reported CO2 Mass (tons):		4138.7