

CUTRALE CITRUS JUICES USA, INC.

LEESBURG FACILITY

COGENERATION SYSTEM

DATE 3/2/12

TIME	KW	TURBINE GAS, MCFH	INLET TEMP, °F	RPM %	T5 TEMP, °F	#2 BOILER GAS METER
1138	3920	53	79	100	1249	231413
START → 1147	3882	53	80	100	1249	231422
1207	3903	53	81	100	1250	
1222	3895	53	81	99.9	1251	
1245	3907	53	82	100	1250	
1300	3862	53	82	100	1249	231504
AVG						

x1000

#2 BOILER
GAS METER