

COVAITA LAKE

Sulfur Dioxide @ 7% O₂

Exit	Unit 1	Unit 2
1 min.	10.0	11.1
15 min	8.1	9.3
1 hr	10.0	6.3
4 hr 100ppm	13	7
1 hr B/B	6	6
4 hr B/B	10	6

Sulfur Dioxide @ 7% O₂ Rem. Eff.

Period	Limit	Unit 1	Unit 2
24 hr Geo	<75%	96.2	95.5
24 hr geo B/B		100	99

SDA Outlet Temp (PSD-127)

Period	Limit	Unit 1	Unit 2
1 min.		294.0	297.0
15 min		293.7	294.9
1 hr		293.6	295.7
4 hr 317' F		294	296
4 hr B/B		294	295.7

Nitrogen Oxides @ 7% O₂

Period	Limit	Unit 1	Unit 2
1 min.		184.4	205.5
15 min		188.2	194.8
1 hr		181	185
24 hr 205ppm		179	184
24 hr B/B		179	185

Sulfur Dioxide @ 7% O₂

Period	Limit	Unit 1	Unit 2
1 min.		0.0	0.0
15 min		0.0	0.0
1 hr		0.0	0.0
24 hr geo 29 ppm		1	1
24 hr geo B/B		1	1

Steam Flow (PSD-127)

Period	Limit	Unit 1	Unit 2
1 min.		65.0	64.0
15 min		65.6	63.7
1 hr		65.1	64.5
4 hr 69Kbs/hr		64.8	64.4
4 hr B/B		65	64

O₂ (1 min)

Period	Limit	Unit 1	Unit 2
Econ		10.0	10.2
Stack		11.4	11.7

Carbon Feed Rate

Period	Limit	Unit 1	Unit 2
1 min.		11.3	11.3
15 min		11.3	11.3
1 hr 12 lbs/hr		11.3	11.3

Opacity

Period	Limit	Unit 1	Unit 2
1 min	4%	0	1
6 min	10%	0	1

U1Boiler Status	OnLine	1 min Raw CO	3
Feed Chute	Opened	15 min Raw CO BB	3
BLR On/Off	ON-LINE	15 min Raw CO	4
O ₂ e	10.2	CO HI Alarm	Normal

U2 Boiler Status	OnLine	1 min Raw CO	15
Feed Chute	Opened	15 min Raw CO BB	17
BLR On/Off	DN-LINE	15 min Raw CO	17
O ₂ e	10.8	CO HI Alarm	Normal

Data Summary Report

Unit 1 run 1

Covanta ENERGY GROUP, INC.

Company: Covanta of Lake
3830 ROGERS INDUSTRIAL PARK ROAD
OKAHUMPKA, FL 34762

■■■■■■■■
Continuous Emissions Monitoring System

Data Group: U1-1MIN C/R DATA
Report Name: RATA 1
Start of Report: 01/18/2006 08:29
End of Report: 01/18/2006 08:53

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 08:29	9.3	24.0	9.6	11.0	0.0	176.9	11.2
01/18/2006 08:30	9.7	23.6	9.9	11.2	0.0	164.8	11.5
01/18/2006 08:31	10.0	20.4	11.5	11.5	0.0	165.6	11.8
01/18/2006 08:32	10.1	20.6	12.9	11.5	0.0	164.1	14.8
01/18/2006 08:33	10.1	20.6	11.6	11.5	0.0	173.0	14.8
01/18/2006 08:34	10.2	22.1	9.1	11.5	0.0	177.4	11.8
01/18/2006 08:35	9.9	20.2	8.8	11.4	0.0	196.1	10.2
01/18/2006 08:36	9.9	20.2	8.8	11.4	0.0	196.1	10.2
01/18/2006 08:37	9.8	20.0	8.8	11.3	0.0	201.3	11.6
01/18/2006 08:38	9.8	20.0	8.8	11.3	0.0	201.3	11.6
01/18/2006 08:39	9.9	24.0	8.8	11.2	0.0	184.9	10.0
01/18/2006 08:40	9.7	21.1	7.4	11.2	0.0	193.5	8.6
01/18/2006 08:41	10.0	21.7	8.9	11.4	0.0	184.4	8.8
01/18/2006 08:42	10.3	21.0	11.8	11.6	0.0	170.4	10.5
01/18/2006 08:43	9.8	20.0	11.3	11.1	0.0	170.2	12.8
01/18/2006 08:44	9.7	18.6	8.7	11.1	0.0	180.1	9.9
01/18/2006 08:45	10.1	19.3	12.9	11.4	0.0	177.0	11.7
01/18/2006 08:46				11.0	0.0	186.7	12.6
01/18/2006 08:47				11.4	0.0	194.6	8.8
01/18/2006 08:48	10.5<	21.4<	10.7<	11.7	0.0	181.3	10.6
01/18/2006 08:49	10.3	19.7	10.5	11.6	0.0	179.4	10.5
01/18/2006 08:50	10.7	19.1	12.3	11.9	0.0	168.3	12.4
01/18/2006 08:51	10.4	19.9	14.6	11.6	0.0	158.4	13.5
01/18/2006 08:52	9.9	17.7	10.1	11.3	0.0	173.8	13.0
Period Average =	10.0	20.7	10.4	11.4	0.0	180.0	11.4
Period Max Value =	10.7	24.0	14.6	11.9	0.0	201.3	14.8
Period Min Value =	9.3	17.7	7.4	11.0	0.0	158.4	8.6
Period Totals =	2.2010E+2	4.5520E+2	2.2780E+2	2.7310E+2	0.0000E+0	4.3196E+3	2.7320E+2
Period % Recovery =	91.7	91.7	91.7	100.0	100.0	100.0	100.0
RM=	9.8	19.8	10.8	11.1	0	182.8	10.8

Data Summary Report

Unit 1 run 2

Covanta ENERGY GROUP, INC.



Continuous Emissions Monitoring System

Company: Covanta of Lake
3830 ROGERS INDUSTRIAL PARK ROAD
OKAHUMPKA, FL 34762

Data Group: U1-1MIN C/R DATA
Report Name: RATA 1
Start of Report: 01/18/2006 09:07
End of Report: 01/18/2006 09:30

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 09:07	10.4	15.9	13.2	11.6	0.0	198.8	13.5
01/18/2006 09:08	10.2	15.6	11.7	11.4	0.0	196.1	11.7
01/18/2006 09:09	10.0	17.9	11.5	11.2	0.0	192.0	11.5
01/18/2006 09:10	9.6	17.2	11.1	11.0	0.0	189.5	12.6
01/18/2006 09:11	10.3	17.0	13.1	11.5	0.0	167.1	13.3
01/18/2006 09:12	10.1	16.7	11.6	11.4	0.0	169.7	13.2
01/18/2006 09:13	10.6	17.5	12.1	11.7	0.0	157.1	13.6
01/18/2006 09:14	10.2	22.1	11.7	11.4	0.0	160.9	11.7
01/18/2006 09:15	9.9	21.5	8.8	11.2	0.0	179.1	11.5
01/18/2006 09:16	10.5	22.7	12.0	11.7	0.0	176.8	12.1
01/18/2006 09:17	10.4	22.5	14.6	11.6	0.0	174.9	13.5
01/18/2006 09:18	10.4	19.9	14.6	11.6	0.0	185.3	17.9
01/18/2006 09:19	10.0	21.7	12.8	11.2	0.0	207.8	14.3
01/18/2006 09:20	9.9	20.2	10.1	11.3	0.0	223.0	11.6
01/18/2006 09:21	10.4	19.9	10.6	11.7	0.0	210.0	10.6
01/18/2006 09:22	10.9	22.2	16.7	12.0	0.0	179.6	15.6
01/18/2006 09:23	10.4	25.2	17.2	11.5	0.0	174.5	17.7
01/18/2006 09:24	10.2	24.7	11.7	11.4	0.0	185.8	14.6
01/18/2006 09:25	9.9	26.5	10.1	11.2	0.0	197.8	12.9
01/18/2006 09:26	9.9	29.1	11.4	11.1	0.0	184.4	12.8
01/18/2006 09:27	9.0	58.4	106.3	10.2	0.0	168.9	88.3
01/18/2006 09:28	9.1	27.1	9.4	10.8	0.0	191.3	30.3
01/18/2006 09:29	10.6	25.6	14.8	11.8	0.0	160.4	15.3
01/18/2006 09:30	10.4	26.5	11.9	11.5	0.0	156.7	16.3
Period Average =	10.1	23.1	16.2	11.4	0.0	182.8	17.4
Period Max Value =	10.9	58.4	106.3	12.0	0.0	223.0	88.3
Period Min Value =	9.0	15.6	8.8	10.2	0.0	156.7	10.6
Period Totals =	2.4330E+2	5.5360E+2	3.8900E+2	2.7300E+2	0.0000E+0	4.3875E+3	4.1640E+2
Period % Recovery =	100.0	100.0	100.0	100.0	100.0	100.0	100.0
RM=	9.9	23.4	15.7	11.1	.4	184.8	15.7

Data Summary Report

Unit 1 run 3

Covanta ENERGY GROUP, INC.

Company: Covanta of Lake
3830 ROGERS INDUSTRIAL PARK ROAD
OKAHUMPKA, FL 34762

Continuous Emissions Monitoring System

Data Group: U1-1MIN C/R DATA
Report Name: RATA 1
Start of Report: 01/18/2006 09:46
End of Report: 01/18/2006 10:09

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500

01/18/2006 09:46				11.5	0.0	187.8	10.4
01/18/2006 09:47				11.4	0.0	180.0	11.7
01/18/2006 09:48	10.1<	19.3<	12.9<	11.2	0.0	172.0	12.9
01/18/2006 09:49	9.8	18.8	10.0	11.1	0.0	185.8	11.3
01/18/2006 09:50	10.3	21.0	10.5	11.5	0.0	170.1	11.8
01/18/2006 09:51	10.2	20.8	9.1	11.4	0.0	162.4	11.7
01/18/2006 09:52	9.1	27.1	7.1	10.1	0.0	173.8	10.3
01/18/2006 09:53	8.5	21.3	2.2	10.2	0.0	218.2	5.2
01/18/2006 09:54	9.9	19.0	3.8	11.3	0.0	208.5	5.8
01/18/2006 09:55	11.0	23.9	7.0	12.2	0.0	171.0	8.0
01/18/2006 09:56	11.7	30.2	13.6	12.8	0.0	125.3	15.4
01/18/2006 09:57	12.0	32.8	15.6	13.0	0.0	107.3	15.8
01/18/2006 09:58	11.4	41.0	13.2	12.2	0.0	108.6	16.0
01/18/2006 09:59	10.8	35.8	6.9	12.1	0.0	162.7	9.5
01/18/2006 10:00	11.0	39.3	8.4	11.9	0.0	169.9	10.8
01/18/2006 10:01	10.0	33.2	6.4	11.1	0.0	212.8	9.9
01/18/2006 10:02	9.4	31.4	3.6	10.7	0.0	222.1	5.5
01/18/2006 10:03	9.6	30.8	2.5	10.9	0.0	212.7	4.2
01/18/2006 10:04	10.2	29.9	3.9	11.6	0.0	197.3	4.5
01/18/2006 10:05	10.8	28.9	4.1	12.0	0.0	170.2	6.2
01/18/2006 10:06	11.0	30.9	5.6	12.1	0.0	151.6	7.9
01/18/2006 10:07	10.5	29.4	6.7	11.6	0.0	158.4	9.0
01/18/2006 10:08	10.6	22.9	8.1	11.6	0.0	177.9	9.0
01/18/2006 10:09	9.8	21.3	3.8	11.1	0.0	208.5	7.1

Period Average =	10.4	27.7	7.5	11.5	0.0	175.6	9.6
Period Max Value =	12.0	41.0	15.6	13.0	0.0	222.1	16.0
Period Min Value =	8.5	18.8	2.2	10.1	0.0	107.3	4.2
Period Totals =	2.2770E+2	6.0900E+2	1.6500E+2	2.7660E+2	0.0000E+0	4.2149E+3	2.2990E+2
Period % Recovery =	95.7	95.7	95.7	100.0	100.0	100.0	100.0
RM=	10.0	23.4	8.9	11.2	.52	181.2	8.9

Data Summary Report

Unit 1 run 4

Covanta ENERGY GROUP, INC.

Company: Covanta of Lake
 3830 ROGERS INDUSTRIAL PARK ROAD
 OKAHUMPKA, FL 34762

Continuous Emissions Monitoring System

Data Group: U1-1MIN C/R DATA
 Report Name: RATA 1
 Start of Report: 01/18/2006 10:24
 End of Report: 01/18/2006 10:47

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 10:24	11.6	13.5	16.4	12.6	0.0	157.4	20.1
01/18/2006 10:25	11.2	12.9	15.8	12.1	0.0	169.0	17.4
01/18/2006 10:26	11.0	9.8	11.2	12.1	0.0	192.7	14.2
01/18/2006 10:27	10.8	8.3	13.8	11.8	0.0	190.9	15.3
01/18/2006 10:28	10.0	10.2	8.9	11.2	0.0	206.4	11.5
01/18/2006 10:29	10.1	9.0	9.0	11.4	0.0	223.9	11.7
01/18/2006 10:30	10.4	7.9	10.6	11.6	0.0	216.7	12.0
01/18/2006 10:31	10.0	7.7	8.9	11.2	0.0	202.1	11.5
01/18/2006 10:32	10.0	8.9	7.7	11.3	0.0	196.9	10.1
01/18/2006 10:33	10.1	7.7	10.3	11.4	0.0	181.4	11.7
01/18/2006 10:34	10.5	6.7	9.4	11.8	0.0	172.6	12.2
01/18/2006 10:35	10.8	6.9	8.3	12.1	0.0	173.8	9.5
01/18/2006 10:36	11.3	5.8	14.5	12.4	0.0	152.1	14.7
01/18/2006 10:37	11.0	8.4	14.0	12.1	0.0	153.2	15.8
01/18/2006 10:38	10.7	10.9	13.6	11.6	0.0	145.0	14.9
01/18/2006 10:39	9.7	12.4	9.9	11.1	0.0	171.6	12.8
01/18/2006 10:40	9.7	13.7	9.9	11.0	0.0	171.3	12.6
01/18/2006 10:41	9.5	13.4	9.8	10.8	0.0	178.9	11.0
01/18/2006 10:42	8.9	13.9	9.3	10.3	0.0	190.1	10.5
01/18/2006 10:43	9.3	14.4	7.2	10.9	0.0	222.4	9.7
01/18/2006 10:44	9.8	15.0	7.5	11.2	0.0	199.2	10.0
01/18/2006 10:45	10.7	13.6	10.9	12.1	0.0	194.3	11.1
01/18/2006 10:46				12.1	0.0	151.6	17.4
01/18/2006 10:47				11.7	0.0	158.6	16.6
Period Average =	10.3	10.5	10.8	11.6	0.0	182.2	13.1
Period Max Value =	11.6	15.0	16.4	12.6	0.0	223.9	20.1
Period Min Value =	8.9	5.8	7.2	10.3	0.0	145.0	9.5
Period Totals =	2.2710E+2	2.3100E+2	2.3690E+2	2.7790E+2	0.0000E+0	4.3721E+3	3.1430E+2
Period % Recovery =	95.7	95.7	95.7	100.0	100.0	100.0	100.0
RM=	9.9	11.2	11.9	11.4	.63	186.1	11.9

Data Summary Report

Unit 1 run 5

Covanta ENERGY GROUP, INC.

Company: Covanta of Lake
 3830 ROGERS INDUSTRIAL PARK ROAD
 OKAHUMPKA, FL 34762

Continuous Emissions Monitoring System

Data Group: U1-1MIN C/R DATA
 Report Name: RATA 1
 Start of Report: 01/18/2006 11:02
 End of Report: 01/18/2006 11:25

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 11:02	9.9	8.8	13.9	11.3	0.0	196.9	15.9
01/18/2006 11:03	9.8	8.8	18.8	11.2	0.0	180.6	18.6
01/18/2006 11:04	8.7	11.4	14.8	10.3	0.0	186.2	17.0
01/18/2006 11:05	8.7	11.4	14.8	10.3	0.0	186.2	17.0
01/18/2006 11:06	9.3	10.8	13.2	10.8	0.0	195.4	15.1
01/18/2006 11:07	9.2	10.7	10.7	10.8	0.0	206.4	13.8
01/18/2006 11:08	9.6	8.6	11.1	11.0	0.0	251.3	12.6
01/18/2006 11:09	10.0	8.9	8.9	11.4	0.0	261.9	11.7
01/18/2006 11:10	10.0	8.9	12.8	11.3	0.0	240.4	13.0
01/18/2006 11:11	9.6	9.8	12.3	11.0	0.0	220.4	14.0
01/18/2006 11:12	9.9	10.1	10.1	11.4	0.0	200.5	11.7
01/18/2006 11:13	10.1	11.6	15.4	11.4	0.0	160.9	16.1
01/18/2006 11:14	9.7	13.7	13.7	11.1	0.0	175.9	14.2
01/18/2006 11:15	9.2	14.3	11.9	10.7	0.0	181.2	13.6
01/18/2006 11:16	9.4	16.9	8.5	11.0	0.0	169.9	11.2
01/18/2006 11:17	10.3	19.7	11.8	11.7	0.0	140.5	12.1
01/18/2006 11:18	10.4	22.5	11.9	11.7	0.0	117.8	15.1
01/18/2006 11:19	10.5	22.7	17.4	11.8	0.0	113.0	15.3
01/18/2006 11:20	9.9	22.7	15.2	11.1	0.0	114.9	18.4
01/18/2006 11:21	9.9	21.5	17.7	11.3	0.0	134.7	15.9
01/18/2006 11:22	9.2	21.4	13.1	10.6	0.0	139.0	18.9
01/18/2006 11:23	9.1	22.4	8.2	10.7	0.0	163.5	9.5
01/18/2006 11:24	9.6	22.1	6.2	11.2	0.0	164.8	8.6
01/18/2006 11:25	10.1	25.7	12.9	11.3	0.0	144.8	13.0
Period Average =	9.7	15.2	12.7	11.1	0.0	177.0	14.3
Period Max Value =	10.5	25.7	18.8	11.8	0.0	261.9	18.9
Period Min Value =	8.7	8.6	6.2	10.3	0.0	113.0	8.6
Period Totals =	2.3210E+2	3.6540E+2	3.0530E+2	2.6640E+2	0.0000E+0	4.2471E+3	3.4230E+2
Period % Recovery =	100.0	100.0	100.0	100.0	100.0	100.0	100.0
RM=	9.4	15.2	13.1	10.8	.7	178.6	13.1

Data Summary Report

Unit 1 run 6

Covanta ENERGY GROUP, INC.

Company: Covanta of Lake
 3830 ROGERS INDUSTRIAL PARK ROAD
 OKAHUMPKA, FL 34762

Continuous Emissions Monitoring System

Data Group: U1-1MIN C/R DATA
 Report Name: RATA 1
 Start of Report: 01/18/2006 11:40
 End of Report: 01/18/2006 12:03

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 11:40	9.4	31.4	2.4	10.9	0.0	233.5	7.0
01/18/2006 11:41	10.4	30.4	2.6	11.8	0.0	207.7	6.1
01/18/2006 11:42	11.0	32.3	7.0	12.2	0.0	151.8	8.0
01/18/2006 11:43	11.7	31.7	18.1	12.6	0.0	123.9	15.1
01/18/2006 11:44	10.1	29.6	6.4	11.2	0.0	180.6	8.6
01/18/2006 11:45	10.1	29.6	6.4	11.2	0.0	180.6	8.6
01/18/2006 11:46				11.4	0.0	201.9	10.4
01/18/2006 11:47				11.5	0.0	186.3	10.4
01/18/2006 11:48	10.1<	28.3<	6.4<	11.1	0.0	205.7	9.9
01/18/2006 11:49	9.9	26.5	5.1	11.2	0.0	225.0	8.6
01/18/2006 11:50	9.8	27.5	3.8	11.1	0.0	228.4	7.1
01/18/2006 11:51	9.6	28.3	3.7				
01/18/2006 11:52	10.5	28.1	6.7				
01/18/2006 11:53	10.4	29.1	6.6	12.0<	0.0<	123.4<	9.4<
01/18/2006 11:54	11.2	31.5	14.3	12.3	0.0	92.1	12.9
01/18/2006 11:55	10.7	28.6	15.0	11.8	0.0	90.1	15.3
01/18/2006 11:56	10.8	26.1	12.4	11.9	0.0	118.9	15.4
01/18/2006 11:57	10.5	28.1	12.0	11.7	0.0	166.2	13.6
01/18/2006 11:58	9.9	26.5	5.1	11.4	0.0	162.4	7.3
01/18/2006 11:59	9.9	26.5	5.2	11.4	0.0	162.4	10.2
01/18/2006 12:00	10.3	26.2	9.2	11.4	0.0	156.6	10.2
01/18/2006 12:01	9.8	22.5	3.8	11.3	0.0	192.6	7.2
01/18/2006 12:02	10.5	21.4	4.0	11.7	0.0	170.7	7.6
01/18/2006 12:03	10.4	21.2	6.6	11.7	0.0	181.3	9.1
Period Average =	10.3	27.8	7.4	11.6	0.0	170.1	9.9
Period Max Value =	11.7	32.3	18.1	12.6	0.0	233.5	15.4
Period Min Value =	9.4	21.2	2.4	10.9	0.0	90.1	6.1
Period Totals =	2.2700E+2	6.1140E+2	1.6280E+2	2.5480E+2	0.0000E+0	3.7421E+3	2.1800E+2
Period % Recovery =	95.7	95.7	95.7	95.7	95.7	95.7	95.7
RM=	10.1	26.1	9.5	11.3	.98	169.1	9.5

Data Summary Report

Unit 1 run 7

Covanta ENERGY GROUP, INC.



Continuous Emissions Monitoring System

Company: Covanta of Lake
3830 ROGERS INDUSTRIAL PARK ROAD
OKAHUMPKA, FL 34762

Data Group: U1-1MIN C/R DATA
Report Name: RATA 1
Start of Report: 01/18/2006 12:18
End of Report: 01/18/2006 12:41

Validation: Valid Data Only

Group#-Channel#	G63-C7	G63-C23	G63-C24	G63-C1	G63-C18	G63-C22	G63-C25
Long Descrip.	U1-1MIN E	U1-1MIN E	U1-1MIN E	U1-1MIN S	U1-1MIN S	U1-1MIN N	U1-1MIN S
Short Descrip.	U1 O2e	SO2ec	CO-Hec	U1 O2s	U1 SO2sc	NOXsc@7%	CO-Lsc
Units	%	PPM	PPM	%	PPMc	PPMc	ppm
Range	0-21	0-500	0-2000	0-21	0-5000	0-1500	0-500
01/18/2006 12:18	9.8	30.6	15.3	11.2	0.0	212.1	14.2
01/18/2006 12:19	10.9	25.4	13.4	12.1	0.0	167.4	16.4
01/18/2006 12:20	10.5	25.4	13.4	11.6	0.0	143.5	16.4
01/18/2006 12:21	9.9	19.0	8.8	11.2	0.0	159.1	14.3
01/18/2006 12:22	11.1	15.6	7.1	12.2	0.0	126.2	11.2
01/18/2006 12:23	9.6	14.8	2.5	11.1	0.0	170.2	7.1
01/18/2006 12:24	9.6	13.9	5.6	11.1	0.0	170.2	7.8
01/18/2006 12:25	10.5	16.0	8.0	11.7	0.0	164.7	10.6
01/18/2006 12:26	11.0	15.4	7.0	12.3	0.0	192.3	9.7
01/18/2006 12:27	11.0	15.4	7.0	12.3	0.0	192.3	9.7
01/18/2006 12:28	11.8	26.0	13.7	12.7	0.0	179.7	13.6
01/18/2006 12:29	11.2	15.0	15.0	12.1	0.0	184.8	16.8
01/18/2006 12:30	10.7	15.0	15.0	11.8	0.0	197.0	16.8
01/18/2006 12:31	10.0	14.0	10.2	11.2	0.0	219.2	12.9
01/18/2006 12:32	10.0	14.0	8.9	11.3	0.0	234.6	10.1
01/18/2006 12:33	9.2	14.3	5.9	10.6	0.0	220.0	10.8
01/18/2006 12:34	10.2	9.1	5.2	11.6	0.0	218.2	7.5
01/18/2006 12:35	10.8	10.3	7.7	11.9	0.0	182.2	10.0
01/18/2006 12:36	10.1	10.3	7.7	11.2	0.0	176.3	10.0
01/18/2006 12:37	9.9	6.3	6.3	11.3	0.0	175.2	8.7
01/18/2006 12:38	10.4	5.3	9.3	11.6	0.0	156.9	10.5
01/18/2006 12:39	9.7	7.4	6.2	11.0	0.0	155.8	9.8
01/18/2006 12:40	10.5	5.3	6.7	11.8	0.0	148.2	7.6
01/18/2006 12:41	9.8	8.8	7.5	10.9	0.0	119.5	9.7
Period Average =	10.3	14.7	8.9	11.6	0.0	177.7	11.3
Period Max Value =	11.8	30.6	15.3	12.7	0.0	234.6	16.8
Period Min Value =	9.2	5.3	2.5	10.6	0.0	119.5	7.1
Period Totals =	2.4820E+2	3.5260E+2	2.1340E+2	2.7780E+2	0.0000E+0	4.2656E+3	2.7220E+2
Period % Recovery =	100.0	100.0	100.0	100.0	100.0	100.0	100.0
RM=	10.1	14.4	10.9	11.3	1.1	173.3	10.9