



HOME MY WORK

Generation Applications | PMTOOLS | WBITools | Ass

Production Management Tools - Log Viewer

Martin 3, 4 , 8 & Solar Edition

BACK

NEXT

Log ID 701340

Created: 12/22/2011 7:09:22 AM

Details



Log Type: * Inside Operator 8 (IO8)

Written By: (jxv0zy8) Vandermolen, Jonathan (Jonathan.Vandermolen@fpl.com)

Team: Shift #3

Shift: (12/22/2011 6:00:00 AM to 12/22/2011 6:00:00 PM)

Content



| | |
|--------------------|---|
| General Log Notes: | <p>SHIFT TURNOVER ALL CT'S ONLINE AND STEAM TURBINE ONLINE 8A,8B ON LOAD CONTROL SAFTEY TAILBOARD/CREW MEETING 8D LINED UP FOR LIQUID FUEL SWAP 09:20 DROPPED LOAD ON 8D TO 14 MW'S 09:20 8D OUT OF COMPLIANCE 09:38 8D RAMPED TO 35 MW ON GAS UNTIL A DOWNLOAD CAN BE COMPLETED 10:05 8D BACK IN COMPLIANCE ON GAS PLANNING ON DROPPING LOAD ON 8C,FUEL SWAPPING AND ISOLATING 8C GAS HEATER 10:15 8C TO 100 MW'S TO UNBLEND IN COMPLIANCE 10:30 8C UNBLENDED AND IN COMPLIANCE BUT REHEATER#3 OUTLET GOT REALLY HOT SUGGEST BLENDING OUT OF COMPLIANCE AT</p> |
|--------------------|---|

LOWER LOAD OR FINDING A SWEET SPOT IN COMPLIANCE

10:45 DROPPED LOAD ON 8C TO LOWER REHEATER TEMPS 14mw'S
11:11 8A AND 8B OFF CONTROL TO TEST DUCT BURNERS
11:14 DUCT BURNERS IN 8A
11:18 DUCT BURNERS IN 8B
11:30 DUCT BURNERS OUT OF 8A AND 8B
11:58 SELECTED LIQUID FUEL ON 8C
12:03 8C ON LIQUID FUEL 100%
12:09 REPORTED LEAK ON CAN #9
12:25 WATER INJECTION IN SERVICE ON 8C #2,#1,#6 AND EAST HORIZONTAL JOINT LEAKING WATER ON 8C
12:33 8C TO 14 M.W TO SWAP BACK TO GAS
12:40 8C ON GAS
12:41 FIRED SHUT DOWN ON 8A
12:42 8C BREAKER OPEN
12:41 8A BREAKER OPEN
12:46 8A CT BACK ONLINE
12:47 8C FIRES OUT
12:41 8A OUT OF COMPLIANCE
12:54 FGT TARGET AT 96000
13:11 8A TO BASE LOAD
13:11 8A IN COMPLIANCE
13:38 SHUT DOWN 8C BOILER FEED PUMP
13:55 CRANK COOLING 8C TO FIX LIQUID FUEL AND WATER INJECTION
GENERATED EVENT REPORT FOR PM820114781
8A CT FIRED SHUTDOWN
14:18 8D PRESELECET LOAD 15 MW ON 8D
14:19 8D OUT OF COMPLIANCE
14:41 SELECTED LIQUID FUEL ON 8D
14:46 8D TRIPPED ON ATOMIZING AIR PRESSURE RATIO LOW
15:07 8A FIRED SHUT DOWN ON COMPRESOR BLEED VLVS VA 2-3,2-4
15:07 8A BREAKER OPEN
15:20 8A FIRES OUT
15:41 8D STARTED
15:59 8D FIRES IN

| | |
|-------------------------|---|
| | <p>16:09 8D BREAKER CLOSED 16:16 8D FEED PUMP TRIPPED ON DISCH LOW FLOW 175 MIN LOCKOUT 16:32 8D GEN BREAKER OPEN ***PLEASE DECLARE 4 ON 1 TONIGHT FOR GCM DECLARATIONS ***PLEASE DECLARE A, B, AND C AS LIQUID FUEL CAPABLE--D IS UNPROVEN ***A CT REVERTS TO RSD AFTER MIDNIGHT PUT HRSG D BFP AUX L.O. PUMP IN MANUAL. CONTINUALLY CYCLING ON AND OFF</p> |
| Safety Concerns: | |
| Environmental Concerns: | 8A CT HAS EXHAUSTED TODAYS NOX LIMITATIONS 12:00 - 11.8 PPM; 13:00 - 7.7 PPM |
| Security Concerns: | |
| Reliability Concerns: | <p>WITH .04 UPGRADE, IT IS NECESSARY TO SET L.L.L. GREATER THAN 100MWS. RECENTLY TRANSFERRED OUT OF COMPLIANCE WITH A L.L.L. OF 90 MWS.</p> <p>IF 8X STEAM TURBINE ROTOR HI TEMP OR FIELD AMP ALARM COMES IN:NOTIFY JOE P. AND TIM BRYANT THE S.T MAY NEED TO COME OFF TO FIX</p> |

Attachments ▣▣▣▣

| | |
|--|--|
| | |
|--|--|

Inspection of Watch Results ▣▣▣▣

| |
|--|
| <p>No IOW Work found for this period.</p> |
|--|

