

# Compliance Summary

Test Performed For:  
Progress Energy Florida  
Intercession City  
P11  
RATA and Compliance  
Date:2/17/09

Test Performed By:  
C.E.M. Solutions, Inc.  
1183 E. Overdrive Circle  
Hernando, FL 34442  
Ph: 352-489-4337

| Run Number                        | Units      | Run 1   | Run 2   | Run 3    | Run 4    | Run 5    | Run 6    | Average | Standard |
|-----------------------------------|------------|---------|---------|----------|----------|----------|----------|---------|----------|
| Date of Run                       | 2009       | 17-Feb  | 17-Feb  | 17-Feb   | 17-Feb   | 17-Feb   | 17-Feb   |         |          |
| Start Time                        |            | 8:51:00 | 9:29:00 | 10:06:00 | 10:44:00 | 11:21:00 | 11:58:00 |         |          |
| Stop Time                         |            | 9:12:00 | 9:50:00 | 10:27:00 | 11:05:00 | 11:42:00 | 12:19:00 |         |          |
| Unit Load                         | MW         | 160.68  | 161.66  | 161.08   | 160.56   | 159.32   | 158.77   | 160.3   |          |
| NO <sub>x</sub> / CO <sub>2</sub> | Lbs/mmBtu  | 0.1520  | 0.1600  | 0.1550   | 0.1580   | 0.1570   | 0.1560   | 0.156   |          |
| NO <sub>x</sub> / CO <sub>2</sub> | ppm@15% O2 | 39.0    | 41.0    | 39.9     | 40.8     | 40.4     | 40.3     | 40.2    | 42.0     |
| CO / CO <sub>2</sub>              | Lbs/mmBtu  | 0.0020  | 0.0020  | 0.0020   | 0.0020   | 0.0020   | 0.0020   | 0.002   |          |
| CO / CO <sub>2</sub>              | ppm@15% O2 | 0.7     | 0.8     | 0.8      | 0.8      | 0.7      | 0.7      | 0.8     |          |

PRELIMINARY

# Compliance Summary

Test Performed For:  
Progress Energy Florida  
Intercession City  
P11  
RATA and Compliance  
Date:2/17/09

Test Performed By:  
C.E.M. Solutions, Inc.  
1183 E. Overdrive Circle  
Hernando, FL 34442  
Ph: 352-489-4337

| Run Number                        | Units      | Run 7    | Average | Standard |
|-----------------------------------|------------|----------|---------|----------|
| Date of Run                       | 2009       | 17-Feb   |         |          |
| Start Time                        |            | 12:34:00 |         |          |
| Stop Time                         |            | 12:55:00 |         |          |
| Unit Load                         | MW         | 158.49   | 93.4    |          |
| NO <sub>x</sub> / CO <sub>2</sub> | Lbs/mmBtu  | 0.1570   | 0.156   |          |
| NO <sub>x</sub> / CO <sub>2</sub> | ppm@15% O2 | 40.3     | 40.2    | 42.0     |
| CO / CO <sub>2</sub>              | Lbs/mmBtu  | 0.0020   | 0.002   |          |
| CO / CO <sub>2</sub>              | ppm@15% O2 | 0.7      | 0.7     |          |

PRELIMINARY