

TABLE 1. CONTINUOUS EMISSION MONITOR CERTIFICATION
 KWA, CAH ISLAND
 12 Sep 07
 CI 1

| RUN NO. | RUN TIME | REFERENCE METHOD | | NOx LB/MMBTU | | DIFF | RM | DIFF | RM |
|---------|-----------|------------------|-------|--------------|-------|----------|-------------|----------|--------|
| | | NOx | O2 | RM | CEM | | | | |
| 1 | 1156-1224 | 23.36 | 15.04 | 0.0086 | 0.003 | 0.005631 | 4.18628E-03 | 0.00831 | 0.0052 |
| 2 | 1212-1267 | 24.12 | 15.06 | 0.0090 | 0.006 | 0.003798 | 0.0847 CEM | 0.003798 | 0.0090 |
| 3 | 1303-1367 | 24.90 | 15.04 | 0.0025 | 0.003 | 0.004693 | | 0.004693 | 0.0025 |
| 4 | 1412-1433 | 23.97 | 15.05 | 0.0090 | 0.005 | 0.003763 | | 0.003763 | 0.0090 |
| 5 | 1443-1504 | 23.77 | 15.07 | 0.0006 | 0.004 | 0.004622 | | 0.004622 | 0.0006 |
| 6 | 1515-1536 | 23.80 | 15.06 | 0.0005 | 0.004 | 0.004518 | | 0.004518 | 0.0005 |
| 7 | 1548-1609 | 24.49 | 15.00 | 0.0014 | 0.007 | 0.004395 | | 0.004395 | 0.0014 |
| 8 | 1619-1640 | 24.02 | 15.05 | 0.0013 | 0.005 | 0.004256 | | 0.004256 | 0.0013 |
| 9 | 1651-1712 | 22.84 | 15.03 | 0.0045 | 0.000 | 0.004529 | | 0.004529 | 0.0045 |

FUEL FACTOR: 07/10

DELETE COLUMN HERE

NG D

1st VALUE 2.308
 TOTAL DATA POINTS USED 9
 AVERAGE 0.009 0.005 0.0043 0.009
 AVERAGE DIFF CORRECTED FOR DELETED RUNS 0.0004 0.0004 0.0004 0.0004
 SD 0.0003 0.0003 0.0003 0.0003
 CV 0.0003 0.0003 0.0003 0.0003
 RM 0.0003 0.0003 0.0003 0.0003
 RM GROSS ADJUSTED (M) 1.000 1.000

DELETE

NA NA

Font11

Page 1

GE Energy NetDAHS©
Average Values Report
Version 57.0
Generated: 9/12/2007 09:30

Company: Kissimmee Utility Authority Period Start: 9/12/2007 09:00
Plant: 6075 Old Tampa Highway Period End: 9/12/2007 09:21
City/St: Intercession City, FL 33848 Validation Type: 1/1 min
Source: Bypass Averaging Period: 1 min
Type: Block Avg

| Period Start | NOx_2A ppm | O2_2A % | NOx_cor_2A ppm | NOx/btu_2A #/M | LOAD_2A MW | GAS_FL Kscfh |
|-----------------|---------------|------------|-------------------|-------------------|---------------|-----------------|
| 9/12/2007 09:00 | 6.3 | 15.40 | 6.8 | 0.025 | 106.54 | 847 |
| 9/12/2007 09:01 | 6.2 | 15.22 | 6.4 | 0.024 | 105.65 | 845 |
| 9/12/2007 09:02 | 6.3 | 15.26 | 6.6 | 0.024 | 105.49 | 848 |
| 9/12/2007 09:03 | 6.3 | 15.12 | 6.4 | 0.024 | 106.02 | 847 |
| 9/12/2007 09:04 | 6.4 | 15.13 | 6.5 | 0.024 | 105.93 | 843 |
| 9/12/2007 09:05 | 6.4 | 15.17 | 6.6 | 0.024 | 105.46 | 844 |
| 9/12/2007 09:06 | 6.3 | 15.19 | 6.6 | 0.024 | 105.94 | 846 |
| 9/12/2007 09:07 | 6.3 | 15.19 | 6.5 | 0.024 | 106.04 | 847 |
| 9/12/2007 09:08 | 6.4 | 15.14 | 6.5 | 0.024 | 105.58 | 848 |
| 9/12/2007 09:09 | 6.5 | 15.36 | 7.0 | 0.026 | 106.27 | 848 |
| 9/12/2007 09:10 | 6.3 | 15.32 | 6.7 | 0.024 | 106.28 | 846 |
| 9/12/2007 09:11 | 6.4 | 15.22 | 6.7 | 0.024 | 105.69 | 845 |
| 9/12/2007 09:12 | 6.5 | 15.15 | 6.7 | 0.025 | 106.20 | 845 |
| 9/12/2007 09:13 | 6.5 | 15.16 | 6.7 | 0.025 | 106.25 | 844 |
| 9/12/2007 09:14 | 6.3 | 15.21 | 6.6 | 0.024 | 105.61 | 850 |
| 9/12/2007 09:15 | 6.3 | 15.12 | 6.5 | 0.024 | 105.99 | 848 |
| 9/12/2007 09:16 | 6.4 | 15.12 | 6.5 | 0.024 | 106.56 | 852 |
| 9/12/2007 09:17 | 6.5 | 15.11 | 6.6 | 0.024 | 104.24 | 849 |
| 9/12/2007 09:18 | 6.8 | 15.11 | 6.9 | 0.026 | 101.87 | 844 |
| 9/12/2007 09:19 | 6.9 | 15.10 | 7.0 | 0.026 | 101.07 | 845 |
| 9/12/2007 09:20 | 6.9 | 15.10 | 7.0 | 0.026 | 100.86 | 852 |
| 9/12/2007 09:21 | 6.9 | 15.10 | 7.0 | 0.026 | 100.82 | 854 |
| Final Average* | 6.5 | 15.18 | 6.7 | 0.025 | 105.02 | 8 |
| Maximum* | 6.9 | 15.40 | 7.0 | 0.026 | 106.56 | 8 |
| Minimum* | 6.2 | 15.10 | 6.4 | 0.024 | 100.82 | 843 |

*Does not include Invalid Averaging Periods ("N/A")

| EU ID | EU Description | Pollutant | 2006 | 2005 |
|-------|--|-----------|--------------|--------------|
| | | | Actual (TPY) | Actual (TPY) |
| | | SAM | | |
| | | SO2 | 0.584665 | 0.448015 |
| | | VOC | 2.04633 | 1.568053 |
| 003 | A 250 MW Combined Cycle Turbine with Supplemental Duct Firg | | | |
| | | CO | 8.36142 | 9.72618 |
| | | H015 | | |
| | | H021 | | |
| | | H095 | | |
| | | H114 | | |
| | | NH3 | 1.85555 | 0.558738 |
| | | NOX | 5.2 | 20.47 |
| | | PB | | |
| | | PM | 26.4816 | 31.222041 |
| | | PM10 | 26.4816 | 31.222041 |
| | | SO2 | 2.40742 | 2.838367 |
| | | VOC | 0.773145 | 0.93123 |
| 004 | Distillate Fuel Oil Storage Tank No. 3 - 1.0 million gallons | | | |
| | | VOC | | |
| 005 | 44MMBTU/hr natural gas duct burner | | | |
| | | CO | | |
| | | NOX | 0.00 | 0.00 |
| | | PM | | |
| | | PM10 | | |
| | | SO2 | | |
| | | VOC | | |
| 006 | Cooling Tower | | | |
| | | PM | | |

ELECTRONIC ANNUAL OPERATING REPORT

Emission Report by EU

Facility ID: 0970043
Owner/Company Name: KISSIMMEE UTILITY AUTHORITY
Site Name: KUA CANE ISLAND POWER PARK

| EU ID | EU Description | Pollutant | 2006 | 2005 |
|-------|--|-----------|--|--------------|
| | | | Actual (TPY) | Actual (TPY) |
| 001 | Simple Cycle CT Unit: 1, (Phase II Acid Rain Unit) | CO | 0.657878 | 0.93328 |
| | | H015 | | |
| | | H021 | 0.00 | 0.00 |
| | | H095 | | |
| | | H114 | 0.00 | 0.000001 |
| | | NOX | 3.1 | 2.62 |
| | | PB | | |
| | | PM | 0.144733 | 0.214569 |
| | | PM10 | 0.144733 | 0.214569 |
| | | SAM | | |
| | | SO2 | 0.013158 | 0.064137 |
| | | VOC | 0.046051 | 0.063893 |
| | | 002 | Combined Cycle CT Unit: 2, (Phase II Acid Rain Unit) | CO |
| H015 | | | | |
| H021 | | | | |
| H095 | | | | |
| H114 | | | | |
| NOX | 50.5 | | | 61.52 |
| PB | | | | |
| PM | 6.43132 | | | 4.928166 |
| PM10 | 6.43132 | | | 4.928166 |

| EU ID | EU Description | Pollutant | 2006 | 2005 |
|-------|--|-------------|--------------|--------------|
| | | | Actual (TPY) | Actual (TPY) |
| | | PM10 | | |
| 007 | Distillate Fuel Oil Storage Tank No. 2 - 700,000 gallon. | VOC | | |
| 008 | Distillate Fuel Oil Storage Tank No.1- 300,000 gallons. | VOC | | |

**Kissimmee Utility Authority
Cane Island Power Park
Facility ID: 0970043
Rolling 12-month Average
NOx Emissions From Units 1 and 2**

| 12-Months Ending | Unit 1 | Unit 2 | Total |
|-----------------------------|---------------|---------------|--------------|
| Jan-06 | 4.5 | 35.9 | 40.4 |
| Feb-06 | 4.6 | 36.2 | 40.8 |
| Mar-06 | 4.4 | 36.9 | 41.4 |
| Apr-06 | 4.7 | 38.1 | 42.8 |
| May-06 | 4.7 | 42.7 | 47.5 |
| Jun-06 | 4.8 | 43.5 | 48.2 |
| Jul-06 | 4.0 | 41.1 | 45.2 |
| Aug-06 | 2.1 | 40.1 | 42.3 |
| Sep-06 | 2.1 | 40.5 | 42.7 |
| Oct-06 | 2.7 | 42.3 | 45.0 |
| Nov-06 | 2.6 | 41.1 | 43.7 |
| Dec-06 | 2.2 | 38.6 | 40.8 |

Kissimmee Utility Authority
Cane Island Power Park
Facility ID: 0970043
Rolling 12-month Average
NOx Emissions From Units 1 and 2

| 12-Months Ending | Unit 1 | Unit 2 | Total |
|-----------------------------|---------------|---------------|--------------|
| Jan-05 | 2.0 | 81.7 | 83.7 |
| Feb-05 | 1.8 | 83.3 | 85.1 |
| Mar-05 | 1.9 | 92.7 | 94.7 |
| Apr-05 | 1.9 | 92.2 | 94.1 |
| May-05 | 1.8 | 86.7 | 88.6 |
| Jun-05 | 1.8 | 86.9 | 88.7 |
| Jul-05 | 2.5 | 89.6 | 92.1 |
| Aug-05 | 2.9 | 91.5 | 94.4 |
| Sep-05 | 2.5 | 80.8 | 83.3 |
| Oct-05 | 2.3 | 59.3 | 61.6 |
| Nov-05 | 2.4 | 61.9 | 64.3 |
| Dec-05 | 2.4 | 56.2 | 58.6 |
| Jan-06 | 2.4 | 49.2 | 51.6 |
| Feb-06 | 2.5 | 47.9 | 50.4 |
| Mar-06 | 2.5 | 41.1 | 43.5 |
| Apr-06 | 2.7 | 42.2 | 44.9 |
| May-06 | 2.7 | 47.5 | 50.2 |
| Jun-06 | 2.7 | 48.2 | 51.0 |
| Jul-06 | 2.1 | 45.9 | 48.0 |
| Aug-06 | 1.7 | 45.3 | 47.0 |
| Sep-06 | 1.6 | 46.3 | 48.0 |
| Oct-06 | 2.2 | 48.4 | 50.5 |
| Nov-06 | 2.1 | 46.7 | 48.8 |
| Dec-06 | 3.0 | 43.5 | 46.5 |