

634 Unanswered Episodes

0 Unacknowledged Alarms

gas fl.1

0.0

kscfh

State Ok

Status Process Off

Minute 0.0

Hour -999.9

LOAD_1

0.00

MW

State Ok

Status Process Off

Minute 0.00

Hour -99.99

NOx_1

ppm

Low

State Ok

Status Process Off

Minute -0.1

Hour -999.9

O2_1

20.98

%

State Ok

Status Process On

Minute 20.99

Hour -99.99

GAS_FL_2B

817.5

Kscfh

State Ok

Status Process On

Minute 818.2

Hour 821.2

LOAD_2B

68.19

MW

State Ok

Status Process On

Minute 67.92

Hour 68.23

NOx_2B

8.0

ppm

State Ok

Status Process On

Minute 8.0

Hour 8.1

O2_2B

15.59

%

State Ok

Status Process On

Minute 15.59

Hour 15.59

GAS_FL_3B

18.2

#/S

State Ok

Status Process On

Minute 18.1

Hour 18.1

LOAD_3B

149.6

MW

State Ok

Status Process On

Minute 149.8

Hour 149.7

NOx_3B

3.6

ppm

State Ok

Status Process On

Minute 3.7

Hour 3.7

O2_3B

13.72

%

State Ok

Status Process On

Minute 13.71

Hour 13.76

Page 1



(S) Attached to DAHS

DAHS = NTAHS

B IS COMBINED CYCLE STACK.
KUA CANE ISLAND
9/9/03