



Osceola Fuel Oil Testing Report

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-1	2/13/2006	2006-0222	19543	0.8501	0.0382
CT-1	2/12/2006	2006-0222	19586	0.8502	0.0385
CT-1	9/26/2005	T5104529	19528	0.8524	0.0404
CT-1	9/2/2005	T5104558	19538	0.8522	0.0399
CT-1	8/31/2005	T5094487	19546	0.8529	0.0378
CT-1	8/30/2005	T5094487	19551	0.853	0.0365
CT-1	8/29/2005	T5094487	19524	0.8529	0.0379
CT-1	7/11/2005	T5074339	19444	0.8565	0.0455
CT-1	7/8/2005	T5074339	19471	0.8563	0.0451
CT-1	7/7/2005	T5074339	19467	0.8537	0.0432
CT-1	7/6/2005	T5074339	19447	0.8537	0.0429
CT-1	5/3/2005	2005-0386	19499	0.8523	0.0455
CT-1	5/2/2005	2005-0386	19486	0.8523	0.0451
CT-1	10/4/2004	2005-0034	19527	0.8522	0.0434
CT-1	9/27/2004	2004-0671	19536	0.8524	0.0416
CT-1	9/17/2004	T4092671	19498	0.8506	0.0353
CT-1	9/16/2004	T4092671	19506	0.8506	0.035
CT-1	9/9/2004	T4092661	19565	0.8505	0.0354
CT-1	6/25/2004	2004-0499	19568	0.8504	0.0324
CT-1	6/24/2004	2004-0499	19563	0.8504	0.0326
CT-1	4/9/2004	2004-0267	19496	0.8503	0.0427
CT-1	3/11/2004	2004-0203	19432	0.8518	0.0492
CT-1	1/10/2004	2004-0203	19421	0.8517	0.0469
CT-1	1/8/2004	2004-0203	19486	0.8517	0.0482
CT-1	12/19/2003	OS03-67	19508	0.852	0.0435
CT-1	11/26/2003	OS03-64	19518	0.852	0.0458
CT-1	10/13/2003	OS03-60	19550	0.8521	0.0447

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-1	8/26/2003	OS03-54	19420		0.0402
CT-1	7/11/2003	OS03-44	19402		0.053
CT-1	7/10/2003	OS03-43	19508		0.0543
CT-1	7/9/2003	OS03-57	19460		0.0402
CT-1	7/9/2003	OS03-57	19460		0.0402
CT-1	7/8/2003	OS03-41	19541		0.0535
CT-1	6/14/2003	OS03-49	19196		0.056
CT-1	6/9/2003	OS03-46	19307		0.052
CT-1	6/8/2003	OS03-40	19362		0.0511
CT-1	6/6/2003	OS03-45	19183		0.056
CT-1	5/31/2003	OS03-39	19495		0.0564
CT-1	5/18/2003	OS03-38	19437		
CT-1	5/17/2003	OS03-36	19451		
CT-1	5/14/2003	OS03-35	19456		
CT-1	5/13/2003	OS03-33	19290		
CT-1	3/31/2003	OS-0329	19424		0.0408
CT-1	3/29/2003	OS-0328	19648		0.0421
CT-1	3/27/2003	OS-0327	19442		0.0424
CT-1	3/26/2003	OS-0326	19455		0.0423
CT-1	3/19/2003	OS-0323	19437		0.0427
CT-1	2/18/2003	OS-0321	19455		0.0437
CT-1	1/29/2003	OS-0314	19310		0.039
CT-1	1/24/2003	OS-0309	19434		0.039
CT-1	1/23/2003	OS-0306	19478		0.04
CT-1	1/20/2003	OS-0305	19464		0.04
CT-1	11/22/2002	OS-56	19449		0.047
CT-1	10/25/2002	OS-55	19447		0.045
CT-1	10/22/2002	OS-54	19432		0.0451
CT-1	10/21/2002	OS-53	19478		0.0459
CT-1	10/2/2002	OS-39	19411		0.04
CT-1	9/28/2002	OS-36	19482		0.04

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-1	9/27/2002	OS-33	19501		0.038
CT-1	9/26/2002	OS-35	19508		0.039
CT-1	9/25/2002	OS-31	19512		0.039
CT-1	9/23/2002	OS-28	19419		0.04
CT-1	9/21/2002	OS-25	19429		0.043
CT-1	9/18/2002	OS-24	19500		0.042
CT-1	9/11/2002	OS-18	19453	0.8577	0.039
CT-1	8/22/2002	OS-16	19452	0.8577	0.04
CT-1	8/21/2002	OS-15	19398	0.8577	0.04
CT-1	7/17/2002	OS-12	19492	0.8577	0.04
CT-1	7/7/2002	OS-10	19478	0.8561	0.04
CT-2	2/12/2006	2006-0222	19559	0.8503	0.0383
CT-2	12/20/2005	2006-0126	19567	0.8518	0.049
CT-2	12/18/2005	2006-0126	19571	0.8519	0.0455
CT-2	12/8/2005	2006-0126	19608	0.8519	0.0461
CT-2	11/3/2005	2006-0126	19668	0.8522	0.0466
CT-2	10/13/2005	T5104558	19521	0.8522	0.0399
CT-2	9/30/2005	T5104529	19514	0.8524	0.038
CT-2	9/24/2005	T5104529	19556	0.8524	0.0372
CT-2	9/1/2005	T5094487	19538	0.8529	0.0388
CT-2	8/31/2005	T5094487	19529	0.8529	0.0369
CT-2	8/30/2005	T5094487	19546	0.8529	0.0388
CT-2	8/29/2005	T5094451	19438	0.8565	0.0456
CT-2	8/28/2005	T5094451	19450	0.8564	0.0444
CT-2	7/11/2005	T5074339	19453	0.8564	0.0455
CT-2	7/10/2005	T5074339	19439	0.8565	0.0457
CT-2	7/8/2005	T5074339	19457	0.8564	0.0453
CT-2	7/7/2005	T5074339	19430	0.8537	0.0427
CT-2	7/6/2005	T5074339	19421	0.8537	0.0429
CT-2	7/5/2005	T5074339	19431	0.8537	0.0433
CT-2	12/10/2004	2005-0034	19564	0.8523	0.0491

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-2	10/20/2004	2005-0034	19497	0.8523	0.0431
CT-2	10/20/2004	2004-0822	19571	0.8552	0.0408
CT-2	10/2/2004	2005-0034	19505	0.8522	0.043
CT-2	9/30/2004	2004-0671	19531	0.8523	0.0403
CT-2	9/29/2004	2004-0671	19544	0.8523	0.0406
CT-2	9/18/2004	T4092671	19526	0.8506	0.0347
CT-2	9/17/2004	T4092671	19510	0.8506	0.0359
CT-2	9/14/2004	T4092671	19503	0.8506	0.0353
CT-2	9/10/2004	T4092661	19573	0.8505	0.0354
CT-2	4/22/2004	2004-0298	19543	0.8504	0.0413
CT-2	4/10/2004	2004-0267	19490	0.8503	0.0423
CT-2	2/28/2004	2004-0243	19503	0.8519	0.0472
CT-2	2/10/2004	2004-0267	19490	0.8503	0.0423
CT-2	1/10/2004	2004-0203	19468	0.8517	0.0486
CT-2	12/18/2003	OS03-66	19519	0.852	0.0413
CT-2	11/22/2003	OS03-63	19422	0.8517	0.0448
CT-2	11/21/2003	OS03-62	19510	0.852	0.0475
CT-2	9/4/2003	OS03-59	19473		0.0419
CT-2	8/26/2003	OS03-55	19507		0.0391
CT-2	8/26/2003	OS03-55	19507		0.0391
CT-2	7/21/2003	OS03-53	19519		0.0549
CT-2	7/20/2003	OS03-52	19487		0.0532
CT-2	7/19/2003	OS03-51	19430		0.053
CT-2	7/18/2003	OS03-50	19365		0.054
CT-2	7/15/2003	OS03-58	19427		0.0399
CT-2	7/15/2003	OS03-58	19427		0.0399
CT-2	6/10/2003	OS03-48	19429		0.057
CT-2	6/9/2003	OS03-47	19390		0.054
CT-2	5/17/2003	OS03-37	19464		
CT-2	5/13/2003	OS03-34	19387		
CT-2	5/9/2003	OS03-32	19442		

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-2	5/6/2003	OS03-31	19452		
CT-2	4/14/2003	OS-0330	19443		0.0426
CT-2	3/20/2003	OS-0325	19409		0.0442
CT-2	3/19/2003	OS-0324	19449		0.0436
CT-2	2/25/2003	OS-0322	19455		0.0401
CT-2	2/13/2003	OS-0319	19459		0.0414
CT-2	1/29/2003	OS-0315	19423		0.038
CT-2	1/25/2003	OS-0312	19444		0.039
CT-2	1/24/2003	OS-0310	19468		0.041
CT-2	1/23/2003	OS-0307	19394		0.04
CT-2	1/19/2003	OS-0304	19436		0.04
CT-2	1/17/2003	OS-0302	19518		0.04
CT-2	1/14/2003	OS-0301	19376		0.042
CT-2	1/13/2003	OS-0318	19414		0.043
CT-2	1/9/2003	OS-0317	19453		0.043
CT-2	1/8/2003	OS-0316	19363		0.043
CT-2	11/9/2002	OS-49	19446		0.0402
CT-2	11/9/2002	OS-50	19483		0.0402
CT-2	11/8/2002	OS-47	19503		0.0412
CT-2	11/8/2002	OS-48	19476		0.0434
CT-2	11/7/2002	OS-46	19493		0.0418
CT-2	11/6/2002	OS-45	19493		0.0388
CT-2	10/15/2002	OS-52	19432		0.0457
CT-2	10/14/2002	OS-51	19461		0.0451
CT-2	10/4/2002	OS-43	19402		0.038
CT-2	10/3/2002	OS-41	19466		0.041
CT-2	10/2/2002	OS-40	19448		0.04
CT-2	10/1/2002	OS-38	19507		0.04
CT-2	9/27/2002	OS-34	19519		0.039
CT-2	9/24/2002	OS-30	19514		0.04
CT-2	9/21/2002	OS-27	19400		0.039

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-2	9/20/2002	OS-26	19622		0.04
CT-2	9/16/2002	OS-22	19494		0.038
CT-2	9/13/2002	OS-21	19493		0.041
CT-2	9/12/2002	OS-20	19483	0.8577	0.038
CT-2	9/11/2002	OS-19	19504	0.8577	0.038
CT-2	9/10/2002	OS-17	19478	0.8577	0.038
CT-2	8/14/2002	OS-14	19442	0.8577	0.04
CT-2	8/13/2002	OS-13	19492	0.8577	0.04
CT-2	7/16/2002	OS-11	19370	0.8577	0.04
CT-2	6/27/2002	OS-06	19515	0.8545	0.042
CT-3	2/20/2006	2006-0222	19579	0.8501	0.0387
CT-3	2/12/2006	2006-0222	19532	0.8502	0.0387
CT-3	12/20/2005	2006-0126	19534	0.8519	0.0458
CT-3	12/18/2005	2006-0126	19592	0.8519	0.047
CT-3	12/17/2005	2006-0126	19580	0.8511	0.0481
CT-3	12/16/2005	2006-0126	19530	0.8519	0.0435
CT-3	12/14/2005	2006-0126	19512	0.8518	0.0475
CT-3	12/12/2005	2006-0126	19511	0.8504	0.0411
CT-3	12/11/2005	2006-0126	19506	0.8505	0.0476
CT-3	12/10/2005	2006-0126	19559	0.8519	0.0467
CT-3	12/8/2005	2006-0126	19608	0.8519	0.0474
CT-3	10/13/2005	T5104558	19530	0.8522	0.0403
CT-3	9/29/2005	T5104529	19534	0.8524	0.0388
CT-3	8/30/2005	T5104558	19512	0.8523	0.0395
CT-3	8/29/2005	T5094451	19446	0.8565	0.0438
CT-3	8/28/2005	T5094451	19443	0.8565	0.0431
CT-3	7/11/2005	T5074339	19449	0.8564	0.0454
CT-3	7/7/2005	T5074339	19460	0.8537	0.0425
CT-3	7/6/2005	T5074339	19438	0.8537	0.043
CT-3	3/19/2005	2005-0352	19511	0.8523	0.0455
CT-3	12/20/2004	2005-0034	19541	0.8523	0.0465

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-3	9/30/2004	2004-0671	19544	0.8523	0.0422
CT-3	9/27/2004	2004-0671	19543	0.8522	0.0409
CT-3	9/20/2004	T4092671	19530	0.8525	0.04
CT-3	9/19/2004	T4092671	19527	0.8525	0.0405
CT-3	9/18/2004	T4092671	19526	0.8525	0.0417
CT-3	9/17/2004	T4092671	19531	0.8525	0.0403
CT-3	9/16/2004	T4092671	19532	0.8525	0.0414
CT-3	9/15/2004	T4092671	19507	0.8506	0.0407
CT-3	9/14/2004	T4092671	19507	0.8507	0.0364
CT-3	6/28/2004	2004-0499	19553	0.8505	0.0327
CT-3	1/16/2004	2004-0243	19508	0.8519	0.049
CT-3	12/21/2003	OS03-70	19440	0.852	0.0434
CT-3	12/20/2003	OS03-69	19405	0.852	0.0434
CT-3	12/19/2003	OS03-68	19477	0.852	0.0433
CT-3	11/6/2003	OS03-61	19518	0.8518	0.0458
CT-3	10/15/2003	OS03-65	19438	0.8525	0.0416
CT-3	8/26/2003	OS03-56	19334		0.0391
CT-3	8/26/2003	OS03-56	19334		0.0391
CT-3	7/9/2003	OS03-42	19529		0.053
CT-3	2/13/2003	OS-0320	19384		0.0437
CT-3	1/25/2003	OS-0313	19402		0.043
CT-3	1/24/2003	OS-0311	19468		0.041
CT-3	1/23/2003	OS-0308	19392		0.039
CT-3	1/17/2003	OS-0303	19469		0.039
CT-3	10/9/2002	OS-44	19473		0.04
CT-3	10/3/2002	OS-42	19473		0.04
CT-3	9/28/2002	OS-37	19489		0.041
CT-3	9/26/2002	OS-32	19331		0.041
CT-3	9/23/2002	OS-29	19525		0.038
CT-3	9/16/2002	OS-23	19489		0.037
CT-3	6/28/2002	OS-08	19503	0.8545	0.041

Unit #	Sample Date	Lab ID #	BTU/ lbs	Density @ 15 Deg C	% S
CT-3	6/28/2002	OS-09	19468	0.8545	0.04
CT-3	6/27/2002	OS-07	19483	0.8535	0.042
CT-3	6/3/2002	OS-05	19505	0.854	0.04
CT-3	5/30/2002	OS-04	19506	0.8545	0.04
CT-3	5/29/2002	OS-03	19539	0.8545	0.04
CT-3	5/28/2002	OS-02	19505	0.854	0.039
CT-3	5/23/2002	OS-01	19465	0.854	0.041