

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:24

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stackla

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1A_NOXCORR ppm	Average 1A_NOXC_24 ppm	Average 1A_COCORR ppm	Average 1A_COC_24 ppm	Average 1A_HICOMB mmbtu
08/03/2011 00:00	1.4	1.4	4.8	3.0	2164.0
08/03/2011 01:00	1.5	1.4	4.8	4.8	2157.6
08/03/2011 02:00	1.5	1.5	4.8	4.8	2156.7
08/03/2011 03:00	1.5	1.5	5.0	4.8	2158.5
08/03/2011 04:00	1.5	1.5	5.0	4.9	2156.5
08/03/2011 05:00	1.5	1.5	4.8	4.9	2155.7
08/03/2011 06:00	1.4	1.5	4.9	4.9	2154.8
08/03/2011 07:00	1.5	1.5	4.4	4.9	2160.4
08/03/2011 08:00	1.5	1.5	3.4	4.8	2162.7
08/03/2011 09:00	1.4	1.5	3.2	4.7	2166.2
08/03/2011 10:00	1.5	1.5	2.9	4.5	2161.3
08/03/2011 11:00	1.5	1.5	2.4	4.4	2161.7
08/03/2011 12:00	1.4	1.5	2.4	4.2	2161.5
08/03/2011 13:00	1.5	1.5	2.0	4.1	2162.3
08/03/2011 14:00	1.4	1.5	1.5	3.9	2158.5
08/03/2011 15:00	1.4	1.5	1.5	3.8	2157.2
08/03/2011 16:00	1.5	1.5	2.2	3.6	2161.7
08/03/2011 17:00	1.5	1.5	2.6	3.5	2164.4
08/03/2011 18:00	1.4	1.5	3.5	3.5	2168.1
08/03/2011 19:00	1.4	1.5	5.5	3.5	2166.6
08/03/2011 20:00	1.4	1.5	4.7	3.6	2157.6
08/03/2011 21:00	1.4	1.5	4.8	3.6	2156.3
08/03/2011 22:00	1.5	1.5	4.4	3.7	2159.8
08/03/2011 23:00	1.5	1.5	4.6	3.7	2163.4
08/04/2011 00:00	1.5	1.5 ✓	4.1	3.8 ✓	2161.6
Final Average*	1.5	1.5	3.8	4.2	2160.6
Maximum*	1.5	1.5	5.5	4.9	2168.1
Minimum*	1.4	1.4	1.5	3.0	2154.8

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:25

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack1b

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average	Average	Average	Average	Average
	1B_NOXCORR ppm	1B_NOXC_24 ppm	1B_COCORR ppm	1B_COC_24 ppm	1B_HICOMB mmbtu
08/03/2011 00:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 01:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 02:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 03:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 04:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 05:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 06:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 07:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 08:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 09:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 10:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 11:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 12:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 13:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 14:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 15:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 16:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 17:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 18:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 19:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 20:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 21:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 22:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 23:00	N/A	N/A	N/A	N/A	N/A
08/04/2011 00:00	N/A	N/A	N/A	N/A	N/A
Final Average*	N/A	N/A	N/A	N/A	N/A
Maximum*	N/A	N/A	N/A	N/A	N/A
Minimum*	N/A	N/A	N/A	N/A	N/A

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:25

C any: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stacklc

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1C_NOXCORR ppm	Average 1C_NOXC_24 ppm	Average 1C_COCORR ppm	Average 1C_COC_24 ppm	Average 1C_HICOMB mmbtu
08/03/2011 00:00	1.5	1.5	1.3	0.9	2155.8
08/03/2011 01:00	1.5	1.5	1.4	1.3	2147.9
08/03/2011 02:00	1.5	1.5	1.5	1.4	2147.4
08/03/2011 03:00	1.5	1.5	1.4	1.4	2149.8
08/03/2011 04:00	1.5	1.5	1.3	1.4	2147.2
08/03/2011 05:00	1.5	1.5	1.3	1.4	2146.5
08/03/2011 06:00	1.5	1.5	1.4	1.4	2147.0
08/03/2011 07:00	1.5	1.5	1.1	1.4	2152.6
08/03/2011 08:00	1.5	1.5	0.9	1.3	2155.1
08/03/2011 09:00	1.5	1.5	0.8	1.3	2156.9
08/03/2011 10:00	1.5	1.5	0.8	1.2	2153.1
08/03/2011 11:00	1.5	1.5	0.7	1.2	2150.5
08/03/2011 12:00	1.5	1.5	0.8	1.2	2146.9
08/03/2011 13:00	1.5	1.5	0.6	1.1	2153.2
08/03/2011 14:00	1.5	1.5	0.5	1.1	2148.5
08/03/2011 15:00	1.5	1.5	0.6	1.0	2145.5
08/03/2011 16:00	1.5	1.5	0.8	1.0	2151.4
08/03/2011 17:00	1.5	1.5	0.9	1.0	2155.2
08/03/2011 18:00	1.5	1.5	1.0	1.0	2158.7
08/03/2011 19:00	1.5	1.5	1.5	1.0	2159.0
08/03/2011 20:00	1.5	1.5	1.3	1.0	2151.0
08/03/2011 21:00	1.5	1.5	1.3	1.0	2145.0
08/03/2011 22:00	1.5	1.5	1.1	1.0	2146.6
08/03/2011 23:00	1.5	1.5	1.2	1.1	2155.1
08/04/2011 00:00	1.5	1.5 ✓	1.1	1.1 ✓	2154.0
Final Average*	1.5	1.5	1.1	1.2	2151.2
Maximum*	1.5	1.5	1.5	1.4	2159.0
Minimum*	1.5	1.5	0.5	0.9	2145.0

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:22

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2a

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2A_NOXCORR ppm	Average 2A_NOXC_24 ppm	Average 2A_COCORR ppm	Average 2A_COC_24 ppm	Average 2A_HICOMB mmbtu
08/03/2011 00:00	N/A	23.2	N/A	150.9	N/A
08/03/2011 01:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 02:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 03:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 04:00	N/A	N/A	N/A	N/A	N/A
08/03/2011 05:00	24.6	N/A	1623.1	N/A	985.6
08/03/2011 06:00	18.2	N/A	906.3	N/A	1334.3
08/03/2011 07:00	14.5	N/A	64.8	N/A	1580.2
08/03/2011 08:00	14.6	N/A	5.8	N/A	1585.5
08/03/2011 09:00	13.4	N/A	9.1	N/A	1564.6
08/03/2011 10:00	13.3	13.4	10.0	9.1	1556.0
08/03/2011 11:00	12.9	13.3	11.6	9.6	1543.7
08/03/2011 12:00	7.7	13.2	13.3	10.2	1734.1
08/03/2011 13:00	3.1	11.8	2.2	11.0	2120.5
08/03/2011 14:00	3.9	10.1	2.0	9.2	2113.6
08/03/2011 15:00	2.6	9.0	86.9	8.0	1952.7
08/03/2011 16:00	18.1	8.1	942.9	19.3	1304.2
08/03/2011 17:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 18:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 19:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 20:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 21:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 22:00	N/A	9.4	N/A	135.6	N/A
08/03/2011 23:00	N/A	9.4	N/A	135.6	N/A
08/04/2011 00:00	N/A	9.4	N/A	135.6	N/A
Final Average*	12.2	11.1	306.5	82.0	1614.6
Maximum*	24.6	23.2	1623.1	150.9	2120.5
Minimum*	2.6	8.1	2.0	8.0	985.6

Fuel Oil
 Comm.

*Does not include Invalid Averaging Periods ("N/A")

04:51 - Cold S/D (gas)
 06:46 - Fuel Swap (to oil)
 07:34 - CO compliance
 (CO bounced in/out of comp. several times)
 15:54 - Fuel swap (to gas)
 16:20 - CEMS process off
 16:41 - S/D
 16:51 - S/D complete

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:22

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2b

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2B_NOXCORR ppm	Average 2B_NOXC_24 ppm	Average 2B_COCORR ppm	Average 2B_COC_24 ppm	Average 2B_HICOMB mmbtu
08/03/2011 00:00	1.5	1.6	2.2	1.0	2214.4
08/03/2011 01:00	1.6	1.5	3.2	2.2	2006.4
08/03/2011 02:00	1.6	1.6	3.4	2.7	2004.5
08/03/2011 03:00	1.6	1.6	3.5	3.0	2005.4
08/03/2011 04:00	1.6	1.6	3.2	3.1	2004.6
08/03/2011 05:00	1.6	1.6	0.9	3.1	2393.2
08/03/2011 06:00	1.6	1.6	0.2	2.7	2506.4
08/03/2011 07:00	1.6	1.6	0.2	2.4	2500.2
08/03/2011 08:00	1.6	1.6	0.2	2.1	2498.5
08/03/2011 09:00	1.6	1.6	0.5	1.9	2638.5
08/03/2011 10:00	1.6	1.6	0.5	1.8	2627.8
08/03/2011 11:00	1.6	1.6	0.4	1.6	2613.9
08/03/2011 12:00	1.6	1.6	0.4	1.5	2621.9
08/03/2011 13:00	1.6	1.6	0.4	1.5	2607.3
08/03/2011 14:00	1.6	1.6	0.3	1.4	2594.4
08/03/2011 15:00	1.6	1.6	0.4	1.3	2588.9
08/03/2011 16:00	1.6	1.6	0.5	1.3	2593.2
08/03/2011 17:00	1.6	1.6	0.5	1.2	2615.2
08/03/2011 18:00	1.6	1.6	0.5	1.2	2649.8
08/03/2011 19:00	1.6	1.6	0.5	1.1	2687.3
08/03/2011 20:00	1.6	1.6	0.5	1.1	2674.3
08/03/2011 21:00	1.6	1.6	0.5	1.1	2675.9
08/03/2011 22:00	1.6	1.6	0.5	1.1	2481.3
08/03/2011 23:00	1.5	1.6	1.6	1.0	2327.2
08/04/2011 00:00	1.5	1.6 ✓	2.7	1.1 ✓	2193.2
Final Average*	1.6	1.6	1.1	1.7	2452.9
Maximum*	1.6	1.6	3.5	3.1	2687.3
Minimum*	1.5	1.5	0.2	1.0	2004.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:22

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2c

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2C_NOXCORR ppm	Average 2C_NOXC_24 ppm	Average 2C_COCORR ppm	Average 2C_COC_24 ppm	Average 2C_HICOMB mmbtu
08/03/2011 00:00	1.5	1.6	1.2	1.1	2340.7
08/03/2011 01:00	1.5	1.5	0.6	1.2	2483.5
08/03/2011 02:00	1.6	1.5	0.7	0.9	2481.0
08/03/2011 03:00	1.5	1.5	0.7	0.8	2480.7
08/03/2011 04:00	1.6	1.5	0.6	0.8	2480.7
08/03/2011 05:00	1.6	1.5	0.6	0.8	2479.9
08/03/2011 06:00	1.5	1.5	0.6	0.7	2479.5
08/03/2011 07:00	1.6	1.5	0.5	0.7	2484.9
08/03/2011 08:00	1.6	1.6	0.4	0.7	2483.3
08/03/2011 09:00	1.6	1.6	0.5	0.7	2622.9
08/03/2011 10:00	1.6	1.6	0.5	0.6	2614.2
08/03/2011 11:00	1.6	1.6	0.4	0.6	2602.4
08/03/2011 12:00	1.6	1.6	0.5	0.6	2610.7
08/03/2011 13:00	1.6	1.6	0.4	0.6	2594.0
08/03/2011 14:00	1.6	1.6	0.4	0.6	2582.0
08/03/2011 15:00	1.6	1.6	0.4	0.6	2579.2
08/03/2011 16:00	1.6	1.6	0.5	0.6	2584.5
08/03/2011 17:00	1.6	1.6	0.5	0.6	2605.3
08/03/2011 18:00	1.6	1.6	0.5	0.6	2638.9
08/03/2011 19:00	1.6	1.6	0.7	0.6	2647.4
08/03/2011 20:00	1.6	1.6	0.6	0.6	2648.0
08/03/2011 21:00	1.6	1.6	0.7	0.6	2642.9
08/03/2011 22:00	1.6	1.6	0.6	0.6	2487.4
08/03/2011 23:00	1.5	1.6	1.0	0.6	2412.7
08/04/2011 00:00	1.6	1.6 ✓	1.1	0.6 ✓	2391.0
Final Average*	1.6	1.6	0.6	0.7	2538.3
Maximum*	1.6	1.6	1.2	1.2	2648.0
Minimum*	1.5	1.5	0.4	0.6	2340.7

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:25

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3a

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3A_NOXCORR ppm	Average 3A_NOXC_24 ppm	Average 3A_COCORR ppm	Average 3A_COC_24 ppm	Average 3A_HICOMB mmbtu
08/03/2011 00:00	1.6	1.6	0.5	1.1	2388.7
08/03/2011 01:00	1.5	1.6	1.9	0.5	2076.3
08/03/2011 02:00	1.6	1.6	2.6	1.2	1893.3
08/03/2011 03:00	1.6	1.6	2.5	1.7	1875.5
08/03/2011 04:00	1.6	1.6	1.5	1.9	1966.5
08/03/2011 05:00	1.6	1.6	0.2	1.8	2195.2
08/03/2011 06:00	1.6	1.6	0.1	1.5	2345.6
08/03/2011 07:00	1.6	1.6	0.0	1.3	2439.3
08/03/2011 08:00	1.6	1.6	0.2	1.2	2441.3
08/03/2011 09:00	1.6	1.6	1.0	1.1	2691.1
08/03/2011 10:00	1.6	1.6	1.1	1.1	2714.4
08/03/2011 11:00	1.6	1.6	1.1	1.1	2711.7
08/03/2011 12:00	1.6	1.6	1.2	1.1	2711.8
08/03/2011 13:00	1.7	1.6	1.1	1.1	2708.7
08/03/2011 14:00	1.6	1.6	0.9	1.1	2711.8
08/03/2011 15:00	1.6	1.6	1.0	1.1	2704.4
08/03/2011 16:00	1.6	1.6	1.1	1.1	2689.9
08/03/2011 17:00	1.6	1.6	1.0	1.1	2704.0
08/03/2011 18:00	1.6	1.6	1.0	1.1	2721.4
08/03/2011 19:00	1.6	1.6	0.9	1.1	2745.5
08/03/2011 20:00	1.6	1.6	0.9	1.0	2737.3
08/03/2011 21:00	1.6	1.6	0.9	1.0	2732.8
08/03/2011 22:00	1.6	1.6	0.5	1.0	2500.3
08/03/2011 23:00	1.6	1.6	0.4	1.0	2467.5
08/04/2011 00:00	1.6	1.6 ✓	0.8	1.0 ✓	2353.5
Final Average*	1.6	1.6	1.0	1.2	2489.1
Maximum*	1.7	1.6	2.6	1.9	2745.5
Minimum*	1.5	1.6	0.0	0.5	1875.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:26

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3b

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3B_NOXCORR ppm	Average 3B_NOXC_24 ppm	Average 3B_COCORR ppm	Average 3B_COC_24 ppm	Average 3B_HICOMB mmbtu
08/03/2011 00:00	1.4	1.4	0.4	1.2	2406.8
08/03/2011 01:00	1.4	1.4	2.1	0.4	2088.7
08/03/2011 02:00	1.5	1.4	3.9	1.2	1906.9
08/03/2011 03:00	1.6	1.4	3.9	2.1	1889.8
08/03/2011 04:00	1.6	1.4	2.1	2.6	1979.0
08/03/2011 05:00	1.6	1.5	0.8	2.5	2211.4
08/03/2011 06:00	1.6	1.5	0.6	2.2	2361.0
08/03/2011 07:00	1.6	1.5	0.2	2.0	2450.6
08/03/2011 08:00	1.6	1.5	0.1	1.7	2447.5
08/03/2011 09:00	1.6	1.5	0.7	1.6	2699.0
08/03/2011 10:00	1.6	1.5	0.7	1.5	2721.9
08/03/2011 11:00	1.6	1.5	0.7	1.4	2721.4
08/03/2011 12:00	1.6	1.5	0.7	1.4	2718.6
08/03/2011 13:00	1.6	1.5	0.7	1.3	2715.3
08/03/2011 14:00	1.6	1.6	0.7	1.3	2721.0
08/03/2011 15:00	1.6	1.6	0.7	1.2	2714.1
08/03/2011 16:00	1.6	1.6	0.8	1.2	2704.2
08/03/2011 17:00	1.6	1.6	0.7	1.2	2715.0
08/03/2011 18:00	1.6	1.6	0.7	1.1	2726.8
08/03/2011 19:00	1.6	1.6	0.6	1.1	2750.7
08/03/2011 20:00	1.6	1.6	0.7	1.1	2744.9
08/03/2011 21:00	1.6	1.6	0.7	1.1	2742.1
08/03/2011 22:00	1.6	1.6	0.2	1.1	2518.4
08/03/2011 23:00	1.6	1.6	0.2	1.0	2488.8
08/04/2011 00:00	1.5	1.6 ✓	0.5	1.0	2367.1
Final Average*	1.6	1.5	1.0	1.4	2500.4
Maximum*	1.6	1.6	3.9	2.6	2750.7
Minimum*	1.4	1.4	0.1	0.4	1889.8

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 8/4/2011 06:26

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3c

Period Start: 8/3/2011 00:00
 Period End: 8/4/2011 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3C_NOXCORR ppm	Average 3C_NOXC_24 ppm	Average 3C_COCORR ppm	Average 3C_COC_24 ppm	Average 3C_HICOMB mmbtu
08/03/2011 00:00	1.3	1.4	1.3	1.7	2388.0
08/03/2011 01:00	1.2	1.3	2.8	1.3	2072.6
08/03/2011 02:00	1.4	1.3	4.7	2.0	1892.5
08/03/2011 03:00	1.6	1.3	4.8	2.9	1871.0
08/03/2011 04:00	1.5	1.4	2.3	3.4	1968.5
08/03/2011 05:00	1.5	1.4	1.5	3.2	2192.2
08/03/2011 06:00	1.5	1.4	1.5	2.9	2349.4
08/03/2011 07:00	1.6	1.4	0.9	2.7	2441.1
08/03/2011 08:00	1.6	1.4	0.6	2.5	2452.0
08/03/2011 09:00	1.6	1.5	1.2	2.3	2693.9
08/03/2011 10:00	1.6	1.5	1.2	2.2	2718.1
08/03/2011 11:00	1.6	1.5	1.2	2.1	2715.2
08/03/2011 12:00	1.6	1.5	1.2	2.0	2714.7
08/03/2011 13:00	1.6	1.5	1.2	1.9	2710.6
08/03/2011 14:00	1.6	1.5	1.1	1.9	2715.1
08/03/2011 15:00	1.6	1.5	1.2	1.8	2709.4
08/03/2011 16:00	1.6	1.5	1.2	1.8	2702.9
08/03/2011 17:00	1.6	1.5	1.1	1.8	2712.2
08/03/2011 18:00	1.6	1.5	1.2	1.7	2723.4
08/03/2011 19:00	1.6	1.5	1.2	1.7	2744.9
08/03/2011 20:00	1.6	1.5	1.2	1.7	2739.5
08/03/2011 21:00	1.6	1.5	1.2	1.7	2735.8
08/03/2011 22:00	1.6	1.5	0.8	1.6	2514.2
08/03/2011 23:00	1.6	1.6	0.9	1.6	2482.3
08/04/2011 00:00	1.5	1.6 ✓	1.5	1.6	2352.0
Final Average*	1.5	1.5	1.6	2.1	2492.5
Maximum*	1.6	1.6	4.8	3.4	2744.9
Minimum*	1.2	1.3	0.6	1.3	1871.0

*Does not include Invalid Averaging Periods ("N/A")