

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:07

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stackla

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1A_NOXCORR ppm	Average 1A_NOXC_24 ppm	Average 1A_COCORR ppm	Average 1A_COC_24 ppm	Average 1A_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	5.5	1.3	2066.1
09/24/2012 01:00	1.7	1.7	5.5	5.5	2067.2
09/24/2012 02:00	1.7	1.7	5.6	5.5	2065.5
09/24/2012 03:00	1.7	1.7	5.5	5.5	2066.2
09/24/2012 04:00	1.7	1.7	4.7	5.5	2073.4
09/24/2012 05:00	1.7	1.7	1.1	5.4	2350.4
09/24/2012 06:00	1.8	1.7	0.4	4.6	2408.0
09/24/2012 07:00	1.8	1.7	1.1	4.0	2338.8
09/24/2012 08:00	1.6	1.7	0.4	3.7	2442.0
09/24/2012 09:00	1.7	1.7	0.2	3.3	2444.0
09/24/2012 10:00	1.7	1.7	0.2	3.0	2426.4
09/24/2012 11:00	1.7	1.7	0.1	2.7	2424.1
09/24/2012 12:00	1.7	1.7	0.1	2.5	2417.5
09/24/2012 13:00	1.8	1.7	0.1	2.3	2409.9
09/24/2012 14:00	1.7	1.7	0.1	2.2	2411.0
09/24/2012 15:00	1.7	1.7	0.1	2.0	2414.6
09/24/2012 16:00	1.7	1.7	0.1	1.9	2417.9
09/24/2012 17:00	1.7	1.7	0.2	1.8	2424.5
09/24/2012 18:00	1.7	1.7	0.1	1.7	2438.3
09/24/2012 19:00	1.7	1.7	0.2	1.6	2440.4
09/24/2012 20:00	1.7	1.7	0.3	1.6	2437.3
09/24/2012 21:00	1.6	1.7	1.6	1.5	2247.6
09/24/2012 22:00	1.7	1.7	4.8	1.5	2064.3
09/24/2012 23:00	1.7	1.7	4.8	1.6	2065.1
09/25/2012 00:00	1.7	1.7	5.1	1.8	2066.2
Final Average*	1.7	1.7	1.9	3.0	2297.1
Maximum*	1.8	1.7	5.6	5.5	2444.0
Minimum*	1.6	1.7	0.1	1.3	2064.3

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:07

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack1b

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1B_NOXCORR ppm	Average 1B_NOXC_24 ppm	Average 1B_COCORR ppm	Average 1B_COC_24 ppm	Average 1B_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	5.3	1.9	2057.7
09/24/2012 01:00	1.7	1.7	5.7	5.3	2056.6
09/24/2012 02:00	1.7	1.7	5.6	5.5	2055.5
09/24/2012 03:00	1.7	1.7	5.1	5.5	2056.4
09/24/2012 04:00	1.7	1.7	4.1	5.4	2064.6
09/24/2012 05:00	1.7	1.7	1.5	5.1	2315.3
09/24/2012 06:00	1.7	1.7	0.8	4.5	2365.1
09/24/2012 07:00	1.6	1.7	1.7	4.0	2315.8
09/24/2012 08:00	1.7	1.7	0.8	3.7	2388.0
09/24/2012 09:00	1.7	1.7	0.5	3.4	2385.6
09/24/2012 10:00	1.7	1.7	0.4	3.1	2373.0
09/24/2012 11:00	1.7	1.7	0.4	2.9	2365.8
09/24/2012 12:00	1.7	1.7	0.4	2.6	2356.8
09/24/2012 13:00	1.7	1.7	0.4	2.5	2349.4
09/24/2012 14:00	1.7	1.7	0.4	2.3	2344.8
09/24/2012 15:00	1.7	1.7	0.4	2.2	2346.2
09/24/2012 16:00	1.7	1.7	0.4	2.1	2355.5
09/24/2012 17:00	1.7	1.7	0.4	2.0	2365.8
09/24/2012 18:00	1.7	1.7	0.4	1.9	2375.9
09/24/2012 19:00	1.7	1.7	0.4	1.8	2383.7
09/24/2012 20:00	1.7	1.7	0.5	1.8	2390.6
09/24/2012 21:00	1.6	1.7	2.0	1.7	2225.4
09/24/2012 22:00	1.7	1.7	5.1	1.7	2054.4
09/24/2012 23:00	1.7	1.7	5.3	1.9	2055.2
09/25/2012 00:00	1.7	1.7	5.4	2.0	2055.2
Final Average*	1.7	1.7	2.1	3.1	2258.3
Maximum*	1.7	1.7	5.7	5.5	2390.6
Minimum*	1.6	1.7	0.4	1.7	2054.4

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:07

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stacklc

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 1C_NOXCORR ppm	Average 1C_NOXC_24 ppm	Average 1C_COCORR ppm	Average 1C_COC_24 ppm	Average 1C_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	1.6	0.6	2158.6
09/24/2012 01:00	1.7	1.7	2.0	1.6	2098.1
09/24/2012 02:00	1.7	1.7	1.7	1.8	2095.2
09/24/2012 03:00	1.7	1.7	1.4	1.7	2096.8
09/24/2012 04:00	1.7	1.7	1.0	1.7	2160.8
09/24/2012 05:00	1.8	1.7	0.4	1.5	2480.3
09/24/2012 06:00	1.7	1.7	0.3	1.3	2531.5
09/24/2012 07:00	1.7	1.7	0.5	1.2	2499.1
09/24/2012 08:00	1.7	1.7	0.3	1.1	2540.8
09/24/2012 09:00	1.7	1.7	0.2	1.0	2530.6
09/24/2012 10:00	1.7	1.7	0.2	0.9	2517.6
09/24/2012 11:00	1.7	1.7	0.2	0.9	2508.3
09/24/2012 12:00	1.7	1.7	0.2	0.8	2502.4
09/24/2012 13:00	1.7	1.7	0.2	0.8	2495.0
09/24/2012 14:00	1.7	1.7	0.2	0.7	2492.4
09/24/2012 15:00	1.7	1.7	0.2	0.7	2493.9
09/24/2012 16:00	1.7	1.7	0.2	0.7	2502.5
09/24/2012 17:00	1.7	1.7	0.2	0.6	2510.9
09/24/2012 18:00	1.7	1.7	0.2	0.6	2522.9
09/24/2012 19:00	1.7	1.7	0.2	0.6	2529.0
09/24/2012 20:00	1.7	1.7	0.2	0.6	2537.8
09/24/2012 21:00	1.6	1.7	0.6	0.6	2393.1
09/24/2012 22:00	1.7	1.7	2.2	0.6	2091.5
09/24/2012 23:00	1.7	1.7	1.7	0.6	2126.7
09/25/2012 00:00	1.7	1.7	1.8	0.7	2116.8
Final Average*	1.7	1.7	0.7	1.0	2381.3
Maximum*	1.8	1.7	2.2	1.8	2540.8
Minimum*	1.6	1.7	0.2	0.6	2091.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:05

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2a

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average	Average	Average	Average	Average
	2A_NOXCORR	2A_NOXC_24	2A_COCORR	2A_COC_24	2A_HICOMB
	ppm	ppm	ppm	ppm	mmbtu
09/24/2012 00:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 01:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 02:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 03:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 04:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 05:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 06:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 07:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 08:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 09:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 10:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 11:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 12:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 13:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 14:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 15:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 16:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 17:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 18:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 19:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 20:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 21:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 22:00	N/A	N/A	N/A	N/A	N/A
09/24/2012 23:00	N/A	N/A	N/A	N/A	N/A
09/25/2012 00:00	N/A	N/A	N/A	N/A	N/A
Final Average*	N/A	N/A	N/A	N/A	N/A
Maximum*	N/A	N/A	N/A	N/A	N/A
Minimum*	N/A	N/A	N/A	N/A	N/A

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:05

Company: Florida Power & Light

Plant: West County Plant

City/St: Loxahatchee, FL 33470

Source: stack2b

Period Start: 9/24/2012 00:00

Period End: 9/25/2012 00:59

Validation Type: 40CFR75 Subpart B

Averaging Period: 1 hr

Type: Block Avg

Period Start	Average 2B_NOXCORR ppm	Average 2B_NOXC_24 ppm	Average 2B_COCORR ppm	Average 2B_COC_24 ppm	Average 2B_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	3.1	2.3	2195.4
09/24/2012 01:00	1.7	1.7	3.4	3.1	2163.3
09/24/2012 02:00	1.7	1.7	4.1	3.3	2118.5
09/24/2012 03:00	1.7	1.7	3.7	3.6	2116.3
09/24/2012 04:00	1.7	1.7	2.9	3.6	2228.2
09/24/2012 05:00	1.7	1.7	1.3	3.4	2465.7
09/24/2012 06:00	1.7	1.7	1.2	3.1	2443.4
09/24/2012 07:00	1.7	1.7	2.4	2.8	2415.8
09/24/2012 08:00	1.7	1.7	0.7	2.8	2465.9
09/24/2012 09:00	1.7	1.7	0.6	2.5	2451.8
09/24/2012 10:00	1.7	1.7	0.8	2.3	2469.3
09/24/2012 11:00	1.7	1.7	0.8	2.2	2485.6
09/24/2012 12:00	1.7	1.7	0.8	2.1	2482.1
09/24/2012 13:00	1.7	1.7	0.8	2.0	2481.9
09/24/2012 14:00	1.7	1.7	0.8	1.9	2481.7
09/24/2012 15:00	1.7	1.7	0.8	1.8	2471.7
09/24/2012 16:00	1.7	1.7	0.8	1.8	2478.1
09/24/2012 17:00	1.7	1.7	0.6	1.7	2460.2
09/24/2012 18:00	1.7	1.7	0.4	1.6	2451.1
09/24/2012 19:00	1.7	1.7	0.4	1.6	2457.6
09/24/2012 20:00	1.7	1.7	0.5	1.5	2467.8
09/24/2012 21:00	1.6	1.7	1.8	1.5	2358.9
09/24/2012 22:00	1.7	1.7	6.6	1.5	1984.5
09/24/2012 23:00	1.7	1.7	3.9	1.7	2085.8
09/25/2012 00:00	1.7	1.7	3.6	1.8	2184.9
Final Average*	1.7	1.7	1.9	2.3	2354.6
Maximum*	1.7	1.7	6.6	3.6	2485.6
Minimum*	1.6	1.7	0.4	1.5	1984.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:05

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack2c

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 2C_NOXCORR ppm	Average 2C_NOXC_24 ppm	Average 2C_COCORR ppm	Average 2C_COC_24 ppm	Average 2C_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	3.6	2.6	2237.8
09/24/2012 01:00	1.7	1.7	4.1	3.6	2205.8
09/24/2012 02:00	1.7	1.7	4.5	3.8	2161.5
09/24/2012 03:00	1.7	1.7	4.3	4.1	2159.3
09/24/2012 04:00	1.7	1.7	3.1	4.1	2270.8
09/24/2012 05:00	1.7	1.7	2.0	3.9	2507.2
09/24/2012 06:00	1.7	1.7	2.0	3.6	2484.3
09/24/2012 07:00	1.7	1.7	2.9	3.4	2459.8
09/24/2012 08:00	1.7	1.7	1.5	3.3	2506.1
09/24/2012 09:00	1.7	1.7	1.5	3.1	2490.1
09/24/2012 10:00	1.7	1.7	1.3	3.0	2476.0
09/24/2012 11:00	1.7	1.7	1.2	2.8	2469.2
09/24/2012 12:00	1.7	1.7	1.2	2.7	2462.9
09/24/2012 13:00	1.7	1.7	1.2	2.6	2461.0
09/24/2012 14:00	1.7	1.7	1.2	2.5	2461.1
09/24/2012 15:00	1.7	1.7	1.3	2.4	2461.7
09/24/2012 16:00	1.7	1.7	1.3	2.3	2467.1
09/24/2012 17:00	1.7	1.7	1.4	2.3	2473.7
09/24/2012 18:00	1.7	1.7	1.4	2.2	2481.9
09/24/2012 19:00	1.7	1.7	1.4	2.2	2488.8
09/24/2012 20:00	1.7	1.7	1.4	2.1	2499.7
09/24/2012 21:00	1.7	1.7	2.4	2.1	2393.1
09/24/2012 22:00	1.7	1.7	5.4	2.1	2011.5
09/24/2012 23:00	1.7	1.7	4.7	2.2	2119.8
09/25/2012 00:00	1.7	1.7	4.0	2.3	2218.7
Final Average*	1.7	1.7	2.4	2.9	2377.2
Maximum*	1.7	1.7	5.4	4.1	2507.2
Minimum*	1.7	1.7	1.2	2.1	2011.5

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:06

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3a

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3A_NOXCORR ppm	Average 3A_NOXC_24 ppm	Average 3A_COCORR ppm	Average 3A_COC_24 ppm	Average 3A_HICOMB mmbtu
09/24/2012 00:00	1.5	1.6	0.9	1.0	2161.3
09/24/2012 01:00	1.6	1.5	1.6	0.9	1829.9
09/24/2012 02:00	1.6	1.5	2.1	1.2	1742.1
09/24/2012 03:00	1.6	1.6	1.8	1.5	1756.0
09/24/2012 04:00	1.6	1.6	1.0	1.6	2058.0
09/24/2012 05:00	1.6	1.6	0.7	1.5	2296.4
09/24/2012 06:00	1.6	1.6	0.7	1.3	2292.2
09/24/2012 07:00	1.6	1.6	0.7	1.2	2287.0
09/24/2012 08:00	1.6	1.6	0.7	1.2	2281.4
09/24/2012 09:00	1.6	1.6	0.7	1.1	2265.1
09/24/2012 10:00	1.6	1.6	0.8	1.1	2256.0
09/24/2012 11:00	1.5	1.6	0.7	1.1	2263.6
09/24/2012 12:00	1.6	1.6	0.7	1.0	2256.6
09/24/2012 13:00	1.6	1.6	0.7	1.0	2253.7
09/24/2012 14:00	1.6	1.6	0.7	1.0	2251.7
09/24/2012 15:00	1.6	1.6	0.7	1.0	2265.2
09/24/2012 16:00	1.6	1.6	0.7	0.9	2272.4
09/24/2012 17:00	1.6	1.6	0.7	0.9	2296.0
09/24/2012 18:00	1.6	1.6	0.7	0.9	2328.5
09/24/2012 19:00	1.6	1.6	0.7	0.9	2315.0
09/24/2012 20:00	1.6	1.6	0.7	0.9	2346.1
09/24/2012 21:00	1.6	1.6	0.7	0.9	2350.5
09/24/2012 22:00	1.6	1.6	0.7	0.9	2335.0
09/24/2012 23:00	1.6	1.6	0.7	0.9	2337.7
09/25/2012 00:00	1.5	1.6	1.2	0.9	2063.7
Final Average*	1.6	1.6	0.9	1.1	2206.4
Maximum*	1.6	1.6	2.1	1.6	2350.5
Minimum*	1.5	1.5	0.7	0.9	1742.1

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:06

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3b

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3B_NOXCORR ppm	Average 3B_NOXC_24 ppm	Average 3B_COCORR ppm	Average 3B_COC_24 ppm	Average 3B_HICOMB mmbtu
09/24/2012 00:00	1.7	1.7	1.0	1.0	2386.2
09/24/2012 01:00	1.7	1.7	2.3	1.0	2052.9
09/24/2012 02:00	1.7	1.7	2.1	1.7	1974.6
09/24/2012 03:00	1.7	1.7	1.7	1.8	1978.4
09/24/2012 04:00	1.7	1.7	1.5	1.8	2269.8
09/24/2012 05:00	1.7	1.7	0.7	1.7	2523.5
09/24/2012 06:00	1.7	1.7	0.6	1.5	2513.1
09/24/2012 07:00	1.7	1.7	0.6	1.4	2508.5
09/24/2012 08:00	1.7	1.7	0.5	1.3	2494.7
09/24/2012 09:00	1.7	1.7	0.5	1.2	2481.9
09/24/2012 10:00	1.7	1.7	0.4	1.1	2469.6
09/24/2012 11:00	1.7	1.7	0.3	1.1	2460.1
09/24/2012 12:00	1.7	1.7	0.3	1.0	2451.9
09/24/2012 13:00	1.7	1.7	0.3	1.0	2448.2
09/24/2012 14:00	1.7	1.7	0.3	0.9	2444.4
09/24/2012 15:00	1.7	1.7	0.4	0.9	2446.4
09/24/2012 16:00	1.7	1.7	0.4	0.8	2450.2
09/24/2012 17:00	1.7	1.7	0.4	0.8	2458.3
09/24/2012 18:00	1.7	1.7	0.4	0.8	2470.6
09/24/2012 19:00	1.7	1.7	0.4	0.8	2473.6
09/24/2012 20:00	1.7	1.7	0.5	0.8	2487.7
09/24/2012 21:00	1.7	1.7	0.5	0.7	2499.1
09/24/2012 22:00	1.7	1.7	0.5	0.7	2513.8
09/24/2012 23:00	1.7	1.7	0.5	0.7	2515.2
09/25/2012 00:00	1.7	1.7	1.5	0.7	2243.5
Final Average*	1.7	1.7	0.7	1.1	2400.6
Maximum*	1.7	1.7	2.3	1.8	2523.5
Minimum*	1.7	1.7	0.3	0.7	1974.6

*Does not include Invalid Averaging Periods ("N/A")

Babcock & Wilcox Power Generation Group NetDAHS©

Average Values Report

Version 59.0

Generated: 9/25/2012 10:06

Company: Florida Power & Light
 Plant: West County Plant
 City/St: Loxahatchee, FL 33470
 Source: stack3c

Period Start: 9/24/2012 00:00
 Period End: 9/25/2012 00:59
 Validation Type: 40CFR75 Subpart B
 Averaging Period: 1 hr
 Type: Block Avg

Period Start	Average 3C_NOXCORR ppm	Average 3C_NOXC_24 ppm	Average 3C_COCORR ppm	Average 3C_COC_24 ppm	Average 3C_HICOMB mmbtu
09/24/2012 00:00	1.6	1.7	1.7	1.4	2344.9
09/24/2012 01:00	1.6	1.6	3.2	1.7	2018.1
09/24/2012 02:00	1.7	1.6	3.6	2.4	1942.4
09/24/2012 03:00	1.7	1.7	3.2	2.8	1945.4
09/24/2012 04:00	1.6	1.7	2.1	2.9	2239.2
09/24/2012 05:00	1.6	1.7	0.9	2.7	2505.6
09/24/2012 06:00	1.6	1.6	0.9	2.4	2495.4
09/24/2012 07:00	1.6	1.6	0.8	2.2	2492.7
09/24/2012 08:00	1.6	1.6	0.8	2.0	2480.5
09/24/2012 09:00	1.6	1.6	0.7	1.9	2463.4
09/24/2012 10:00	1.6	1.6	0.7	1.8	2451.1
09/24/2012 11:00	1.7	1.6	0.6	1.7	2440.9
09/24/2012 12:00	1.6	1.6	0.6	1.6	2434.2
09/24/2012 13:00	1.7	1.6	0.6	1.5	2427.3
09/24/2012 14:00	1.6	1.6	0.6	1.4	2425.4
09/24/2012 15:00	1.6	1.6	0.7	1.4	2422.3
09/24/2012 16:00	1.6	1.6	0.6	1.3	2430.0
09/24/2012 17:00	1.6	1.6	0.6	1.3	2440.0
09/24/2012 18:00	1.6	1.6	0.6	1.3	2448.9
09/24/2012 19:00	1.6	1.6	0.6	1.2	2454.6
09/24/2012 20:00	1.6	1.6	0.7	1.2	2470.0
09/24/2012 21:00	1.6	1.6	0.8	1.2	2482.7
09/24/2012 22:00	1.6	1.6	0.7	1.2	2499.0
09/24/2012 23:00	1.6	1.6	0.8	1.1	2494.0
09/25/2012 00:00	1.7	1.6	2.3	1.1	2208.2
Final Average*	1.6	1.6	1.2	1.7	2378.2
Maximum*	1.7	1.7	3.6	2.9	2505.6
Minimum*	1.6	1.6	0.6	1.1	1942.4

*Does not include Invalid Averaging Periods ("N/A")