



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 21, 2012 12:55 PM

Facility Name: Auburndale Cogeneration Facility

Facility Details

Facility ID (ORISPL): 54658
 Monitoring Plan Locations: 1
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)
1	2011	QTR 1	1619	90	1467.66	1624610	0.5	96548.8	0.052	38.2	
		QTR 2	1361	91	1208.51	1331863	0.4	79152.3	0.053	30.2	
		QTR 3	1314	89	1167.15	1245972	0.4	74047.1	0.052	27.7	
		QTR 4	1398	81	1269.40	1375899	0.4	81768.5	0.053	30.3	
		Ozone Season To Date	2228		1978.77	2138927				47.8	
		Year To Date	5692	351	5112.72	5578344	1.7	331516.7	0.053	126.4	

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
1	2011	QTR 1	DSL	1
			PNG	1619
		QTR 2	DSL	1
			PNG	1361
		QTR 3	PNG	1314
		QTR 4	DSL	2
PNG	1398			



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 21, 2012 12:55 PM

Facility Name: Auburndale Cogeneration Facility

Facility Details

Facility ID (ORISPL): 54658
 Monitoring Plan Locations: 1
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)	
1	2012	QTR 1	1624	90	1478.06	1633092	0.5	97053.0	0.053	37.2		
		Ozone Season To Date										
		Year To Date	1624	90	1478.06	1633092	0.5	97053.0	0.053	37.2		

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
1	2012	QTR 1	DSL	4
			PNG	1624