



Tiger Bay Compliance Data 2011

Run	September 14, 2011		Fuel MSCFH	Inlet Temp ° F	Calculated Heat Input mmBTU/hr	Permitted Heat Input @ 27 deg F mmBTU/hr	Permitted Heat Input at Inlet Temp mmBTU/hr	Capacity
	Start	End						
1	7:39	8:00	1458.0	74.7	1338	1710	1623	82.4%
2	8:24	8:45	1452.1	76.0	1332		1620	82.2%
3	9:03	9:24	1439.9	78.6	1321		1615	81.8%
4	9:48	10:09	1425.9	81.7	1308		1610	81.2%
5	10:27	10:48	1419.1	83.3	1302		1607	81.0%
6	11:02	11:23	1414.8	84.6	1298		1605	80.9%
7	11:02	11:23	1414.8	84.6	1298		1605	80.9%
8	11:02	11:23	1414.8	84.6	1298		1605	80.9%
9	11:02	11:23	1414.8	84.6	1298		1605	80.9%
<b>Average</b>				<b>81.4</b>	<b>1310</b>		<b>1610</b>	<b>81.4%</b>