

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 June - 2011

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	23.67	12.7	488.2	74.3
02	46.40	13.2	957.7	77.4
03	39.59	12.7	758.9	78.6
04	29.00	12.8	597.0	78.4
05	25.96	13.3	534.2	79.6
06	21.21	12.9	436.6	79.9
07	28.44	13.7	585.5	78.5
08	32.57	13.2	669.9	76.9
09	25.80	12.9	530.7	77.8
10	14.35	12.8	294.8	79.8
11	1.51	2.4	31.1	80.1
12	0.28	0.7	5.8	81.9
13	9.68	8.7	199.1	82.8
14	33.64	13.1	692.0	81.5
15	64.85	22.1	1338.3	79.3
16	63.01	24.0	1296.5	78.3
17	24.63	13.5	506.2	81.2
18	15.99	12.7	329.1	78.1
19	16.01	12.6	329.4	81.5
20	16.33	12.6	335.3	84.1
21	18.17	12.6	373.0	84.8
22	18.31	12.5	375.9	83.8
23	25.64	13.2	526.4	81.4
24	25.88	12.9	531.7	77.5
25	17.00	12.7	349.5	75.6
26	8.17	9.1	167.7	78.1
27	4.73	8.3	97.4	75.9
28	2.68	6.0	55.0	74.6
29	Down	0.0	Down	73.8
30	0.65	1.0	13.4	75.5
Average Total	654.2	341	13406	79.0

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 July - 2011

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	3.70	4.8	76.2	77.4
02	Down	0.0	Down	77.8
03	Down	0.0	Down	79.7
04	0.13	0.3	2.6	80.3
05	3.05	3.4	62.8	81.2
06	9.06	9.1	186.3	80.7
07	10.98	14.3	226.8	77.0
08	6.16	7.2	127.5	77.8
09	Down	0.0	Down	82.3
10	Down	0.0	Down	81.6
11	8.14	11.1	167.2	82.7
12	6.55	11.1	134.5	83.1
13	10.34	13.0	212.2	83.3
14	2.78	5.4	57.1	84.4
15	1.65	3.3	33.7	80.7
16	0.02	0.0	0.4	79.1
17	0.00	0.0	0.1	80.9
18	1.61	3.1	33.3	80.4
19	4.08	7.5	84.4	81.3
20	13.06	18.7	272.9	84.4
21	16.19	17.3	337.2	84.8
22	7.24	9.1	149.5	78.6
23	Down	0.0	Down	79.8
24	Down	0.0	Down	84.0
25	2.72	5.0	56.0	84.2
26	7.56	10.2	156.5	79.8
27	4.95	9.4	101.8	79.4
28	11.46	16.7	236.9	81.9
29	2.71	5.3	55.8	83.0
30	Down	0.0	Down	84.4
31	Down	0.0	Down	82.9
Average Total	134.1	185	2772	81.3

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 August - 2011

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	2.94	5.3	60.2	82.6
02	12.57	16.4	259.3	81.0
03	5.76	12.1	118.4	83.0
04	6.30	14.4	130.2	84.4
05	5.30	12.6	109.0	83.6
06	Down	0.0	Down	84.5
07	Down	0.0	Down	84.6
08	2.57	5.7	52.9	81.7
09	2.29	4.4	47.1	76.9
10	1.85	4.8	37.9	77.5
11	4.01	8.7	82.2	84.4
12	3.59	9.4	73.7	84.0
13	Down	0.0	Down	83.1
14	Down	0.0	Down	83.1
15	0.19	0.6	4.0	83.9
16	2.64	5.6	54.2	83.2
17	2.66	5.3	54.7	79.5
18	3.32	8.3	68.1	78.8
19	2.83	9.1	57.8	78.4
20	Down	0.0	Down	80.0
21	Down	0.0	Down	82.7
22	2.66	5.5	54.6	83.1
23	1.63	3.7	33.5	80.1
24	2.44	5.2	50.3	79.3
25	5.70	8.8	117.2	81.7
26	6.30	7.5	130.4	83.9
27	Down	0.0	Down	80.4
28	Down	0.0	Down	82.4
29	2.09	5.3	43.0	77.2
30	2.53	5.5	52.2	78.8
31	1.84	5.0	37.8	77.9
Average Total	84.0	169	1729	81.5

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 September - 2011

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	2.25	5.0	46.2	78.2
02	7.70	12.1	158.8	79.0
03	Down	0.0	Down	78.4
04	Down	0.0	Down	80.0
05	Down	0.0	Down	84.3
06	6.72	16.1	138.4	78.4
07	7.26	20.3	149.3	76.6
08	3.50	11.7	71.8	77.8
09	6.35	16.4	130.4	77.1
10	0.03	0.0	0.5	79.3
11	Down	0.0	Down	82.0
12	5.13	13.8	105.5	81.7
13	5.54	15.8	114.0	80.2
14	2.17	5.6	44.8	79.0
15	4.29	9.8	88.3	79.9
16	3.67	10.6	75.8	81.4
17	Down	0.0	Down	80.5
18	Down	0.0	Down	78.2
19	5.62	14.7	115.6	79.5
20	2.11	5.0	43.2	81.1
21	Down	0.0	Down	81.1
22	Down	0.0	Down	79.2
23	Down	0.0	Down	78.9
24	Down	0.0	Down	80.5
25	Down	0.0	Down	79.1
26	0.02	0.0	0.5	79.7
27	7.06	6.8	145.5	75.0
28	8.15	9.5	168.1	80.9
29	12.77	12.5	262.7	79.7
30	9.00	8.5	131.0	74.6
Average				
Total	99.3	194	1990	79.4

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 October - 2011

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	0.44	1.2	8.9	73.8
02	Down	0.0	Down	68.3
03	Down	0.0	Down	71.0
04	Down	0.0	Down	73.1
05	Down	0.0	Down	73.4
06	Down	0.0	Down	73.4
07	Down	0.0	Down	72.6
08	Down	0.0	Down	69.2
09	Down	0.0	Down	70.3
10	Down	0.0	Down	74.2
11	Down	0.0	Down	77.1
12	0.21	0.2	4.5	77.0
13	Down	0.0	Down	76.4
14	Down	0.0	Down	75.6
15	0.03	0.0	0.7	72.8
16	0.61	1.5	13.1	75.3
17	33.57	20.2	712.2	76.0
18	24.54	20.2	502.9	74.7
19	37.78	20.3	782.7	73.7
20	35.93	24.0	742.1	63.0
21	44.31	24.0	923.4	62.2
22	8.15	9.7	170.1	63.7
23	Down	0.0	Down	67.8
24	17.43	10.7	363.7	67.0
25	30.37	13.8	633.0	67.8
26	35.95	15.9	746.6	70.9
27	41.34	24.0	852.5	73.3
28	41.40	24.0	852.8	70.6
29	7.62	10.2	156.9	71.9
30	0.05	0.1	1.0	66.5
31	38.50	20.3	793.3	68.6
Average Total	398.2	240	8260	71.3

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 November - 2011

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	50.82	24.0	1047.8	67.2
02	49.31	24.0	1018.5	67.3
03	48.38	24.0	997.6	69.2
04	50.65	24.0	1046.2	64.3
05	13.76	11.4	284.0	62.3
06	Down	0.0	Down	65.7
07	35.70	18.9	737.6	69.0
08	50.65	24.0	1045.4	69.3
09	50.04	24.0	1032.5	70.1
10	51.27	24.0	1057.1	68.0
11	51.32	24.0	1058.1	57.6
12	12.91	8.3	266.0	61.4
13	Down	0.0	Down	66.3
14	36.64	19.2	757.4	70.7
15	47.59	23.2	982.8	76.2
16	37.51	19.1	775.0	76.8
17	26.81	14.3	554.6	73.5
18	28.85	13.8	598.5	67.4
19	12.09	6.4	250.9	71.0
20	Down	0.0	Down	72.1
21	13.84	6.9	286.8	72.7
22	25.75	13.1	533.7	74.1
23	25.79	13.7	534.3	71.3
24	7.68	6.0	158.1	66.3
25	3.12	2.5	64.3	65.8
26	16.28	13.4	336.2	68.1
27	17.77	13.0	367.0	68.3
28	28.62	13.0	591.8	65.4
29	41.38	14.1	855.6	61.7
30	43.03	15.4	889.8	56.6
Average Total	877.6	438	18128	67.9

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 December - 2011

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	73.07	21.3	1512.7	56.7
02	85.97	24.0	1780.2	61.4
03	42.96	24.0	887.7	64.1
04	46.06	24.0	952.4	67.6
05	82.80	24.0	1711.0	68.0
06	92.49	24.0	1908.7	67.5
07	93.38	24.0	1924.1	65.9
08	99.69	24.0	2056.8	54.8
09	91.36	24.0	1885.5	67.5
10	56.96	24.0	1175.9	69.6
11	55.10	24.0	1137.8	67.5
12	85.95	24.0	1772.4	68.0
13	101.50	24.0	2091.9	68.3
14	99.23	23.9	2047.2	66.8
15	92.47	23.9	1909.2	66.3
16	98.58	24.0	2035.1	70.7
17	77.54	24.0	1599.0	68.3
18	45.12	24.0	929.1	60.3
19	60.35	24.0	1247.0	62.1
20	65.81	24.0	1359.0	66.4
21	73.86	24.0	1525.5	69.6
22	66.44	24.0	1373.4	70.7
23	56.31	24.0	1164.5	72.4
24	16.83	16.6	347.1	69.0
25	Down	0.0	Down	70.1
26	16.89	12.6	351.5	66.7
27	56.59	24.0	1171.8	65.6
28	70.04	24.0	1446.8	54.4
29	86.79	24.0	1793.7	53.9
30	99.41	24.0	2052.7	62.1
31	96.56	24.0	1995.4	66.6
Average Total	2186.1	698	45145	65.4

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 January - 2012

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	38.24	14.1	789.6	65.4
02	37.22	14.3	769.2	59.6
03	59.48	16.6	1229.4	45.1
04	63.53	21.6	1311.2	45.3
05	70.44	24.0	1451.5	51.6
06	55.39	16.9	1143.0	56.4
07	50.41	16.8	1040.8	60.1
08	50.32	16.8	1039.9	62.7
09	38.77	19.2	801.1	63.7
10	57.69	22.2	1193.6	64.6
11	61.92	24.0	1281.9	62.5
12	52.23	24.0	1079.0	60.4
13	59.71	21.3	1234.7	57.4
14	61.10	21.0	1263.8	50.0
15	63.50	21.6	1313.2	52.5
16	58.56	20.6	1212.8	57.4
17	60.00	20.7	1164.2	63.6
18	78.30	22.4	1622.4	62.5
19	54.11	16.1	1129.8	60.2
20	90.74	24.0	1886.4	62.5
21	81.57	24.0	1691.5	65.2
22	87.39	24.0	1812.7	63.9
23	84.36	24.0	1752.0	69.0
24	77.43	24.0	1615.8	71.0
25	73.90	24.0	1538.0	71.0
26	72.22	24.0	1493.4	71.3
27	67.86	24.0	1404.1	66.7
28	70.13	24.0	1452.9	62.6
29	66.39	24.0	1375.4	62.2
30	81.69	24.0	1691.0	61.0
31	88.01	24.0	1822.7	63.3
Average Total	2012.6	662	41607	61.0

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 February - 2012

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	40.45	15.3	790.8	66.3
02	31.72	16.1	656.5	68.8
03	34.86	15.9	720.1	67.7
04	42.30	18.2	873.3	69.6
05	38.01	16.3	785.9	71.7
06	25.79	13.9	532.2	70.2
07	30.49	11.0	628.2	66.5
08	36.58	11.7	755.5	66.7
09	59.34	18.4	1229.0	63.7
10	48.38	16.4	1000.9	67.8
11	55.00	16.7	1138.3	59.3
12	56.55	21.2	1169.9	44.2
13	57.97	24.0	1199.8	51.5
14	48.89	16.6	1012.4	64.2
15	50.64	16.6	1047.4	69.5
16	38.67	15.6	798.4	71.3
17	51.02	14.5	1054.8	68.5
18	51.53	16.8	1064.8	70.0
19	55.93	17.4	1155.6	70.7
20	52.42	16.6	1084.0	60.6
21	50.11	18.1	1036.7	63.8
22	40.54	14.6	838.8	69.5
23	60.99	20.7	1261.2	73.4
24	50.39	16.0	1042.6	74.6
25	63.82	23.0	1321.2	65.0
26	53.34	24.0	1104.1	63.0
27	72.18	24.0	1494.7	71.4
28	80.21	23.2	1658.5	69.6
29	89.43	24.0	1852.1	72.7
Average Total	1467.6	517	30308	66.6

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 March - 2012

Day	Gas Flow klbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	61.43	17.0	1270.0	74.2
02	52.20	16.0	1078.6	73.6
03	32.97	14.2	681.3	75.9
04	26.06	13.8	538.3	62.9
05	31.15	14.0	645.2	61.0
06	41.53	13.9	858.0	63.0
07	42.36	14.4	876.3	67.7
08	39.80	14.4	822.4	71.1
09	38.84	14.1	802.8	73.3
10	42.19	14.3	871.9	71.0
11	51.73	16.9	1069.3	68.6
12	69.08	21.2	1431.1	69.5
13	81.03	21.6	1602.1	69.6
14	77.96	21.1	1533.4	70.3
15	79.46	21.6	1643.0	71.3
16	85.67	22.0	1771.4	71.7
17	79.24	21.3	1638.0	70.5
18	63.29	18.9	1308.7	70.4
19	73.93	21.4	1531.4	70.9
20	69.22	24.0	1433.0	71.7
21	65.21	24.0	1349.1	73.3
22	49.55	24.0	555.3	75.8
23	59.94	24.0	1011.7	76.2
24	67.23	24.0	1391.8	69.0
25	53.63	22.5	1108.4	70.0
26	44.58	20.0	923.3	69.8
27	68.56	24.0	1417.7	70.6
28	55.86	24.0	1153.7	72.2
29	41.86	21.6	864.7	72.6
30	46.54	24.0	962.1	74.0
31	45.98	24.0	951.3	70.8
Average				70.7
Total	1738.1	612	35095	

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 April - 2012

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	22.58	12.8	464.5	74.6
02	31.64	20.2	651.1	74.3
03	61.17	24.0	1260.6	76.7
04	84.26	24.0	1736.9	76.8
05	80.04	24.0	1653.3	75.6
06	61.49	23.6	1267.8	73.7
07	15.52	12.6	320.3	68.3
08	Down	0.0	Down	68.7
09	25.84	19.8	532.7	71.4
10	46.99	24.0	968.8	73.8
11	57.33	24.0	1183.8	74.0
12	66.83	24.0	1379.9	73.1
13	96.05	24.0	1980.2	73.0
14	76.35	24.0	1572.9	71.6
15	78.43	24.0	1616.4	73.4
16	60.72	24.0	1251.7	73.7
17	51.89	24.0	1069.5	74.2
18	37.93	14.9	782.6	71.9
19	78.11	24.0	1607.4	73.4
20	72.35	24.0	1489.4	71.7
21	88.63	24.0	1825.7	71.1
22	69.89	24.0	1442.7	68.9
23	25.48	13.1	527.6	65.5
24	28.04	12.8	582.5	62.9
25	44.01	13.3	909.6	63.3
26	53.71	19.4	1111.9	65.8
27	65.62	24.0	1356.1	69.4
28	64.42	24.0	1333.2	72.9
29	51.52	24.0	1064.7	72.2
30	27.35	18.5	565.3	74.9
Average Total	1624.2	613	33509	71.7

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 May - 2012

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	26.39	24.0	541.7	77.7
02	40.48	24.0	834.9	76.2
03	50.44	24.0	1042.7	78.5
04	46.92	24.0	967.6	77.5
05	59.18	24.0	1220.8	78.5
06	49.10	24.0	1013.3	78.5
07	59.16	24.0	1221.2	76.8
08	48.28	24.0	995.2	77.2
09	74.65	24.0	1540.5	79.0
10	57.51	24.0	1184.5	78.5
11	90.22	24.0	1858.4	76.6
12	75.16	24.0	1547.8	75.4
13	67.22	24.0	1382.5	75.5
14	74.21	23.8	1528.4	77.4
15	70.06	24.0	1443.4	77.5
16	81.16	24.0	1671.0	72.5
17	73.83	24.0	1520.8	76.0
18	81.33	23.9	1673.1	76.7
19	60.74	24.0	1249.1	76.6
20	20.34	15.8	418.8	76.6
21	40.93	19.8	842.3	77.4
22	66.23	24.0	1366.4	80.0
23	68.81	24.0	1419.9	79.2
24	77.48	24.0	1598.1	78.6
25	55.07	24.0	1133.3	80.3
26	1.17	3.2	24.2	80.4
27	Down	0.0	Down	78.6
28	Down	0.0	Down	79.6
29	31.00	17.9	637.4	77.7
30	65.57	24.0	1357.7	81.6
31	74.72	24.0	1545.5	81.5
Average Total	1687.4	656	34781	77.9

ORANGE COGEN
 BARTOW, FL
Aux Boiler Monthly Operations
 June - 2012

Day	Gas Flow kbs	On-Time	Heat Input mmBtu	Ambient Temp °F
01	57.56	24.0	1185.1	73.1
02	4.28	9.3	87.8	77.8
03	Down	0.0	Down	80.6
04	9.83	9.0	202.3	80.4
05	17.68	13.1	363.9	78.5
06	13.24	10.5	272.4	75.9
07	2.02	4.7	41.4	74.4
08	1.93	4.2	39.5	74.4
09	Down	0.0	Down	78.6
10	Down	0.0	Down	81.4
11	4.08	9.2	83.8	80.7
12	2.13	4.9	43.8	79.3
13	2.04	4.8	41.4	79.5
14	1.95	4.3	40.1	77.8
15	1.27	3.2	25.9	77.2
16	Down	0.0	Down	78.6
17	Down	0.0	Down	76.9
18	8.40	7.9	172.8	77.1
19	16.16	12.6	332.7	76.3
20	16.48	12.7	339.4	75.7
21	16.64	12.9	342.6	77.9
22	16.29	12.8	336.6	78.3
23	15.92	12.3	327.6	77.3
24	17.37	13.0	357.4	75.4
25	17.08	12.8	351.9	78.8
26	10.55	9.3	217.0	79.8
27	Down	0.0	Down	78.5
28	Down	0.0	Down	79.4
29	0.05	0.1	1.1	81.0
30	Down	0.0	Down	80.3
Average Total	253.0	208	5207	78.0

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 June - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	12.4	15	0.056	216.0	4664.6	12.6	4260.3	469
02	15.6	13.3	16	0.057	215.7	4633.8	12.1	4224.5	465
03	15.2	14.2	15	0.055	228.9	4820.3	12.3	4396.7	490
04	15.6	13.7	16	0.058	222.6	4657.2	12.2	4244.1	467
05	15.3	12.8	14	0.052	199.1	4607.2	12.1	4199.5	465
06	15.5	13.2	15	0.056	206.4	4552.3	12.1	4150.6	459
07	15.5	13.0	15	0.055	207.7	4615.0	12.1	4207.7	464
08	15.5	13.3	15	0.055	208.0	4553.5	12.0	4147.1	461
09	15.2	14.7	16	0.057	189.5	4628.1	11.8	4217.9	469
10	15.1	14.2	14	0.053	226.0	4706.8	11.9	4287.3	476
11	15.3	13.6	15	0.054	224.3	4763.0	12.1	4341.6	482
12	15.1	14.1	15	0.053	223.5	4677.3	11.9	4262.5	474
13	15.4	13.4	14	0.051	225.6	4738.2	12.0	4317.0	479
14	15.2	13.7	14	0.052	208.9	4513.5	11.8	4109.6	456
15	15.1	14.1	15	0.053	226.0	4744.4	12.0	4316.5	480
16	15.7	12.8	14	0.051	218.0	4641.8	12.0	4219.3	467
17	15.6	12.0	13	0.047	203.0	4604.9	12.0	4186.2	465
18	15.4	14.1	16	0.058	234.8	4698.7	12.1	4274.0	473
19	15.5	13.5	16	0.056	221.8	4709.7	12.1	4285.7	472
20	15.4	14.3	16	0.058	230.3	4630.2	12.2	4212.6	464
21	15.3	14.4	16	0.057	232.0	4707.2	12.2	4282.1	474
22	15.5	13.5	16	0.057	216.4	4628.0	12.2	4211.0	465
23	15.5	14.1	16	0.059	206.5	4170.5	11.2	3795.4	413
24	15.6	13.8	16	0.059	221.4	4602.0	12.1	4188.1	458
25	15.9	12.8	16	0.059	162.5	3446.1	9.8	3131.7	337
26	15.8	10.8	13	0.049	158.5	4123.1	12.1	3750.6	405
27	15.5	14.1	16	0.060	229.6	4667.8	12.3	4241.1	470
28	15.4	14.2	16	0.058	224.2	4550.8	11.9	4133.4	455
29	15.5	14.2	16	0.059	161.8	3300.6	9.0	3000.7	327
30	17.6	12.1	21	0.079	3.8	55.4	0.6	50.3	0
Average	15.5	13.5	15	0.056					440
Total					6153	131412	345	119645	13201
Yearly tons					17.0				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 July - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.6	13.2	15	0.056	194.0	4226.6	11.8	3495.9	423
02	15.6	13.7	16	0.059	212.5	4345.8	12.1	3961.6	438
03	15.4	14.3	16	0.058	212.8	4332.2	11.9	3959.4	435
04	15.4	13.4	15	0.056	206.1	4551.9	12.3	4146.7	458
05	15.5	14.2	16	0.059	226.5	4548.8	12.1	4137.1	457
06	15.5	12.9	15	0.055	204.7	4566.2	12.6	4157.8	458
07	15.7	11.2	12	0.043	183.7	4380.3	12.0	3986.2	439
08	15.5	10.9	13	0.046	170.8	4404.2	12.1	4014.0	438
09	15.2	10.8	11	0.042	161.6	4372.4	12.0	3979.6	435
10	15.5	10.8	12	0.045	164.4	4309.5	12.1	3921.8	429
11	15.7	10.8	11	0.042	176.7	4356.1	12.0	3975.7	431
12	15.5	10.4	12	0.044	158.9	4328.2	12.0	3948.0	430
13	15.5	11.1	13	0.046	170.5	4334.0	12.0	3950.2	428
14	15.3	11.7	13	0.047	168.5	4242.7	11.9	3860.9	422
15	15.3	12.0	13	0.047	175.2	4306.7	11.9	3921.9	430
16	16.7	12.1	19	0.070	60.3	1342.4	4.4	1219.5	124
17	15.2	11.5	12	0.045	181.0	4616.8	12.7	4205.8	464
18	15.3	11.1	12	0.045	159.6	4209.3	11.9	3845.2	425
19	15.3	11.5	13	0.046	166.5	4208.5	11.9	3824.5	420
20	15.3	11.2	12	0.044	157.4	4107.5	11.8	3734.0	411
21	15.5	12.6	14	0.053	184.0	4147.1	12.3	3777.6	407
22	15.6	11.3	13	0.049	167.2	4131.0	12.2	3764.8	406
23	15.3	12.3	13	0.048	170.1	3975.9	11.6	3630.4	391
24	15.5	12.7	14	0.053	185.7	4096.9	12.1	3735.6	406
25	15.3	12.1	13	0.047	170.5	4067.9	11.6	3712.4	408
26	15.3	12.8	14	0.050	182.9	4103.6	11.6	3740.4	412
27	15.3	13.0	14	0.051	184.5	4114.7	11.6	3752.2	413
28	15.6	12.9	15	0.055	188.6	4121.6	12.1	3752.3	406
29	15.7	13.6	16	0.059	214.8	4372.1	12.1	3978.6	439
30	15.3	14.2	15	0.056	212.5	4334.5	11.9	3951.3	438
31	15.7	14.7	18	0.066	218.8	4335.8	12.1	3954.9	439
Average	15.5	12.3	14	0.051					418
Total					5591	129891	365	117996	12960
Yearly tons					19.8				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 August - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.5	13.9	16	0.059	204.8	4164.7	12.1	3797.7	416
02	15.8	13.7	17	0.063	197.9	4207.0	12.3	3834.3	419
03	15.7	13.6	16	0.059	203.7	4172.3	12.1	3801.1	416
04	15.4	13.7	15	0.055	201.0	4184.7	12.0	3809.2	417
05	15.4	14.4	16	0.060	201.7	4189.4	12.0	3816.4	420
06	15.6	12.6	15	0.053	185.7	4159.8	12.1	3792.2	416
07	15.3	13.3	14	0.052	189.4	4121.5	11.8	3753.6	412
08	15.7	12.6	13	0.048	200.4	4264.0	12.0	3882.4	427
09	15.4	13.7	15	0.055	212.7	4344.5	12.1	3958.7	439
10	15.2	13.0	14	0.050	187.7	4180.7	11.9	3809.0	419
11	15.3	13.6	15	0.053	191.9	4118.8	11.9	3752.3	413
12	15.5	13.4	15	0.055	190.3	4140.7	11.9	3776.2	417
13	15.5	14.0	15	0.057	201.2	4159.4	11.8	3791.5	418
14	15.4	13.2	15	0.054	190.3	4193.5	11.8	3820.8	423
15	15.4	13.5	15	0.055	192.7	4156.5	11.8	3789.1	419
16	15.4	14.2	16	0.058	203.7	4156.9	11.7	3788.9	419
17	15.5	14.0	16	0.058	204.8	4199.7	11.8	3826.6	425
18	15.5	13.1	15	0.054	186.3	4121.1	11.6	3760.4	415
19	15.5	13.9	16	0.058	202.0	4047.9	12.1	3696.0	400
20	15.4	14.4	16	0.058	201.1	4062.5	11.6	3711.4	405
21	15.3	14.1	15	0.054	197.3	4021.5	11.5	3672.7	401
22	15.3	14.6	16	0.058	192.3	3927.4	11.3	3583.1	390
23	15.5	13.6	15	0.056	189.6	4040.0	11.5	3684.9	402
24	15.4	14.0	15	0.057	199.5	4174.7	11.5	3803.2	414
25	15.6	12.3	14	0.053	182.7	4290.0	12.1	3925.8	419
26	15.6	11.3	13	0.049	162.4	4251.6	12.1	3876.1	427
27	15.7	10.8	13	0.048	153.7	4150.4	12.1	3778.2	414
28	15.8	11.0	14	0.051	86.2	2265.6	7.0	2060.5	221
29	15.7	12.9	15	0.056	194.2	4172.6	12.1	3805.1	417
30	15.7	13.0	16	0.058	194.3	4273.9	12.1	3895.6	429
31	15.6	12.8	15	0.055	191.7	4264.3	12.1	3887.2	426
Average	15.5	13.3	15	0.055					410
Total					5893	127178	364	115940	12715
Yearly tons					22.7				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 September - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.2	12.9	14	0.050	140.3	4259.1	11.9	3882.3	428
02	15.2	13.3	14	0.051	196.8	4279.0	11.9	3906.6	432
03	15.4	13.2	15	0.054	198.5	4260.6	12.0	3885.3	431
04	15.5	12.0	13	0.048	184.0	4255.3	12.0	3881.9	430
05	15.4	13.3	14	0.053	202.4	4303.7	12.0	3925.1	435
06	15.5	12.1	13	0.048	189.1	4269.8	12.0	3895.8	431
07	15.5	12.2	14	0.051	188.0	4317.5	12.0	3935.0	438
08	15.3	14.0	15	0.055	209.2	4314.6	12.0	3929.0	434
09	15.3	13.5	15	0.054	196.1	4228.5	11.8	3853.2	427
10	15.4	12.8	14	0.053	186.7	4267.4	11.9	3891.3	431
11	15.4	12.4	14	0.051	181.9	4264.0	11.9	3890.5	431
12	15.4	12.4	14	0.051	179.7	4230.5	11.8	3857.8	428
13	15.3	11.1	12	0.043	158.6	4133.4	11.8	3761.7	416
14	15.5	11.8	14	0.050	163.9	4111.7	11.8	3748.3	413
15	15.4	11.2	12	0.046	157.8	4147.8	12.1	3787.7	416
16	15.5	12.1	14	0.051	168.6	4124.2	11.9	3760.5	412
17	15.4	12.4	14	0.050	175.3	4189.4	11.9	3819.5	423
18	15.4	13.4	15	0.053	191.0	4178.8	11.8	3811.9	420
19	15.8	11.0	12	0.044	167.1	4183.8	12.1	3816.4	422
20	15.8	10.6	12	0.044	162.9	4170.9	12.1	3804.1	417
21	15.4	11.9	13	0.049	167.4	4147.7	12.0	3779.0	418
22	15.6	13.6	16	0.058	211.9	4445.6	12.7	4053.9	444
23	15.6	12.9	15	0.055	198.9	4430.3	12.6	3690.8	440
24	15.7	11.7	14	0.052	165.9	4086.1	12.1	3725.2	406
25	15.8	11.7	15	0.054	169.2	4148.1	12.3	3791.0	415
26	15.6	13.2	16	0.058	198.8	4339.2	12.2	3963.3	439
27	15.7	10.9	13	0.049	156.1	4173.8	11.8	3814.8	417
28	Down	Down	Down	Down	Down	Down	0.0	Down	Down
29	Down	Down	Down	Down	Down	Down	0.0	Down	Down
30	15.5	12.4	15	0.053	192.8	4601.3	12.2	4039.4	466
Average	15.5	12.4	14	0.051					427
Total					5059	118862	337	107901	11960
Yearly tons					25.2				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 October - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	Down	Down	Down	Down	Down	Down	0.0	Down	Down
02	15.4	13.1	15	0.055	204.5	4643.4	12.8	4241.9	465
03	Down	Down	Down	Down	Down	Down	0.0	Down	Down
04	Down	Down	Down	Down	Down	Down	0.0	Down	Down
05	Down	Down	Down	Down	Down	Down	0.0	Down	Down
06	Down	Down	Down	Down	Down	Down	0.0	Down	Down
07	Down	Down	Down	Down	Down	Down	0.0	Down	Down
08	Down	Down	Down	Down	Down	Down	0.0	Down	Down
09	Down	Down	Down	Down	Down	Down	0.0	Down	Down
10	Down	Down	Down	Down	Down	Down	0.0	Down	Down
11	Down	Down	Down	Down	Down	Down	0.0	Down	Down
12	20.9	0.0	0	0.000	0.0	34.3	0.1	32.5	0
13	Down	Down	Down	Down	Down	Down	0.0	Down	Down
14	Down	Down	Down	Down	Down	Down	0.0	Down	Down
15	Down	Down	Down	Down	Down	Down	0.0	Down	Down
16	Down	Down	Down	Down	Down	Down	0.0	Down	Down
17	Down	Down	Down	Down	Down	Down	0.0	Down	Down
18	17.7	13.1	25	0.090	3.0	39.9	0.5	36.1	0
19	Down	Down	Down	Down	Down	Down	0.0	Down	Down
20	Down	Down	Down	Down	Down	Down	0.0	Down	Down
21	16.7	18.1	28	0.101	105.9	1381.1	5.3	1255.4	118
22	16.1	28.2	37	0.136	310.3	3059.6	10.5	2781.3	279
23	15.3	12.5	14	0.050	176.9	4280.6	11.6	3891.0	432
24	15.4	15.9	18	0.064	177.9	3424.8	9.1	3114.2	346
25	15.4	13.6	15	0.056	205.6	4472.4	11.6	4066.7	453
26	16.1	20.4	26	0.098	138.2	1972.7	6.2	1804.6	186
27	15.6	13.5	16	0.059	211.8	4648.5	12.1	4251.7	470
28	15.3	13.8	15	0.054	257.9	5436.8	13.8	4968.2	550
29	15.6	14.1	16	0.059	239.1	4730.3	12.1	4319.8	479
30	15.6	13.4	16	0.057	225.0	4723.9	12.1	4315.5	479
31	15.7	13.0	15	0.056	199.4	4192.1	12.1	3832.4	410
Average	16.2	14.5	18	0.067					333
Total					2456	47040	130	42911	4667
Yearly tons					26.5				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 November - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	12.9	16	0.060	199.8	4328.3	12.4	3944.9	424
02	16.0	13.4	17	0.062	208.3	4263.2	12.2	3885.0	421
03	15.9	13.2	16	0.059	206.1	4389.2	12.4	4002.9	432
04	15.9	14.0	17	0.064	218.6	4325.5	12.3	3942.8	427
05	16.1	13.5	18	0.064	218.3	4353.6	12.4	3967.5	429
06	16.3	12.5	17	0.063	199.2	4236.0	12.2	3859.5	415
07	16.0	13.1	17	0.061	197.6	4259.0	12.4	3880.6	416
08	15.8	14.3	17	0.064	213.9	4178.7	11.9	3813.6	412
09	15.9	13.6	17	0.062	198.1	4118.8	11.9	3757.8	406
10	15.6	14.9	17	0.064	172.7	3448.7	9.6	3141.5	343
11	15.9	15.4	19	0.070	174.5	3275.3	9.3	2984.8	325
12	15.8	14.7	18	0.067	163.0	3300.3	9.2	3011.3	328
13	15.9	15.2	19	0.070	225.6	4257.4	12.1	3881.1	421
14	15.9	14.7	18	0.068	221.3	4237.1	12.1	3862.6	415
15	15.9	14.3	18	0.064	167.6	3266.8	9.5	2977.3	316
16	15.7	13.8	17	0.060	198.2	4171.8	11.7	3807.2	414
17	16.0	14.2	19	0.068	213.6	4200.4	12.3	3827.2	407
18	16.0	14.4	18	0.068	223.2	4376.1	12.3	3975.8	434
19	16.0	14.4	18	0.067	220.0	4346.2	12.4	3948.4	429
20	16.0	14.2	18	0.067	220.6	4323.7	12.3	3927.4	427
21	15.9	13.8	17	0.063	215.3	4332.2	12.4	3939.7	427
22	15.9	14.8	19	0.068	217.8	4352.0	12.6	3952.2	425
23	15.9	14.7	18	0.067	222.6	4389.5	12.4	3996.2	436
24	16.0	13.6	17	0.064	205.1	4397.3	12.4	4006.4	438
25	15.9	13.7	18	0.064	207.7	4387.0	12.4	3996.4	438
26	15.9	14.0	18	0.065	216.3	4425.3	12.4	4034.2	440
27	15.8	14.2	18	0.065	213.4	4407.3	12.4	4013.4	441
28	15.9	13.8	17	0.063	213.7	4478.1	12.5	4078.0	447
29	15.9	14.8	19	0.068	229.3	4500.5	12.5	4098.5	449
30	15.9	14.6	18	0.067	217.6	4165.2	11.5	3800.6	420
Average	15.9	14.1	18	0.065					413
Total					6219	125491	356	114315	12402
Yearly tons					29.6				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 December - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.8	14.9	18	0.067	228.6	4393.1	12.3	4003.2	435
02	15.9	15.2	20	0.072	236.8	4512.8	12.5	4109.9	449
03	15.9	15.1	19	0.070	238.2	4473.6	12.4	4074.4	444
04	15.9	14.5	18	0.065	233.1	4483.4	12.4	4081.6	448
05	15.8	14.6	18	0.066	230.8	4452.1	12.4	4049.6	440
06	16.0	15.1	19	0.072	175.7	4413.8	12.4	4022.1	438
07	15.9	15.9	20	0.074	187.4	3486.4	9.8	3175.4	343
08	15.9	15.2	19	0.070	237.4	4526.1	12.6	4120.4	450
09	15.7	14.8	18	0.065	236.7	4569.7	12.6	4163.4	455
10	15.8	14.9	18	0.067	232.1	4484.5	12.5	4087.3	448
11	15.7	14.4	17	0.062	217.4	4426.3	12.6	4030.4	438
12	15.7	14.7	17	0.064	225.2	4433.7	12.4	4035.2	439
13	15.7	14.7	17	0.064	225.0	4419.9	12.3	4022.5	438
14	15.6	14.9	17	0.064	227.1	4463.3	12.5	4063.4	444
15	15.7	14.5	17	0.062	227.5	4420.0	12.4	4024.7	440
16	15.8	13.7	16	0.059	212.3	4295.5	11.8	3908.6	429
17	15.8	14.3	18	0.064	222.1	4429.8	12.5	4035.8	439
18	15.9	15.2	19	0.070	236.2	4402.7	12.5	4008.2	437
19	15.8	15.2	19	0.069	239.2	4443.1	12.4	4051.0	441
20	15.8	15.1	18	0.068	237.5	4432.6	12.5	4044.9	442
21	15.8	15.0	18	0.066	227.3	4414.6	12.5	4026.1	438
22	15.8	14.3	17	0.063	225.5	4462.0	12.4	4070.5	449
23	15.8	13.5	16	0.061	212.2	4411.3	12.5	4019.0	439
24	15.6	14.8	17	0.062	104.2	2002.6	6.1	1826.1	190
25	15.9	14.7	18	0.066	107.8	2031.4	6.4	1850.1	189
26	15.9	14.5	18	0.065	106.2	2044.9	6.4	1862.9	191
27	15.8	13.8	17	0.060	103.2	2126.9	6.3	1936.5	204
28	15.7	15.0	18	0.065	228.3	4376.7	12.5	3984.6	433
29	15.7	15.2	18	0.066	230.0	4430.1	12.3	4033.7	439
30	15.7	15.4	18	0.066	236.2	4425.8	12.3	4030.3	442
31	16.1	14.8	19	0.071	117.0	2262.4	6.4	2057.5	224
Average	15.8	14.8	18	0.066					399
Total					6404	124951	352	113809	12375
Yearly tons					32.8				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 January - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.7	15.4	18	0.067	232.0	4432.7	12.4	4038.8	445
02	15.7	14.8	18	0.064	226.3	4419.3	12.4	4025.1	440
03	15.8	16.3	20	0.072	175.4	3325.2	9.2	3028.3	330
04	15.9	15.5	19	0.070	225.2	4182.7	11.6	3809.8	414
05	15.7	15.9	18	0.067	57.1	1036.3	2.9	941.9	101
06	15.9	15.4	20	0.072	206.5	4025.7	10.9	3665.0	404
07	15.5	15.2	17	0.061	239.5	4559.0	12.2	4154.0	458
08	15.5	15.6	17	0.063	242.5	4544.4	12.3	4141.3	455
09	15.6	15.4	18	0.066	241.0	4598.8	12.5	4185.6	458
10	15.4	15.7	17	0.063	233.9	4418.3	12.0	4021.8	445
11	15.5	15.5	17	0.064	229.7	4375.0	12.1	3981.1	439
12	15.5	14.6	16	0.059	229.5	4440.2	12.2	4040.3	446
13	16.1	14.1	17	0.063	238.9	4486.7	12.4	4085.3	448
14	15.8	16.1	19	0.070	188.7	3370.7	9.5	3069.0	334
15	15.7	16.5	20	0.072	170.3	3109.3	8.9	2832.1	306
16	15.7	16.1	20	0.072	134.3	2703.0	7.5	2457.5	267
17	15.5	15.3	18	0.065	229.9	4489.2	12.3	4085.8	446
18	16.1	14.9	19	0.071	84.7	1568.4	5.1	1427.7	143
19	15.7	15.3	18	0.066	240.6	4541.9	12.3	4128.9	456
20	17.8	15.1	29	0.106	4.9	50.8	0.6	46.5	0
21	15.7	16.1	20	0.076	149.9	3559.8	9.8	3243.9	355
22	15.7	14.8	18	0.065	221.5	4343.4	11.8	3957.4	438
23	15.6	15.2	17	0.064	171.9	3367.2	9.2	3061.6	339
24	15.4	13.7	15	0.055	217.0	4532.1	12.5	4123.8	453
25	15.7	13.7	16	0.060	206.5	4284.3	11.9	3900.3	430
26	15.7	14.2	16	0.060	226.7	4446.7	12.3	4052.9	445
27	15.5	15.0	17	0.061	228.8	4433.2	12.3	4036.5	443
28	16.4	14.6	21	0.075	154.0	2826.4	8.4	2574.9	276
29	16.6	14.7	20	0.073	122.6	2247.2	6.4	2046.4	221
30	15.9	16.1	20	0.074	199.6	3681.4	10.4	3358.7	365
31	15.8	16.0	20	0.072	242.3	4549.8	12.5	4152.8	454
Average	15.8	15.3	19	0.068					369
Total					5972	114949	319	104675	11454
Yearly tons					3.0				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 February - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	14.5	17	0.062	231.1	4484.7	12.5	4086.7	446
02	15.6	16.0	18	0.067	178.4	3400.0	9.3	3099.7	343
03	15.7	14.7	17	0.064	228.7	4418.6	12.4	4030.3	440
04	15.7	15.1	18	0.066	185.2	3540.4	9.9	3227.9	352
05	15.6	14.8	17	0.063	226.5	4393.4	12.4	4004.9	437
06	16.0	15.1	19	0.069	210.1	3908.7	11.4	3561.5	381
07	15.3	14.7	16	0.058	331.8	6618.0	17.1	6030.7	679
08	15.7	15.6	18	0.067	171.4	3386.7	9.0	3086.6	339
09	15.5	15.0	17	0.062	231.1	4458.4	12.3	4062.2	445
10	15.9	14.1	18	0.065	224.1	4449.3	12.4	4054.5	445
11	16.0	14.0	17	0.063	228.5	4465.9	12.4	4068.5	443
12	16.0	14.5	19	0.068	235.3	4442.5	12.4	4046.8	442
13	15.6	15.2	17	0.064	109.4	2137.8	5.9	1946.4	214
14	15.9	14.8	18	0.068	177.4	3418.8	9.6	3116.2	340
15	16.0	14.1	17	0.062	233.4	4448.7	12.4	4059.7	444
16	15.5	15.3	17	0.064	222.9	4328.5	11.7	3947.6	436
17	15.5	15.1	17	0.062	239.8	4538.9	12.4	4141.2	459
18	15.7	14.1	15	0.056	221.5	4350.3	11.9	3969.4	440
19	15.7	14.5	17	0.063	232.2	4490.6	12.4	4097.5	455
20	15.9	14.8	18	0.066	236.2	4537.3	12.4	4137.0	458
21	15.7	15.0	18	0.066	226.2	4399.5	11.8	4008.4	443
22	15.8	14.7	18	0.065	239.6	4562.1	12.4	4153.5	460
23	15.7	15.5	19	0.068	223.1	4335.3	11.8	3950.4	435
24	15.6	16.1	19	0.070	189.2	3562.4	9.7	3242.6	356
25	16.0	15.1	20	0.072	242.0	4534.8	12.3	4131.0	457
26	15.7	14.6	18	0.065	226.1	4489.0	12.3	4089.6	449
27	15.7	14.8	17	0.064	233.5	4535.3	12.3	4130.3	455
28	15.7	14.3	17	0.062	228.9	4562.3	12.3	4158.1	455
29	15.9	14.5	17	0.064	185.4	3595.0	9.8	3276.0	361
Average	15.7	14.8	18	0.065					424
Total					6349	122793	337	111915	12309
Yearly tons					6.2				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 March - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.5	15.1	17	0.062	185.1	3571.9	9.7	3256.2	358
02	15.9	14.9	19	0.069	231.5	4442.8	12.3	4050.1	439
03	15.6	15.9	19	0.069	182.7	3488.3	9.7	3175.2	347
04	16.0	13.9	17	0.062	227.5	4396.9	12.2	4003.0	437
05	15.9	14.8	19	0.070	231.2	4501.6	12.4	4096.5	450
06	16.1	14.1	18	0.066	237.4	4528.4	12.3	4123.4	450
07	15.8	14.4	17	0.061	223.5	4386.3	11.8	3993.5	442
08	15.6	15.7	18	0.067	167.1	3370.5	9.3	3068.1	335
09	15.9	15.4	19	0.072	178.6	4295.0	11.7	3912.1	432
10	15.7	15.6	19	0.070	166.0	3362.7	9.2	3062.8	337
11	15.7	15.4	19	0.068	168.5	3377.3	9.2	3072.9	339
12	15.8	14.5	18	0.067	224.8	4499.7	12.4	4091.3	449
13	16.0	14.0	16	0.060	232.3	4541.5	12.4	4135.3	456
14	15.8	15.1	19	0.068	230.9	4517.5	12.4	3770.3	452
15	15.8	14.3	17	0.061	226.4	4497.3	12.3	4091.8	451
16	16.0	13.5	16	0.061	216.9	4421.8	12.3	4022.9	439
17	15.7	15.5	19	0.068	175.6	3484.6	9.7	3167.7	347
18	15.9	14.7	18	0.066	218.7	4329.2	11.8	3941.3	436
19	15.9	15.0	19	0.069	182.4	3516.1	9.7	3203.0	353
20	16.1	13.7	16	0.059	227.3	4427.6	12.3	4030.2	441
21	16.0	14.6	19	0.069	228.2	4468.1	12.3	4065.3	448
22	15.8	14.8	18	0.066	219.4	4371.2	11.8	2162.7	434
23	15.7	15.2	18	0.067	220.7	4338.0	11.8	3210.2	431
24	16.0	13.9	18	0.065	225.9	4504.1	12.3	4101.1	454
25	16.1	14.0	18	0.065	226.9	4477.1	12.2	4071.4	451
26	15.9	15.0	19	0.070	115.7	2268.8	6.2	2066.3	228
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	15.9	16.3	21	0.078	118.4	2264.9	6.4	2058.9	226
29	15.7	14.9	18	0.066	212.9	4275.1	11.8	3888.4	429
30	15.5	15.2	17	0.063	221.9	4316.4	11.8	3924.7	436
31	15.5	15.6	18	0.065	221.7	4299.6	11.9	3919.4	435
Average	15.8	14.8	18	0.066					405
Total					6146	121540	334	107736	12162
Yearly tons					9.2				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 April - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.6	14.2	17	0.061	214.6	4457.3	12.1	4061.5	453
02	15.6	14.3	17	0.062	213.6	4292.8	12.2	3913.8	425
03	15.3	15.0	16	0.059	227.8	4540.0	12.2	4137.9	459
04	15.6	14.1	16	0.057	225.5	4511.3	12.2	4114.6	458
05	16.5	14.3	21	0.076	151.6	2911.8	9.1	2663.7	284
06	15.4	14.9	16	0.060	232.8	4519.7	12.2	4131.0	462
07	15.4	14.4	16	0.058	216.1	4409.5	11.7	4028.6	452
08	15.4	14.7	16	0.060	219.7	4456.9	12.0	4080.8	456
09	15.4	14.9	16	0.060	217.2	4343.8	11.6	3977.4	449
10	15.4	14.8	16	0.061	211.7	4303.7	11.6	3951.9	448
11	15.4	14.6	16	0.060	213.0	4339.5	11.6	3959.2	443
12	15.5	14.7	17	0.061	212.3	4297.1	11.6	3937.2	441
13	15.4	14.7	16	0.060	214.5	4323.8	11.7	3958.2	447
14	15.4	14.5	16	0.060	208.6	4303.3	11.5	3933.0	446
15	15.4	14.9	17	0.062	215.8	4327.2	11.6	3956.3	446
16	15.4	14.1	16	0.057	206.9	4338.1	11.6	3969.4	449
17	15.4	14.0	16	0.058	201.2	4271.6	11.6	3906.9	440
18	15.4	14.5	16	0.058	222.4	4465.1	12.1	4065.6	460
19	15.7	13.4	15	0.055	215.9	4362.9	12.1	3992.5	444
20	15.6	13.5	16	0.057	202.9	4326.6	12.2	3960.6	439
21	15.6	13.9	16	0.059	211.5	4405.5	12.2	4016.8	446
22	15.4	14.3	16	0.057	214.9	4387.1	12.1	3997.8	442
23	Down	Down	Down	Down	Down	Down	0.0	Down	Down
24	16.0	15.1	19	0.070	100.0	1885.5	5.5	1721.6	187
25	15.4	14.2	15	0.057	220.1	4441.6	12.1	4059.5	450
26	15.4	14.2	16	0.057	216.3	4466.3	12.1	4081.1	460
27	15.3	14.7	16	0.058	223.8	4504.6	12.1	4105.6	458
28	15.4	14.8	16	0.060	220.4	4449.2	12.1	4065.0	455
29	15.4	14.4	16	0.059	217.3	4450.7	12.1	4046.8	450
30	15.4	14.5	16	0.058	221.3	4501.9	12.1	4097.9	455
Average	15.5	14.4	16	0.060					435
Total					6090	123594	337	112892	12604
Yearly tons					12.3				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 May - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.4	14.7	16	0.059	222.8	4491.5	11.8	4089.3	453
02	15.3	14.4	15	0.056	226.0	4604.4	12.0	4189.5	469
03	15.3	13.1	14	0.052	207.8	4651.5	12.1	4230.2	471
04	15.4	13.8	16	0.057	219.8	4742.7	12.2	4316.2	483
05	15.2	14.0	15	0.055	220.3	4702.3	12.1	4280.7	478
06	15.3	13.8	15	0.054	214.9	4695.3	12.1	4270.8	475
07	15.4	13.8	15	0.055	212.9	4495.3	12.1	4091.0	455
08	15.3	14.1	15	0.056	221.4	4729.5	12.1	4305.7	481
09	15.3	13.3	14	0.052	209.5	4682.5	12.1	4263.0	474
10	15.3	13.5	14	0.054	204.4	4540.7	11.6	4139.5	462
11	15.3	13.9	15	0.055	218.8	4606.8	12.0	4202.2	469
12	15.5	13.7	16	0.057	229.2	4799.6	12.1	4379.9	484
13	15.2	13.8	15	0.054	224.5	4860.3	12.1	4354.1	481
14	15.3	13.4	14	0.053	202.9	4555.1	11.6	4151.4	465
15	15.4	14.0	15	0.056	207.5	4533.6	11.6	4129.4	462
16	15.3	13.5	15	0.054	204.7	4578.5	11.6	4173.2	465
17	15.2	14.8	16	0.057	226.7	4673.0	11.8	4260.1	472
18	15.2	14.8	16	0.057	226.4	4657.2	11.6	4238.2	471
19	15.2	14.3	15	0.054	232.4	4812.9	12.2	4386.2	489
20	15.2	14.0	15	0.054	225.3	4782.2	12.2	4366.0	489
21	15.2	14.8	15	0.057	236.4	4759.2	12.2	4341.9	489
22	15.2	14.4	15	0.056	226.5	4710.8	12.2	4290.3	480
23	15.2	14.6	15	0.056	231.4	4689.2	12.2	4268.8	474
24	15.2	14.8	15	0.058	230.4	4659.5	12.1	4247.6	470
25	15.4	15.0	16	0.061	218.1	4391.6	11.9	4003.1	442
26	15.4	14.8	16	0.060	223.4	4401.2	12.1	4023.1	447
27	15.4	14.4	15	0.057	217.9	4375.4	12.1	3998.5	444
28	15.4	14.7	16	0.060	214.5	4301.6	11.6	3925.4	437
29	15.4	15.0	16	0.060	224.4	4436.2	12.1	4056.4	449
30	15.4	14.4	16	0.058	179.1	4390.1	12.1	3995.2	439
31	15.8	14.3	17	0.064	169.1	3428.5	9.7	3126.6	346
Average	15.3	14.2	15	0.056					463
Total					6729	141738	369	129094	14365
Yearly tons					15.6				

ORANGE COGEN
 BARTOW, FL
Turbine-1 Monthly Emissions & Operations Report
 June - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.3	14.8	16	0.059	218.2	4513.8	11.5	4126.5	456
02	15.3	14.7	16	0.058	230.6	4551.6	12.0	4157.1	460
03	15.6	13.5	16	0.059	216.9	4616.5	12.2	4216.5	469
04	15.2	14.1	15	0.055	218.0	4590.9	12.0	4188.5	468
05	15.3	13.3	14	0.052	209.5	4572.7	12.1	4168.0	463
06	15.3	13.9	15	0.055	221.5	4647.5	12.1	4240.0	475
07	15.3	13.6	14	0.053	214.6	4614.9	12.1	4207.9	470
08	15.3	14.2	15	0.056	221.0	4474.1	12.1	4081.9	452
09	15.4	14.1	15	0.056	215.0	4387.5	12.0	3999.5	442
10	15.4	13.7	15	0.054	211.2	4413.7	12.1	4027.0	447
11	15.4	13.3	14	0.053	195.9	4266.7	11.6	3891.6	436
12	15.3	13.7	15	0.054	211.4	4434.6	12.1	4041.4	448
13	15.4	13.8	15	0.054	210.7	4398.8	12.1	4007.5	442
14	15.3	14.3	15	0.056	221.9	4457.0	12.2	4065.1	447
15	15.4	14.0	15	0.055	214.9	4454.8	12.2	4056.4	449
16	15.3	14.3	15	0.056	221.2	4492.9	12.2	4095.8	453
17	15.3	14.5	15	0.057	227.4	4540.7	12.3	4139.5	463
18	15.3	14.7	16	0.058	227.0	4492.7	12.2	4094.3	452
19	15.2	14.2	15	0.055	221.5	4605.2	12.2	4196.2	465
20	15.2	14.5	15	0.055	219.1	4500.4	12.2	4107.7	455
21	15.2	14.1	15	0.054	210.8	4488.5	12.1	4097.5	455
22	15.2	13.3	14	0.052	199.9	4463.1	12.1	4075.7	452
23	15.2	14.4	15	0.056	214.7	4446.1	12.1	4059.8	447
24	15.3	13.4	14	0.052	194.4	4384.1	12.1	4000.6	442
25	15.3	13.1	14	0.051	193.3	4410.6	12.2	4027.9	444
26	15.7	13.3	16	0.059	77.4	1685.4	5.0	1536.3	165
27	15.8	15.0	19	0.068	95.4	1934.7	5.6	1766.8	192
28	15.5	13.6	16	0.057	97.9	2131.4	6.0	1947.6	212
29	15.4	14.3	16	0.058	100.9	2116.9	6.1	1927.3	209
30	15.4	14.1	16	0.057	84.4	1760.7	5.1	1606.9	175
Average	15.4	14.0	15	0.056					410
Total					5817	121849	330	111155	12305
Yearly tons					18.6				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 June - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.7	12.7	15	0.053	215.6	4589.4	12.2	4191.8	455
02	15.8	12.6	15	0.054	224.6	4657.8	12.2	4246.4	461
03	15.6	12.9	15	0.054	224.4	4634.5	12.1	4225.6	459
04	15.7	12.2	14	0.052	213.4	4614.3	12.2	4205.1	456
05	15.6	12.9	15	0.054	222.4	4646.1	12.1	4234.9	462
06	15.4	12.9	14	0.051	186.0	4609.3	12.0	4202.3	459
07	15.7	13.1	15	0.055	225.9	4629.3	12.0	4220.6	458
08	15.5	13.0	15	0.053	219.4	4637.2	12.1	4223.1	461
09	15.2	13.4	14	0.052	207.4	4489.0	11.4	4091.0	447
10	15.3	13.6	15	0.054	179.7	4554.6	11.8	4148.5	454
11	15.3	13.9	15	0.054	224.1	4611.3	11.9	4203.4	459
12	15.3	12.8	14	0.050	202.5	4522.7	11.8	4121.4	452
13	15.3	13.0	14	0.050	209.3	4599.4	11.8	4190.7	461
14	15.3	12.8	13	0.050	197.7	4446.2	11.7	4048.2	439
15	16.0	14.1	17	0.064	176.4	3220.1	11.1	2931.9	288
16	15.4	13.0	14	0.052	212.0	4619.5	11.7	4199.2	462
17	15.3	13.3	14	0.052	212.5	4598.5	11.8	4180.6	460
18	15.5	12.8	14	0.052	210.0	4595.1	11.8	4180.0	458
19	15.4	12.6	14	0.051	205.6	4595.5	11.8	4181.8	462
20	15.6	11.9	14	0.050	200.2	4592.3	12.2	4178.1	456
21	15.4	12.1	13	0.049	193.7	4556.3	11.8	4145.0	458
22	15.5	12.3	14	0.051	193.8	4402.8	11.8	4006.2	439
23	15.5	12.5	14	0.051	203.4	4615.0	12.4	4200.9	458
24	15.6	11.9	14	0.050	195.2	4567.6	12.2	4157.1	453
25	15.6	12.5	14	0.052	211.8	4666.4	12.3	4243.0	462
26	15.7	11.9	14	0.050	196.4	4431.2	12.1	4030.8	434
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	Down	Down	Down	Down	Down	Down	0.0	Down	Down
29	16.1	12.7	16	0.058	76.6	1511.2	4.3	1375.4	145
30	15.5	12.6	14	0.052	211.4	4718.5	12.1	4284.1	470
Average	15.5	12.8	14	0.053					439
Total					5651	123931	327	112847	12288
Yearly tons					15.9				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 July - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	16.0	11.0	14	0.050	156.1	3686.5	10.5	3001.7	361
02	15.6	11.7	13	0.049	186.5	4377.4	12.0	3990.2	437
03	16.1	12.3	16	0.058	98.8	2069.7	6.3	1884.5	198
04	15.5	11.4	13	0.047	181.8	4528.7	12.3	4125.4	450
05	15.5	12.8	14	0.052	155.5	3388.2	8.7	3083.8	339
06	15.6	12.7	15	0.053	201.4	4413.0	12.1	4018.1	436
07	15.3	12.5	13	0.049	168.7	3897.2	10.5	3547.5	389
08	15.5	15.8	18	0.067	190.1	3808.2	10.9	3471.9	370
09	15.5	12.6	14	0.050	189.1	4181.4	11.7	3805.8	410
10	15.3	11.8	13	0.046	173.2	4189.6	11.8	3812.8	411
11	15.3	13.2	14	0.052	166.8	3624.1	10.1	3307.2	353
12	15.2	13.2	14	0.051	199.0	4390.5	11.8	4004.8	432
13	15.2	12.7	13	0.048	161.0	3696.2	10.0	3368.9	363
14	15.3	12.2	13	0.048	188.2	4383.1	11.9	3988.4	430
15	15.3	12.6	14	0.050	170.0	3933.8	10.8	3581.0	381
16	15.8	12.0	14	0.052	77.8	1811.2	5.2	1644.2	173
17	15.8	11.0	12	0.044	157.8	3720.7	10.0	3391.8	369
18	15.2	12.2	13	0.046	183.6	4421.3	11.9	4038.8	441
19	15.4	10.5	12	0.042	164.2	4357.4	12.0	3959.6	430
20	15.3	10.5	11	0.041	156.1	4252.9	12.0	3866.1	421
21	15.5	10.4	12	0.043	151.6	4111.5	12.3	3744.9	398
22	15.8	10.0	12	0.044	156.1	4187.4	12.3	3816.0	411
23	15.7	10.0	12	0.043	151.2	4121.5	12.2	3761.4	403
24	15.3	10.5	11	0.041	147.8	4062.7	11.5	3704.7	403
25	15.6	10.2	12	0.042	152.6	4119.9	12.2	3759.9	406
26	15.6	9.9	11	0.041	147.1	4136.9	12.2	3770.6	405
27	15.6	10.1	12	0.043	152.0	4129.7	12.2	3766.0	407
28	15.6	11.3	13	0.048	169.9	4138.9	12.1	3767.9	403
29	Down	Down	Down	Down	Down	Down	0.0	Down	Down
30	Down	Down	Down	Down	Down	Down	0.0	Down	Down
31	Down	Down	Down	Down	Down	Down	0.0	Down	Down
Average	15.5	11.7	13	0.048					387
Total					4554	110140	310	99984	10830
Yearly tons					18.1				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 August - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.7	11.4	13	0.048	174.6	4158.8	12.2	3792.5	407
02	15.9	10.6	13	0.048	112.1	2853.9	8.6	2601.6	278
03	16.0	10.0	13	0.046	154.5	4105.0	12.3	3739.9	401
04	15.5	9.8	11	0.041	142.4	4080.4	11.9	3714.3	403
05	15.5	9.5	11	0.040	138.1	4061.5	11.9	3699.9	402
06	15.6	9.5	11	0.040	126.9	3710.3	10.9	3382.1	366
07	15.6	9.5	11	0.038	146.5	4152.3	12.0	3781.6	410
08	15.3	10.5	11	0.041	151.0	4110.5	11.8	3742.5	407
09	15.4	10.3	11	0.041	150.9	4124.5	11.9	3758.3	410
10	15.4	10.1	11	0.040	142.9	4049.2	11.8	3689.2	402
11	15.5	11.0	12	0.044	164.1	4172.8	12.0	3801.4	411
12	15.5	11.0	12	0.045	165.3	4201.8	11.9	3831.4	416
13	15.5	10.5	12	0.042	155.7	4170.3	12.0	3801.4	411
14	15.5	10.1	11	0.041	150.9	4189.3	12.1	3816.8	414
15	15.6	10.3	12	0.043	155.9	4189.9	12.2	3819.8	412
16	15.6	11.7	13	0.049	180.2	4170.9	12.1	3801.5	408
17	15.5	12.9	14	0.053	190.6	4073.7	11.6	3712.3	400
18	15.7	13.0	15	0.054	198.5	4138.4	12.1	3775.9	400
19	15.5	13.7	15	0.055	195.7	4045.4	11.3	3694.3	406
20	15.7	12.7	15	0.054	197.7	4200.5	12.2	3837.4	418
21	15.7	12.7	15	0.054	199.8	4194.0	12.2	3830.2	413
22	15.5	12.9	14	0.053	191.4	4141.9	12.1	3778.8	409
23	15.7	12.3	14	0.052	192.0	4161.3	12.1	3795.4	411
24	15.7	12.5	14	0.053	193.9	4193.8	12.1	3820.5	414
25	15.6	13.3	15	0.055	204.7	4181.6	12.1	3827.1	412
26	15.6	12.8	14	0.053	199.8	4250.2	12.1	3874.3	419
27	15.4	12.2	13	0.049	97.2	2277.4	6.7	2070.4	221
28	15.8	11.9	14	0.052	104.6	2304.6	7.0	2096.1	221
29	16.0	11.2	14	0.051	100.5	2291.0	7.0	2085.1	219
30	15.7	12.0	14	0.051	181.2	4072.8	12.1	3712.4	392
31	15.8	11.7	14	0.052	162.6	3731.3	11.2	3402.4	360
Average	15.6	11.4	13	0.048					383
Total					5022	120759	352	110087	11873
Yearly tons					20.7				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 September - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.4	11.9	13	0.047	181.9	4332.7	11.7	3949.7	433
02	15.5	11.5	13	0.046	145.3	4287.5	11.7	3914.5	431
03	15.4	11.7	13	0.046	178.4	4314.4	11.8	3934.6	431
04	15.4	11.8	13	0.047	178.6	4306.6	11.8	3929.0	431
05	15.4	11.6	12	0.046	176.7	4313.4	11.8	3934.2	432
06	15.4	11.8	13	0.047	179.2	4303.7	11.8	3926.8	434
07	15.3	11.7	13	0.046	177.2	4334.1	11.8	3950.5	436
08	15.3	13.0	14	0.051	200.5	4389.4	11.9	3997.1	440
09	15.7	12.4	15	0.053	200.8	4361.8	12.0	3974.4	436
10	15.8	11.8	13	0.049	200.3	4430.1	12.1	4039.6	442
11	15.5	12.3	14	0.050	196.8	4448.1	12.0	4058.3	448
12	15.5	11.6	13	0.047	181.2	4368.1	12.0	3983.1	436
13	15.3	12.3	13	0.048	190.1	4423.5	12.0	4025.5	445
14	15.5	11.7	13	0.048	184.7	4385.8	12.0	3997.7	439
15	15.5	12.0	13	0.049	184.3	4303.6	11.9	3930.2	429
16	15.4	11.9	13	0.048	185.7	4392.1	12.1	4004.6	437
17	15.4	12.0	13	0.048	186.8	4399.8	12.1	4011.1	437
18	15.4	12.0	13	0.048	186.9	4391.4	12.1	4005.8	439
19	15.5	11.7	13	0.048	180.4	4296.1	11.9	3919.1	428
20	15.5	11.7	13	0.048	179.4	4262.5	11.9	3887.6	426
21	15.5	12.1	13	0.049	195.1	4537.5	12.5	4134.0	451
22	15.7	11.6	13	0.049	191.1	4454.4	12.6	4061.6	442
23	15.6	12.4	14	0.051	208.3	4540.5	12.6	3782.6	448
24	15.7	11.6	14	0.050	182.4	4257.0	12.1	3880.7	423
25	15.8	11.7	14	0.051	190.2	4303.6	12.2	3933.4	428
26	15.8	11.1	13	0.049	181.0	4309.3	12.1	3935.9	432
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	15.9	12.4	15	0.054	221.0	4555.3	12.7	4161.7	452
29	15.6	12.9	15	0.054	211.8	4486.4	12.2	4096.9	450
30	Down	Down	Down	Down	Down	Down	0.0	Down	Down
Average	15.5	11.9	13	0.049					437
Total					5256	122489	337	111360	12236
Yearly tons					23.3				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 October - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.5	13.5	15	0.055	216.0	4510.4	12.0	4118.9	453
02	Down	Down	Down	Down	Down	Down	0.0	Down	Down
03	Down	Down	Down	Down	Down	Down	0.0	Down	Down
04	Down	Down	Down	Down	Down	Down	0.0	Down	Down
05	Down	Down	Down	Down	Down	Down	0.0	Down	Down
06	Down	Down	Down	Down	Down	Down	0.0	Down	Down
07	Down	Down	Down	Down	Down	Down	0.0	Down	Down
08	Down	Down	Down	Down	Down	Down	0.0	Down	Down
09	Down	Down	Down	Down	Down	Down	0.0	Down	Down
10	Down	Down	Down	Down	Down	Down	0.0	Down	Down
11	Down	Down	Down	Down	Down	Down	0.0	Down	Down
12	20.4	Invalid	Invalid	Invalid	Invalid	19.0	0.3	18.1	0
13	Down	Down	Down	Down	Down	Down	0.0	Down	Down
14	Down	Down	Down	Down	Down	Down	0.0	Down	Down
15	Down	Down	Down	Down	Down	Down	0.0	Down	Down
16	Down	Down	Down	Down	Down	Down	0.0	Down	Down
17	Down	Down	Down	Down	Down	Down	0.0	Down	Down
18	Down	Down	Down	Down	Down	Down	0.0	Down	Down
19	Down	Down	Down	Down	Down	Down	0.0	Down	Down
20	Down	Down	Down	Down	Down	Down	0.0	Down	Down
21	Down	Down	Down	Down	Down	Down	0.0	Down	Down
22	Down	Down	Down	Down	Down	Down	0.0	Down	Down
23	15.3	13.5	14	0.052	107.3	2315.0	6.4	2104.0	230
24	15.7	14.1	17	0.062	222.0	4554.7	12.2	4141.4	454
25	16.1	14.6	17	0.064	167.3	3522.6	9.5	3202.7	352
26	15.8	13.6	16	0.060	199.8	4042.3	11.0	3696.6	406
27	15.4	15.0	17	0.062	238.5	4653.5	12.0	4256.3	469
28	15.4	14.7	16	0.060	228.6	4596.0	11.7	4199.4	462
29	15.5	15.1	17	0.063	238.5	4630.7	11.9	4228.7	469
30	15.5	14.4	16	0.060	230.6	4598.9	11.8	4201.4	460
31	16.4	14.4	18	0.065	133.5	2252.9	6.7	2060.2	218
Average	16.1	14.3	16	0.060					361
Total					1982	39696	106	36228	3973
Yearly tons					24.3				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 November - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	15.1	19	0.069	180.2	3406.8	9.5	3103.3	336
02	15.9	15.3	19	0.070	181.9	3445.5	9.7	3137.1	342
03	16.0	15.3	20	0.074	173.9	3329.4	9.6	3033.9	323
04	15.8	15.7	20	0.072	178.5	3372.4	9.5	3073.4	332
05	15.9	15.6	20	0.072	178.6	3392.7	9.4	3089.9	336
06	15.9	15.6	19	0.072	175.9	3362.6	9.2	3062.0	333
07	15.9	16.6	21	0.077	184.9	3328.0	9.3	3030.3	330
08	16.0	14.6	19	0.068	181.7	3399.1	9.8	3100.5	332
09	15.9	15.4	19	0.070	180.9	3342.9	9.6	3048.3	329
10	15.7	14.7	18	0.065	230.7	4445.1	12.7	4050.6	439
11	16.5	16.6	24	0.088	159.1	2560.7	8.3	2335.6	239
12	16.0	13.7	18	0.065	210.8	4209.2	12.2	3840.5	410
13	15.8	13.9	17	0.062	162.6	3309.9	9.2	3016.7	327
14	15.8	14.7	18	0.065	170.4	3317.3	9.2	3023.1	328
15	15.9	13.3	16	0.060	202.7	4180.1	12.1	3810.8	408
16	15.7	14.1	16	0.060	169.4	3388.4	9.6	3091.4	332
17	15.8	14.5	18	0.065	173.0	3355.2	9.6	3053.8	327
18	16.1	13.9	18	0.067	172.9	3425.7	9.6	3111.5	334
19	15.9	14.1	17	0.064	172.3	3356.8	9.5	3049.2	328
20	15.9	14.1	17	0.063	172.3	3353.5	9.4	3046.6	329
21	16.2	12.9	16	0.060	151.6	3057.9	8.6	2780.8	303
22	15.9	14.5	18	0.066	166.4	3296.5	9.1	2993.3	326
23	15.9	14.6	18	0.067	170.5	3321.6	9.4	3025.8	326
24	Down	Down	Down	Down	Down	Down	0.0	Down	Down
25	Down	Down	Down	Down	Down	Down	0.0	Down	Down
26	Down	Down	Down	Down	Down	Down	0.0	Down	Down
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	Down	Down	Down	Down	Down	Down	0.0	Down	Down
29	Down	Down	Down	Down	Down	Down	0.0	Down	Down
30	16.5	26.3	37	0.133	24.7	212.0	1.1	192.6	13
Average	16.0	15.2	19	0.071					323
Total					4126	79169	225	72101	7762
Yearly tons					26.3				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 December - 2011

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	Down	Down	Down	Down	Down	Down	0.0	Down	Down
02	Down	Down	Down	Down	Down	Down	0.0	Down	Down
03	Down	Down	Down	Down	Down	Down	0.0	Down	Down
04	18.3	9.8	22	0.082	1.4	18.7	0.2	17.1	0
05	15.9	15.1	19	0.069	180.9	3409.2	9.6	3098.5	333
06	15.9	15.0	19	0.070	166.6	3235.7	9.0	2947.7	320
07	15.9	15.6	19	0.071	191.6	4333.3	11.9	3948.9	432
08	15.9	15.0	19	0.069	168.6	3236.6	9.1	2944.2	321
09	15.6	14.5	17	0.061	161.1	3329.1	9.2	3033.6	331
10	15.7	14.5	17	0.062	161.8	3321.3	9.2	3025.7	328
11	15.7	14.7	18	0.064	163.7	3321.7	9.3	3023.0	330
12	15.7	14.2	17	0.062	156.2	3326.9	9.2	3027.1	330
13	15.7	13.8	16	0.059	155.0	3331.0	9.2	3030.6	331
14	15.9	13.8	17	0.063	146.6	3056.1	8.7	2782.5	298
15	15.7	14.9	18	0.066	170.8	3361.6	9.5	3060.2	331
16	16.0	14.2	17	0.062	177.3	3341.9	9.6	3038.8	323
17	15.7	14.5	17	0.062	164.8	3376.2	9.3	3074.9	335
18	15.9	14.4	18	0.065	156.7	2974.1	8.7	2706.1	288
19	15.6	13.9	16	0.058	164.6	3319.5	9.2	3026.9	328
20	15.8	13.9	16	0.061	160.8	3183.2	9.1	2902.9	313
21	15.7	13.5	16	0.057	157.1	3272.3	9.2	2983.6	324
22	15.7	13.4	16	0.057	157.0	3261.0	9.2	2975.1	321
23	15.6	13.5	15	0.056	160.7	3322.2	9.2	3025.5	330
24	15.6	14.2	16	0.058	107.7	2117.3	5.8	1924.7	209
25	15.6	14.2	16	0.058	111.6	2185.1	6.0	1986.4	215
26	15.5	14.3	16	0.058	103.3	2028.9	5.8	1843.7	196
27	15.6	13.2	15	0.055	104.3	2186.1	6.1	1989.2	214
28	15.8	13.4	16	0.059	95.4	1975.8	5.6	1798.3	192
29	15.7	14.3	17	0.061	167.7	3348.3	9.3	3047.4	332
30	15.8	14.1	17	0.062	62.8	1260.2	3.6	1146.5	122
31	15.6	14.1	16	0.058	111.4	2185.7	6.1	1989.1	216
Average	15.8	14.1	17	0.062					284
Total					3988	80619	226	73398	7943
Yearly tons					28.3				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 January - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	13.8	17	0.062	162.2	3231.2	9.2	2943.1	316
02	15.7	14.3	17	0.061	167.6	3324.4	9.2	3026.7	328
03	15.9	13.4	16	0.060	217.8	4422.3	12.4	4027.4	437
04	16.2	16.6	22	0.081	70.8	1209.6	3.5	1100.3	116
05	15.8	15.2	18	0.066	246.3	4463.3	12.6	4059.9	436
06	15.5	15.9	18	0.066	218.5	3943.3	10.8	3589.4	391
07	15.7	15.0	18	0.065	173.3	3391.9	9.2	3090.8	337
08	15.7	15.9	19	0.069	176.1	3411.4	9.1	3108.0	339
09	15.7	19.2	23	0.085	144.4	2387.5	6.8	2172.1	231
10	16.9	14.5	19	0.070	84.9	1329.2	4.3	1209.8	121
11	Down	Down	Down	Down	Down	Down	0.0	Down	Down
12	Down	Down	Down	Down	Down	Down	0.0	Down	Down
13	15.9	16.4	21	0.076	94.4	1784.1	5.2	1623.8	172
14	16.0	19.3	25	0.093	156.7	2681.2	7.6	2441.4	264
15	16.7	17.1	23	0.085	180.2	2797.5	7.8	2543.0	276
16	15.8	15.6	20	0.072	234.8	4593.9	12.6	4182.2	457
17	16.0	14.3	17	0.064	156.8	3088.2	8.4	2807.4	307
18	16.0	16.2	21	0.075	53.0	936.0	2.9	850.5	89
19	15.7	15.6	19	0.069	172.2	3380.9	9.2	3074.4	337
20	15.5	14.9	17	0.061	227.3	4419.1	12.0	4028.0	442
21	15.8	13.2	15	0.055	209.6	4321.7	11.9	3941.8	432
22	15.6	14.2	16	0.059	173.2	3548.4	9.8	3229.1	354
23	15.5	14.6	16	0.059	229.6	4496.0	12.3	4091.6	450
24	15.5	14.4	16	0.059	164.9	3379.8	9.1	3073.7	338
25	15.5	14.4	16	0.059	174.8	3552.8	9.8	3232.9	353
26	15.6	15.1	17	0.063	171.1	3396.8	9.2	3095.6	338
27	15.7	15.0	18	0.064	170.0	3382.2	9.1	3078.5	337
28	15.7	15.4	18	0.066	176.8	3406.7	9.1	3096.3	341
29	15.8	14.8	18	0.065	233.4	4496.3	12.0	4095.4	450
30	15.9	14.9	19	0.069	227.7	4379.9	12.1	3998.9	435
31	15.7	16.1	19	0.071	177.4	3411.1	9.1	3112.6	342
Average	15.8	15.4	19	0.068					330
Total					5046	96567	266	87925	9566
Yearly tons					2.5				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 February - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.6	15.3	18	0.065	170.9	3416.0	9.3	3112.6	341
02	15.9	13.9	16	0.060	238.0	4577.1	12.5	4173.8	460
03	15.7	14.0	16	0.060	161.4	3359.5	9.2	3063.3	336
04	15.6	14.3	16	0.059	197.4	4034.1	11.2	3679.0	402
05	15.7	14.4	17	0.062	157.2	3266.9	9.0	2977.8	327
06	15.6	14.2	16	0.060	160.5	3349.1	9.2	3051.4	335
07	15.7	14.8	17	0.064	170.9	3397.1	9.2	3096.9	338
08	15.5	14.6	16	0.060	289.2	5702.5	15.1	5197.3	571
09	15.7	14.6	17	0.063	170.7	3393.5	9.3	3090.9	337
10	15.6	14.2	16	0.061	160.8	3336.5	9.2	3039.4	330
11	15.6	14.5	17	0.062	165.8	3332.7	9.2	3034.1	331
12	15.8	15.7	19	0.071	67.0	1288.7	3.6	1173.3	127
13	15.8	15.3	19	0.068	123.9	2301.4	6.5	2097.9	229
14	15.7	14.0	16	0.061	215.2	4338.6	11.8	3957.0	431
15	15.7	14.3	17	0.061	164.2	3367.8	9.2	3072.0	337
16	15.5	14.7	16	0.060	179.8	3609.8	9.8	3290.5	362
17	15.6	14.2	16	0.059	168.8	3416.4	9.3	3116.5	344
18	15.6	14.8	17	0.062	180.0	3469.6	9.7	3163.5	345
19	15.6	14.3	16	0.060	166.7	3370.7	9.3	3074.5	339
20	15.7	14.9	18	0.065	166.7	3326.1	9.2	3031.8	332
21	15.6	13.8	16	0.058	173.5	3564.2	9.7	3245.4	356
22	15.6	14.5	17	0.061	164.9	3405.3	9.3	3099.6	338
23	15.6	14.7	17	0.063	179.4	3573.7	9.7	3254.8	357
24	15.8	13.8	17	0.061	211.8	4333.2	11.8	3945.8	432
25	Down	Down	Down	Down	Down	Down	0.0	Down	Down
26	Down	Down	Down	Down	Down	Down	0.0	Down	Down
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	15.8	14.3	17	0.063	109.4	2126.8	6.0	1938.8	208
29	15.9	13.2	15	0.056	212.5	4361.5	11.8	3976.2	438
Average	15.7	14.4	17	0.062					349
Total					4527	91019	249	82954	9083
Yearly tons					4.8				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 March - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.9	13.3	15	0.056	212.3	4343.3	11.8	3960.2	435
02	15.7	14.4	17	0.063	164.7	3381.5	9.3	3082.2	334
03	16.0	13.2	15	0.056	213.4	4294.7	11.8	3911.4	429
04	15.9	14.6	18	0.066	169.0	3387.7	9.3	3083.4	338
05	15.8	15.4	19	0.070	176.1	3399.3	9.2	3092.9	337
06	15.8	15.0	18	0.067	169.6	3412.4	9.2	3106.6	339
07	16.0	13.7	16	0.059	176.0	3587.9	9.8	3267.4	357
08	15.9	13.4	16	0.058	185.4	4484.3	12.2	4082.4	445
09	15.7	15.4	18	0.067	187.2	3532.4	9.7	3215.1	347
10	15.9	13.7	17	0.062	224.3	4462.2	12.2	4066.4	446
11	15.9	13.9	17	0.064	223.5	4462.6	12.2	4062.0	444
12	15.7	14.3	17	0.062	168.3	3427.6	9.3	3115.4	340
13	15.6	14.0	16	0.059	164.8	3428.5	9.3	3120.9	343
14	15.7	14.9	18	0.065	166.6	3344.8	9.2	2964.3	332
15	15.7	14.5	17	0.063	168.5	3425.8	9.4	3116.1	339
16	15.7	14.3	17	0.062	164.1	3397.3	9.3	3090.9	339
17	15.9	13.9	17	0.061	209.5	4307.1	11.7	3916.4	430
18	15.9	13.7	17	0.063	168.3	3555.3	9.8	3237.0	351
19	15.9	13.7	16	0.059	213.7	4330.6	11.9	3944.6	433
20	15.7	14.3	17	0.063	162.1	3318.1	9.1	3020.3	330
21	15.7	14.8	18	0.064	169.1	3392.8	9.4	3086.4	336
22	16.0	13.6	15	0.056	185.7	3647.0	9.8	1482.8	358
23	16.0	14.2	16	0.060	187.2	3589.7	9.8	3142.7	354
24	Down	Down	Down	Down	Down	Down	0.0	Down	Down
25	Down	Down	Down	Down	Down	Down	0.0	Down	Down
26	16.1	13.7	18	0.066	110.6	2199.9	6.2	2001.1	216
27	15.9	14.1	17	0.064	219.7	4339.8	11.8	3950.9	433
28	15.9	13.9	17	0.064	114.5	2238.9	6.2	2038.6	223
29	Down	Down	Down	Down	Down	Down	0.0	Down	Down
30	Down	Down	Down	Down	Down	Down	0.0	Down	Down
31	Down	Down	Down	Down	Down	Down	0.0	Down	Down
Average	15.8	14.2	17	0.062					362
Total					4674	94692	259	84158	9408
Yearly tons					7.1				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 April - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.7	13.8	16	0.059	215.7	4438.4	12.4	4044.4	442
02	15.4	14.7	16	0.060	219.6	4421.2	11.6	4031.0	447
03	15.4	14.7	17	0.060	214.4	4287.9	11.5	3908.4	431
04	15.4	14.7	16	0.060	220.2	4399.1	11.7	4012.1	446
05	15.8	14.3	17	0.065	219.5	4411.4	11.9	4034.8	447
06	15.4	15.0	17	0.061	223.9	4418.0	11.7	4038.1	453
07	15.8	13.0	14	0.053	226.5	4590.0	12.2	4193.1	467
08	15.5	14.4	16	0.060	216.2	4352.2	11.6	3985.3	447
09	15.8	13.3	15	0.054	222.7	4492.8	12.1	4113.8	457
10	15.8	13.2	15	0.054	222.1	4450.5	12.1	4087.1	457
11	15.4	14.1	15	0.057	225.0	4506.3	12.1	4111.2	454
12	15.5	14.5	16	0.059	223.6	4443.4	12.1	4070.9	453
13	15.8	13.2	15	0.055	217.9	4425.0	12.1	4050.2	448
14	15.5	14.3	16	0.058	223.7	4460.0	12.1	4076.0	452
15	15.8	13.1	14	0.053	221.8	4482.7	12.2	4097.9	453
16	15.7	12.7	14	0.052	214.6	4481.6	12.1	4099.9	459
17	15.7	12.8	14	0.050	214.2	4434.0	12.0	4054.6	453
18	15.9	14.6	18	0.066	70.8	1319.3	4.0	1206.5	129
19	15.4	14.2	15	0.057	209.7	4270.0	11.7	3907.9	437
20	15.5	14.5	16	0.060	209.5	4244.4	11.7	3885.7	434
21	15.4	13.9	15	0.056	203.4	4316.5	11.7	3935.3	437
22	15.4	14.1	16	0.057	207.8	4306.9	11.7	3924.9	436
23	15.5	13.7	15	0.056	217.0	4430.5	12.1	4050.6	448
24	15.5	14.1	16	0.058	221.2	4447.6	12.1	4058.8	452
25	Down	Down	Down	Down	Down	Down	0.0	Down	Down
26	Down	Down	Down	Down	Down	Down	0.0	Down	Down
27	Down	Down	Down	Down	Down	Down	0.0	Down	Down
28	Down	Down	Down	Down	Down	Down	0.0	Down	Down
29	Down	Down	Down	Down	Down	Down	0.0	Down	Down
30	16.1	17.2	23	0.086	137.1	2366.7	8.4	2156.6	210
Average	15.6	14.1	16	0.059					426
Total					5218	105196	287	96135	10649
Yearly tons					9.7				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 May - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.3	15.3	16	0.061	267.2	5147.7	13.8	4680.1	506
02	16.2	16.4	22	0.080	163.9	2737.6	8.4	2492.0	258
03	15.4	15.6	17	0.063	224.1	4302.1	11.5	3912.3	427
04	15.7	14.3	17	0.063	222.9	4560.0	11.8	4149.9	459
05	15.4	14.7	16	0.061	217.1	4510.7	11.6	4106.4	452
06	15.4	14.4	16	0.059	212.4	4520.1	11.6	4111.5	453
07	15.5	13.8	16	0.058	200.2	4323.4	11.6	3934.4	437
08	15.5	14.7	16	0.061	215.6	4371.3	11.6	3979.6	438
09	15.4	15.3	17	0.063	216.1	4308.9	11.6	3922.9	433
10	15.5	14.9	16	0.061	232.3	4483.5	12.1	4087.0	450
11	15.5	15.8	18	0.065	233.3	4417.6	11.8	4029.6	445
12	15.5	14.3	16	0.059	216.7	4407.4	11.7	4022.0	441
13	15.5	14.6	16	0.060	214.2	4412.4	11.6	3950.9	438
14	15.4	13.7	15	0.055	218.3	4518.0	12.1	4117.2	454
15	15.3	14.1	15	0.055	221.4	4470.1	12.0	4069.8	451
16	15.4	13.7	15	0.055	220.0	4517.6	12.1	4116.3	454
17	15.5	14.3	16	0.059	226.6	4504.6	12.2	4106.1	449
18	15.4	14.6	16	0.058	231.4	4535.9	12.2	4127.4	453
19	15.4	14.2	15	0.057	217.3	4412.6	11.7	4021.9	444
20	15.5	15.0	17	0.061	222.5	4373.3	11.7	3993.4	442
21	15.5	15.2	17	0.062	222.7	4373.0	11.7	3989.9	441
22	15.5	15.0	17	0.062	215.8	4355.0	11.7	3966.3	439
23	15.4	15.1	17	0.062	215.7	4325.4	11.7	3937.7	432
24	15.4	15.5	17	0.063	219.2	4283.0	11.5	3904.6	431
25	15.5	14.9	17	0.062	219.3	4347.2	11.9	3962.6	429
26	15.5	15.0	17	0.063	216.0	4286.0	11.6	3918.4	435
27	15.5	14.9	17	0.062	214.2	4265.8	11.6	3898.7	433
28	15.5	14.9	17	0.061	228.0	4377.8	12.1	3994.4	435
29	15.5	16.0	19	0.068	186.6	4296.8	11.6	3929.4	435
30	15.4	15.2	17	0.062	217.4	4271.2	11.5	3887.0	428
31	15.5	15.2	17	0.063	209.4	4130.4	11.6	3764.5	411
Average	15.5	14.9	17	0.061					437
Total					6758	135146	363	123084	13533
Yearly tons					13.1				

ORANGE COGEN
 BARTOW, FL
Turbine-2 Monthly Emissions & Operations Report
 June - 2012

Emission Limits
Yearly Limits
 NOx tons/year - 97

Day	O2%	NOx ppm	NOx ppm @ 15% O2	NOx lb/mmBtu	NOx lbs	Gas Flow kscf	Turbine On-Time	Heat Input mmBtu	Megawatts
01	15.5	15.2	17	0.063	222.9	4321.7	12.0	3950.5	431
02	15.5	15.0	17	0.062	216.0	4257.4	11.6	3888.4	427
03	15.7	14.3	17	0.063	207.9	4282.1	11.7	3911.2	433
04	15.4	15.5	17	0.064	223.2	4427.9	11.6	4039.9	448
05	15.5	15.0	17	0.062	217.0	4395.9	11.5	4006.9	447
06	15.5	15.1	17	0.063	215.1	4392.5	11.5	4007.1	446
07	15.5	15.1	17	0.062	220.1	4419.3	11.6	4029.5	447
08	15.5	15.0	17	0.062	214.5	4297.8	11.6	3921.1	433
09	15.5	15.0	17	0.063	212.3	4243.1	11.6	3867.6	426
10	15.5	14.3	16	0.059	210.3	4281.7	11.6	3907.0	432
11	15.5	14.5	16	0.058	223.8	4411.0	12.1	4022.9	442
12	15.5	15.1	17	0.062	219.6	4292.3	11.6	3912.0	433
13	15.4	15.5	17	0.063	221.7	4276.8	11.5	3896.5	429
14	15.5	14.7	16	0.061	212.3	4302.7	11.8	3924.3	430
15	15.5	14.1	16	0.059	203.8	4267.0	11.7	3885.2	427
16	15.5	14.2	16	0.060	203.8	4291.8	11.7	3912.4	431
17	15.5	15.1	17	0.063	215.3	4307.9	11.7	3927.3	439
18	15.5	15.3	17	0.063	223.0	4333.8	11.7	3949.6	440
19	15.4	15.1	17	0.062	221.5	4423.0	11.7	4030.3	444
20	15.3	15.2	17	0.061	215.4	4362.7	11.7	3982.4	440
21	15.2	14.9	16	0.059	206.8	4326.4	11.5	3949.5	439
22	15.6	14.3	17	0.061	208.6	4368.7	11.8	3989.8	439
23	15.3	15.0	16	0.059	216.7	4364.5	11.8	3985.3	443
24	15.3	14.7	16	0.058	211.6	4315.8	11.6	3938.6	436
25	15.3	15.1	16	0.060	210.3	4305.4	11.6	3931.8	438
26	15.4	14.2	16	0.057	213.1	4343.4	11.8	3963.9	438
27	15.6	14.7	17	0.063	239.3	4582.5	12.3	4188.5	463
28	15.4	14.9	16	0.061	230.3	4522.6	12.1	4130.8	457
29	15.4	14.8	17	0.061	212.0	4340.8	11.5	3958.1	438
30	15.4	14.7	17	0.061	210.8	4359.8	11.5	3977.0	441
Average	15.5	14.9	17	0.061					439
Total					6479	130418	351	118985	13157
Yearly tons					16.4				