



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:12 AM

Facility Name: Osprey Energy Center

Facility Details

Facility ID (ORISPL): 55412
 Monitoring Plan Locations: CT1
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)	
CT1	2011	QTR 1	791	40	773.33	1212847	0.4	72078.5	0.013	6.9		
		QTR 2	1727	89	1663.15	2808660	0.8	166914.9	0.012	15.7		
		QTR 3	1898	92	1851.38	2961151	0.9	175975.3	0.011	16.4		
		QTR 4	1469	73	1398.55	2104575	0.6	125071.7	0.012	11.9		
		Ozone Season To Date	3024		2930.86	4783700					26.6	
		Year To Date	5885	294	5686.41	9087233	2.7	540040.4	0.012	50.9		

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
CT1	2011	QTR 1	PNG	791
		QTR 2	PNG	1727
		QTR 3	PNG	1898
		QTR 4	PNG	1469



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:11 AM

Facility Name: Osprey Energy Center

Facility Details

Facility ID (ORISPL): 55412
Monitoring Plan Locations: CT1
State: FL
County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)
CT1	2012	QTR 1	1409	68	1371.88	2336376	0.7	138848.9	0.012	13.0	
		Ozone Season To Date									
		Year To Date	1409	68	1371.88	2336376	0.7	138848.9	0.012	13.0	

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
CT1	2012	QTR 1	PNG	1409



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:13 AM

Facility Name: Osprey Energy Center

Facility Details

Facility ID (ORISPL): 55412
 Monitoring Plan Locations: CT2
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)	
CT2	2011	QTR 1	874	46	850.48	1355719	0.4	80568.2	0.013	7.8		
		QTR 2	1742	90	1660.20	2799985	0.8	166401.4	0.012	16.0		
		QTR 3	1872	91	1816.72	2884956	0.9	171447.4	0.012	17.3		
		QTR 4	1385	62	1359.92	2143081	0.6	127358.6	0.013	13.1		
		Ozone Season To Date	3011		2903.16	4719143					27.9	
		Year To Date	5873	289	5687.32	9183741	2.7	545775.6	0.012	54.2		

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
CT2	2011	QTR 1	PNG	874
		QTR 2	PNG	1742
		QTR 3	PNG	1872
		QTR 4	PNG	1385



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:12 AM

Facility Name: Osprey Energy Center

Facility Details

Facility ID (ORISPL): 55412
Monitoring Plan Locations: CT2
State: FL
County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)
CT2	2012	QTR 1	1370	65	1336.14	2290412	0.7	136116.6	0.013	14.0	
		Ozone Season To Date									
		Year To Date	1370	65	1336.14	2290412	0.7	136116.6	0.013	14.0	

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
CT2	2012	QTR 1	PNG	1370



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:13 AM

Facility Name: Auburndale Peaker Energy Center

Facility Details

Facility ID (ORISPL): 55833
 Monitoring Plan Locations: 6
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)	
6	2011	QTR 1	0	0	0.00	0	0.0	0.0	0.000	0.0		
		QTR 2	438	50	387.22	478119	0.1	28414.8	0.102	22.1		
		QTR 3	61	11	48.68	55064	0.0	3272.7	0.108	2.6		
		QTR 4	0	0	0.00	0	0.0	0.0	0.000	0.0		
		Ozone Season To Date	427		373.37	459150					21.3	
		Year To Date	499	61	435.90	533183	0.1	31687.5	0.103	24.7		

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
6	2011	QTR 1	NO DATA	0
		QTR 2	PNG	438
		QTR 3	PNG	61
		QTR 4	NO DATA	0



ECMPS Client Tool

Version 1.0 2012 Q1

Emissions Summary Report

May 15, 2012 08:13 AM

Facility Name: Auburndale Peaker Energy Center

Facility Details

Facility ID (ORISPL): 55833
 Monitoring Plan Locations: 6
 State: FL
 County: Polk

Quarterly Emissions Summary Data

Unit/Stack/Pipe	Year	Period	No. of Op. Hours	No. of Op. Days	Op. Time	Heat Input (mmBtu)	SO2 Mass (ton)	CO2 Mass (ton)	NOx Rate (lb/mmBtu)	NOx Mass (ton)	BCO2 Mass (ton)
6	2012	QTR 1	28	3	24.97	31168	0.0	1852.4	0.102	1.4	
		Ozone Season To Date									
		Year To Date	28	3	24.97	31168	0.0	1852.4	0.102	1.4	

Fuel Operating Hours

Unit/Stack/Pipe	Year	Period	Fuel Code	No. of Op. Hours
6	2012	QTR 1	PNG	28